

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Grant High School (217) - Test 1**

| Sample Identification # | Location             | Date/Time Collected | Date Analyzed | Lab ID     | Analyte | Results | Detection Limit | PPS Action Level* | Units |
|-------------------------|----------------------|---------------------|---------------|------------|---------|---------|-----------------|-------------------|-------|
| 217-CH5600-A-001-A      | Hallway (077)        | 8/20/2019           | 8/23/2019     | A9H0672-03 | Lead    | ND      | 0.20            | 15                | ppb   |
| 217-CH5600-B-001-A      | Hallway (077)        | 8/20/2019           | 8/23/2019     | A9H0672-04 | Lead    | ND      | 0.20            | 15                | ppb   |
| 217-CH5600-C-001-A      | Hallway (077)        | 8/20/2019           | 8/23/2019     | A9H0672-05 | Lead    | ND      | 0.20            | 15                | ppb   |
| 217-CH5603-A-001-A      | Hallway (027)        | 8/20/2019           | 8/23/2019     | A9H0672-06 | Lead    | ND      | 0.20            | 15                | ppb   |
| 217-CH5603-B-001-A      | Hallway (027)        | 8/20/2019           | 8/23/2019     | A9H0672-07 | Lead    | ND      | 0.20            | 15                | ppb   |
| 217-CH5603-C-001-A      | Hallway (027)        | 8/20/2019           | 8/23/2019     | A9H0672-08 | Lead    | ND      | 0.20            | 15                | ppb   |
| 217-CH5604-A-001-A      | Main Gym (North)     | 8/20/2019           | 8/23/2019     | A9H0672-09 | Lead    | ND      | 0.20            | 15                | ppb   |
| 217-CH5604-B-001-A      | Main Gym (North)     | 8/20/2019           | 8/23/2019     | A9H0672-10 | Lead    | ND      | 0.20            | 15                | ppb   |
| 217-CH5604-C-001-A      | Main Gym (North)     | 8/20/2019           | 8/23/2019     | A9H0672-11 | Lead    | ND      | 0.20            | 15                | ppb   |
| 217-CH5605-A-001-A      | Main Gym (South)     | 8/20/2019           | 8/23/2019     | A9H0672-12 | Lead    | ND      | 0.20            | 15                | ppb   |
| 217-CH5605-B-001-A      | Main Gym (South)     | 8/20/2019           | 8/23/2019     | A9H0672-13 | Lead    | ND      | 0.20            | 15                | ppb   |
| 217-CH5605-C-001-A      | Main Gym (South)     | 8/20/2019           | 8/23/2019     | A9H0672-14 | Lead    | ND      | 0.20            | 15                | ppb   |
| 217-CH5602-A-001-A      | Hallway (044, South) | 8/20/2019           | 8/23/2019     | A9H0672-15 | Lead    | ND      | 0.20            | 15                | ppb   |
| 217-CH5602-B-001-A      | Hallway (044, South) | 8/20/2019           | 8/23/2019     | A9H0672-16 | Lead    | ND      | 0.20            | 15                | ppb   |
| 217-CH5602-C-001-A      | Hallway (044, South) | 8/20/2019           | 8/23/2019     | A9H0672-17 | Lead    | ND      | 0.20            | 15                | ppb   |
| 217-CH5601-A-001-A      | Hallway (044, North) | 8/20/2019           | 8/23/2019     | A9H0672-18 | Lead    | ND      | 0.20            | 15                | ppb   |
| 217-CH5601-B-001-A      | Hallway (044, North) | 8/20/2019           | 8/23/2019     | A9H0672-19 | Lead    | ND      | 0.20            | 15                | ppb   |

Analyzed by: Apex Laboratories

Reviewed by: PSI-Intertek

\*OHA Action Level = 15ppb

|                      |                         |           |           |            |      |       |      |    |     |
|----------------------|-------------------------|-----------|-----------|------------|------|-------|------|----|-----|
| 217-CH5601-C-001-A   | Hallway (044, North)    | 8/20/2019 | 8/23/2019 | A9H0672-20 | Lead | ND    | 0.20 | 15 | ppb |
| 217-CH5609-N/A-001-A | Kitchen (152)           | 8/20/2019 | 8/23/2019 | A9H0672-21 | Lead | 0.228 | 0.20 | 15 | ppb |
| 217-CH5611-N/A-001-A | Kitchen (152)           | 8/20/2019 | 8/23/2019 | A9H0672-22 | Lead | 1.38  | 0.20 | 15 | ppb |
| 217-CH5610-N/A-001-A | Kitchen (152)           | 8/20/2019 | 8/23/2019 | A9H0672-23 | Lead | 0.874 | 0.20 | 15 | ppb |
| 217-CH5608-A-001-A   | Hallway (177)           | 8/20/2019 | 8/23/2019 | A9H0672-24 | Lead | ND    | 0.20 | 15 | ppb |
| 217-CH5608-B-001-A   | Hallway (177)           | 8/20/2019 | 8/23/2019 | A9H0672-25 | Lead | ND    | 0.20 | 15 | ppb |
| 217-CH5608-C-001-A   | Hallway (177)           | 8/20/2019 | 8/23/2019 | A9H0672-26 | Lead | ND    | 0.20 | 15 | ppb |
| 217-CH5612-N/A-001-A | Medically Fragile (195) | 8/20/2019 | 8/23/2019 | A9H0672-27 | Lead | 0.386 | 0.20 | 15 | ppb |
| 217-CH5617-A-001-A   | Hallway (125)           | 8/20/2019 | 8/23/2019 | A9H0672-28 | Lead | ND    | 0.20 | 15 | ppb |
| 217-CH5617-B-001-A   | Hallway (125)           | 8/20/2019 | 8/23/2019 | A9H0672-29 | Lead | ND    | 0.20 | 15 | ppb |
| 217-CH5617-C-001-A   | Hallway (125)           | 8/20/2019 | 8/23/2019 | A9H0672-30 | Lead | ND    | 0.20 | 15 | ppb |
| 217-CH5621-N/A-001-A | Concesssions (G101C)    | 8/20/2019 | 8/23/2019 | A9H0672-31 | Lead | 2.22  | 0.20 | 15 | ppb |
| 217-CH5622-A-001-A   | Auxilliary Gym          | 8/20/2019 | 8/23/2019 | A9H0672-32 | Lead | ND    | 0.20 | 15 | ppb |
| 217-CH5622-B-001-A   | Auxilliary Gym          | 8/20/2019 | 8/23/2019 | A9H0672-33 | Lead | ND    | 0.20 | 15 | ppb |
| 217-CH5622-C-001-A   | Auxilliary Gym          | 8/20/2019 | 8/23/2019 | A9H0672-34 | Lead | ND    | 0.20 | 15 | ppb |
| 217-CH5618-N/A-001-A | Work Room (120P)        | 8/20/2019 | 8/23/2019 | A9H0672-35 | Lead | 0.364 | 0.20 | 15 | ppb |
| 217-CH5615-N/A-001-A | Staff Offices (101)     | 8/20/2019 | 8/23/2019 | A9H0672-36 | Lead | 0.204 | 0.20 | 15 | ppb |
| 217-CH5614-N/A-001-A | Workroom (132)          | 8/20/2019 | 8/23/2019 | A9H0672-37 | Lead | 0.883 | 0.20 | 15 | ppb |
| 217-CH5624-A-001-A   | Hallway (277)           | 8/20/2019 | 8/23/2019 | A9H0672-38 | Lead | ND    | 0.20 | 15 | ppb |
| 217-CH5624-B-001-A   | Hallway (277)           | 8/20/2019 | 8/23/2019 | A9H0672-39 | Lead | ND    | 0.20 | 15 | ppb |
| 217-CH5624-C-001-A   | Hallway (277)           | 8/20/2019 | 8/23/2019 | A9H0672-40 | Lead | ND    | 0.20 | 15 | ppb |
| 217-CH5625-A-001-A   | Hallway (227)           | 8/20/2019 | 8/23/2019 | A9H0672-41 | Lead | ND    | 0.20 | 15 | ppb |

Analyzed by: Apex Laboratories

Reviewed by: PSI-Intertek

\*OHA Action Level = 15ppb

|                      |                      |           |           |            |      |       |      |    |     |
|----------------------|----------------------|-----------|-----------|------------|------|-------|------|----|-----|
| 217-CH5625-B-001-A   | Hallway (227)        | 8/20/2019 | 8/23/2019 | A9H0672-42 | Lead | ND    | 0.20 | 15 | ppb |
| 217-CH5625-C-001-A   | Hallway (227)        | 8/20/2019 | 8/23/2019 | A9H0672-43 | Lead | ND    | 0.20 | 15 | ppb |
| 217-CH5606-N/A-001-A | Kitchen (A001E)      | 8/20/2019 | 8/23/2019 | A9H0672-44 | Lead | 0.239 | 0.20 | 15 | ppb |
| 217-CH5607-N/A-001-A | Break Room (A003L)   | 8/20/2019 | 8/23/2019 | A9H0672-45 | Lead | 1.05  | 0.20 | 15 | ppb |
| 217-CH5623-A-001-A   | Hallway (A107)       | 8/20/2019 | 8/23/2019 | A9H0672-46 | Lead | 0.851 | 0.20 | 15 | ppb |
| 217-CH5623-B-001-A   | Hallway (A107)       | 8/20/2019 | 8/23/2019 | A9H0672-47 | Lead | ND    | 0.20 | 15 | ppb |
| 217-CH5623-C-001-A   | Hallway (A107)       | 8/20/2019 | 8/23/2019 | A9H0672-48 | Lead | ND    | 0.20 | 15 | ppb |
| 217-CH5626-A-001-A   | Hallway (A207)       | 8/20/2019 | 8/23/2019 | A9H0672-49 | Lead | ND    | 0.20 | 15 | ppb |
| 217-CH5626-B-001-A   | Hallway (A207)       | 8/20/2019 | 8/23/2019 | A9H0672-50 | Lead | ND    | 0.20 | 15 | ppb |
| 217-CH5626-C-001-A   | Hallway (A207)       | 8/20/2019 | 8/23/2019 | A9H0672-51 | Lead | ND    | 0.20 | 15 | ppb |
| 217-CH5627-A-001-A   | Storage (A002)       | 8/20/2019 | 8/23/2019 | A9H0672-52 | Lead | ND    | 0.20 | 15 | ppb |
| 217-CH5627-B-001-A   | Storage (A002)       | 8/20/2019 | 8/23/2019 | A9H0672-53 | Lead | ND    | 0.20 | 15 | ppb |
| 217-CH5627-C-001-A   | Storage (A002)       | 8/20/2019 | 8/23/2019 | A9H0672-54 | Lead | ND    | 0.20 | 15 | ppb |
| 217-CH5620-N/A-001-A | Concesssions (G101C) | 8/20/2019 | 8/23/2019 | A9H0672-55 | Lead | 0.477 | 0.20 | 15 | ppb |