**Portland Public Schools**
**Lead Water Sampling Results**
**Initial Flush Sample Data**
**Grout Elementary School - Test 4**

| Sample Identification # | Location | Date/Time Collected | Date Analyzed | Lab ID | Analyte | Results | Detection Limit | PPS Action Level* | Units |
|---|---|---|---|---|---|---|---|---|---|
| 255-CH1216-A-004-A | Hallway (Room C) | 4/11/2019 | 4/24/2019 | A9D0553-01 | Lead | 28.20 | 0.20 | 15 | ppb |
| 255-CH1216-B-004-A | Hallway (Room C) | 4/11/2019 | 4/24/2019 | A9D0553-03 | Lead | 14.2 | 0.20 | 15 | ppb |
| 255-CH1213-A-004-A | Hallway (Room C) | 4/11/2019 | 4/24/2019 | A9D0553-05 | Lead | 9.49 | 0.20 | 15 | ppb |
| 255-CH1213-B-004-A | Hallway (Room C) | 4/11/2019 | 4/24/2019 | A9D0553-07 | Lead | 5.91 | 0.20 | 15 | ppb |
| 255-CH2253-A-004-A | Hallway (112) | 4/11/2019 | 4/24/2019 | A9D0553-09 | Lead | 20.60 | 0.20 | 15 | ppb |
| 255-CH2253-B-004-A | Hallway (112) | 4/11/2019 | 4/24/2019 | A9D0553-11 | Lead | 18.10 | 0.20 | 15 | ppb |
| 255-CH2254-A-004-A | Hallway (112) | 4/11/2019 | 4/24/2019 | A9D0553-13 | Lead | 13.4 | 0.20 | 15 | ppb |
| 255-CH2254-B-004-A | Hallway (112) | 4/11/2019 | 4/24/2019 | A9D0553-15 | Lead | 8.96 | 0.20 | 15 | ppb |
| 255-CH1196-N/A-004-A | Classroom 109 | 4/11/2019 | 4/22/2019 | A9D0553-17 | Lead | 24.40 | 0.20 | 15 | ppb |
| 255-CH1195-N/A-004-A | Hallway (106) | 4/11/2019 | 4/24/2019 | A9D0553-19 | Lead | 10.5 | 0.20 | 15 | ppb |
| 255-CH1208-A-004-A | Hallway (101) | 4/11/2019 | 4/26/2019 | A9D0553-21 | Lead | 11.4 | 0.20 | 15 | ppb |
| 255-CH1208-B-004-A | Hallway (101) | 4/11/2019 | 4/26/2019 | A9D0553-23 | Lead | 12.8 | 0.20 | 15 | ppb |
| 255-CH2258-A-004-A | Hallway (201) | 4/11/2019 | 4/26/2019 | A9D0553-27 | Lead | 22.80 | 0.20 | 15 | ppb |
| 255-CH2258-B-004-A | Hallway (201) | 4/11/2019 | 4/26/2019 | A9D0553-29 | Lead | 11.1 | 0.20 | 15 | ppb |
| 255-CH1203-A-004-A | Hallway (212) | 4/11/2019 | 4/26/2019 | A9D0553-31 | Lead | 2.07 | 0.20 | 15 | ppb |
| 255-CH1203-B-004-A | Hallway (212) | 4/11/2019 | 4/26/2019 | A9D0553-33 | Lead | 2.44 | 0.20 | 15 | ppb |
| 255-CH1201-N/A-004-A | Classroom 112 | 4/11/2019 | 4/26/2019 | A9D0553-39 | Lead | 12.3 | 0.20 | 15 | ppb |

*OHA Action Level = 15ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

*OHA Action Level = 15ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek