Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Grout Elementary School - Test 5

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
255-CH2253-A-005-A	Hallway (112)	5/23/2019	6/5/2019	A9E0811-17	Lead	6.44	0.20	15	ppb
255-CH2253-B-005-B	Hallway (112)	5/23/2019	6/5/2019	A9E0811-18	Lead	14.1	0.20	15	ppb
255-CH2254-A-005-A	Hallway (112)	5/23/2019	6/5/2019	A9E0811-19	Lead	10.2	0.20	15	ppb
255-CH2254-B-005-A	Hallway (112)	5/23/2019	6/5/2019	A9E0811-20	Lead	9.17	0.20	15	ppb

*OHA Action Level = 15ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek