

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Harrison Park Elementary

Sample Identification #		Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
236-1864-N/A-001-A		Bubbler - Cafeteria, South Corner	7/26/2018	8/1/2018	A8G0701-01	Copper	0.0784	0.00200	1.3	ppm
236-1864-N/A-001-A		Bubbler - Cafeteria, South Corner	7/26/2018	8/1/2018	A8G0701-01	Lead	7.11	0.200	15	ppb
236-1864-N/A-001-B		Bubbler - Cafeteria, South Corner	7/26/2018	8/1/2018	A8G0701-02	Copper	0.167	0.00200	1.3	ppm
236-1864-N/A-001-B		Bubbler - Cafeteria, South Corner	7/26/2018	8/1/2018	A8G0701-02	Lead	9.43	0.200	15	ppb
236-1856-N/A-001-A		Bubbler - Cafeteria	7/26/2018	8/7/2018	A8G0701-03RE1	Copper	0.944	0.0200	1.3	ppm
236-1856-N/A-001-A		Bubbler - Cafeteria	7/26/2018	8/7/2018	A8G0701-03RE1	Lead	ND	20.0	15	ppb
236-1856-N/A-001-B		Bubbler - Cafeteria	7/26/2018	8/7/2018	A8G0701-04RE1	Copper	1.68	0.0200	1.3	ppm
236-1856-N/A-001-B		Bubbler - Cafeteria	7/26/2018	8/2/2018	A8G0701-04	Lead	12.5	0.200	15	ppb
236-1858-N/A-001-A		Bubbler - By 172	7/26/2018	8/1/2018	A8G0701-05	Copper	0.0697	0.00200	1.3	ppm
236-1858-N/A-001-A		Bubbler - By 172	7/26/2018	8/1/2018	A8G0701-05	Lead	17.2	0.200	15	ppb
236-1858-N/A-001-B		Bubbler - By 172	7/26/2018	8/1/2018	A8G0701-06	Copper	0.0285	0.00200	1.3	ppm
236-1858-N/A-001-B		Bubbler - By 172	7/26/2018	8/1/2018	A8G0701-06	Lead	3.48	0.200	15	ppb
236-1852-N/A-001-A		Bubbler - By Main Office	7/26/2018	8/1/2018	A8G0701-07	Copper	0.0216	0.00200	1.3	ppm
236-1852-N/A-001-A		Bubbler - By Main Office	7/26/2018	8/1/2018	A8G0701-07	Lead	8.32	0.200	15	ppb
236-1852-N/A-001-B		Bubbler - By Main Office	7/26/2018	8/1/2018	A8G0701-08	Copper	0.0171	0.00200	1.3	ppm
236-1852-N/A-001-B		Bubbler - By Main Office	7/26/2018	8/1/2018	A8G0701-08	Lead	2.34	0.200	15	ppb
236-1792-N/A-001-A		Bubbler - By 169	7/26/2018	8/2/2018	A8G0701-09	Copper	0.0412	0.00200	1.3	ppm
236-1792-N/A-001-A		Bubbler - By 169	7/26/2018	8/2/2018	A8G0701-09	Lead	12.9	0.200	15	ppb
236-1792-N/A-001-B		Bubbler - By 169	7/26/2018	8/2/2018	A8G0701-10	Copper	0.0435	0.00200	1.3	ppm
236-1792-N/A-001-B		Bubbler - By 169	7/26/2018	8/2/2018	A8G0701-10	Lead	6.52	2.00	15	ppb
236-1795-N/A-001-A		Bubbler - By 137	7/26/2018	8/1/2018	A8G0701-11	Copper	0.0237	0.00200	1.3	ppm
236-1795-N/A-001-A		Bubbler - By 137	7/26/2018	8/1/2018	A8G0701-11	Lead	6.67	0.200	15	ppb
236-1795-N/A-001-B		Bubbler - By 137	7/26/2018	8/1/2018	A8G0701-12	Copper	0.0182	0.00200	1.3	ppm

236-1795-N/A-001-B	Bubbler - By 137	7/26/2018	8/1/2018	A8G0701-12	Lead	0.398	0.200	15	ppb
236-1850-N/A-001-A	Stainless Elkay - By 101	7/26/2018	8/2/2018	A8G0701-13	Copper	0.0214	0.00200	1.3	ppm
236-1850-N/A-001-A	Stainless Elkay - By 101	7/26/2018	8/2/2018	A8G0701-13	Lead	5.85	0.200	15	ppb
236-1850-N/A-001-B	Stainless Elkay - By 101	7/26/2018	8/1/2018	A8G0701-14	Copper	0.00564	0.00200	1.3	ppm
236-1850-N/A-001-B	Stainless Elkay - By 101	7/26/2018	8/1/2018	A8G0701-14	Lead	0.529	0.200	15	ppb
236-1784-N/A-001-A	Bubbler - Gym 1	7/26/2018	8/1/2018	A8G0701-15	Copper	0.0262	0.00200	1.3	ppm
236-1784-N/A-001-A	Bubbler - Gym 1	7/26/2018	8/1/2018	A8G0701-15	Lead	2.82	0.200	15	ppb
236-1784-N/A-001-B	Bubbler - Gym 1	7/26/2018	8/1/2018	A8G0701-16	Copper	0.00693	0.00200	1.3	ppm
236-1784-N/A-001-B	Bubbler - Gym 1	7/26/2018	8/1/2018	A8G0701-16	Lead	1.33	0.200	15	ppb
236-1787-N/A-001-A	Bubbler - Gym 2	7/26/2018	8/2/2018	A8G0701-17	Copper	0.0446	0.00200	1.3	ppm
236-1787-N/A-001-A	Bubbler - Gym 2	7/26/2018	8/2/2018	A8G0701-17	Lead	8.18	0.200	15	ppb
236-1787-N/A-001-B	Bubbler - Gym 2	7/26/2018	8/2/2018	A8G0701-18	Copper	0.0298	0.00200	1.3	ppm
236-1787-N/A-001-B	Bubbler - Gym 2	7/26/2018	8/2/2018	A8G0701-18	Lead	17.4	0.200	15	ppb
236-1790-N/A-001-A	Bubbler - Gym 2	7/26/2018	8/1/2018	A8G0701-19	Copper	0.959	0.00200	1.3	ppm
236-1790-N/A-001-A	Bubbler - Gym 2	7/26/2018	8/1/2018	A8G0701-19	Lead	11.3	0.200	15	ppb
236-1790-N/A-001-B	Bubbler - Gym 2	7/26/2018	8/6/2018	A8G0701-20RE2	Copper	1.25	0.0200	1.3	ppm
236-1790-N/A-001-B	Bubbler - Gym 2	7/26/2018	8/1/2018	A8G0701-20	Lead	2.18	0.200	15	ppb
236-1860-N/A-001-A	Food Prep Faucet - Kitchen	7/26/2018	8/1/2018	A8G0701-21	Copper	0.133	0.00200	1.3	ppm
236-1860-N/A-001-A	Food Prep Faucet - Kitchen	7/26/2018	8/1/2018	A8G0701-21	Lead	1.91	0.200	15	ppb
236-1860-N/A-001-B	Food Prep Faucet - Kitchen	7/26/2018	8/1/2018	A8G0701-22	Copper	0.0519	0.00200	1.3	ppm
236-1860-N/A-001-B	Food Prep Faucet - Kitchen	7/26/2018	8/1/2018	A8G0701-22	Lead	2.15	0.200	15	ppb
236-1857-A-001-A	Food Prep Sprayer - Kitchen, South	7/26/2018	8/1/2018	A8G0701-23	Copper	0.110	0.00200	1.3	ppm
236-1857-A-001-A	Food Prep Sprayer - Kitchen, South	7/26/2018	8/1/2018	A8G0701-23	Lead	0.814	0.200	15	ppb
236-1857-A-001-B	Food Prep Sprayer - Kitchen, South	7/26/2018	8/1/2018	A8G0701-24	Copper	0.180	0.00200	1.3	ppm
236-1857-A-001-B	Food Prep Sprayer - Kitchen, South	7/26/2018	8/1/2018	A8G0701-24	Lead	0.597	0.200	15	ppb
236-1857-B-001-A	Food Prep Faucet - Kitchen, South	7/26/2018	8/1/2018	A8G0701-25	Copper	0.237	0.00200	1.3	ppm
236-1857-B-001-A	Food Prep Faucet - Kitchen, South	7/26/2018	8/1/2018	A8G0701-25	Lead	0.724	0.200	15	ppb
236-1857-B-001-B	Food Prep Faucet - Kitchen, South	7/26/2018	8/1/2018	A8G0701-26	Copper	0.0484	0.00200	1.3	ppm

236-1857-B-001-B	Food Prep Faucet - Kitchen, South	7/26/2018	8/1/2018	A8G0701-26	Lead	0.639	0.200	15	ppb
236-1861-A-001-A	Food Prep Faucet - Kitchen	7/26/2018	8/1/2018	A8G0701-27	Copper	0.114	0.00200	1.3	ppm
236-1861-A-001-A	Food Prep Faucet - Kitchen	7/26/2018	8/1/2018	A8G0701-27	Lead	2.88	0.200	15	ppb
236-1861-A-001-B	Food Prep Faucet - Kitchen	7/26/2018	8/2/2018	A8G0701-28	Copper	0.0595	0.00200	1.3	ppm
236-1861-A-001-B	Food Prep Faucet - Kitchen	7/26/2018	8/2/2018	A8G0701-28	Lead	0.598	0.200	15	ppb
236-1861-B-001-A	Food Prep Sprayer - Kitchen	7/26/2018	8/2/2018	A8G0701-29	Copper	0.109	0.00200	1.3	ppm
236-1861-B-001-A	Food Prep Sprayer - Kitchen	7/26/2018	8/2/2018	A8G0701-29	Lead	8.11	0.200	15	ppb
236-1861-B-001-B	Food Prep Sprayer - Kitchen	7/26/2018	8/2/2018	A8G0701-30	Copper	0.105	0.00200	1.3	ppm
236-1861-B-001-B	Food Prep Sprayer - Kitchen	7/26/2018	8/2/2018	A8G0701-30	Lead	0.681	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.