

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Harrison Park Elementary - 2nd Site Visit

Sample Identification #	Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
236-1807-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 109	8/9/2018	8/17/2018	A8H0249-01	Copper	0.00852	0.00200	1.3	ppm
236-1807-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 109	8/9/2018	8/17/2018	A8H0249-01	Lead	5.09	0.200	15	ppb
236-1807-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 109	8/9/2018	8/17/2018	A8H0249-02	Copper	0.00247	0.00200	1.3	ppm
236-1807-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 109	8/9/2018	8/17/2018	A8H0249-02	Lead	0.706	0.200	15	ppb
236-1788-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 112	8/9/2018	8/21/2018	A8H0249-03RE1	Copper	0.00577	0.00200	1.3	ppm
236-1788-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 112	8/9/2018	8/21/2018	A8H0249-03RE1	Lead	3.51	0.200	15	ppb
236-1788-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 112	8/9/2018	8/21/2018	A8H0249-04RE1	Copper	ND	0.00200	1.3	ppm
236-1788-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 112	8/9/2018	8/21/2018	A8H0249-04RE1	Lead	0.385	0.200	15	ppb
236-1794-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 115	8/9/2018	8/17/2018	A8H0249-05	Copper	0.00268	0.00200	1.3	ppm
236-1794-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 115	8/9/2018	8/17/2018	A8H0249-05	Lead	6.85	0.200	15	ppb
236-1794-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 115	8/9/2018	8/17/2018	A8H0249-06	Copper	0.00239	0.00200	1.3	ppm
236-1794-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 115	8/9/2018	8/17/2018	A8H0249-06	Lead	1.59	0.200	15	ppb
236-1803-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 120	8/9/2018	8/23/2018	A8H0249-07RE2	Copper	0.0408	0.00200	1.3	ppm
236-1803-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 120	8/9/2018	8/23/2018	A8H0249-07RE2	Lead	10.7	2.00	15	ppb
236-1803-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 120	8/9/2018	8/17/2018	A8H0249-08	Copper	0.0191	0.00200	1.3	ppm
236-1803-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 120	8/9/2018	8/17/2018	A8H0249-08	Lead	6.99	0.200	15	ppb
236-1804-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 130	8/9/2018	8/23/2018	A8H0249-09RE2	Copper	0.0777	0.00200	1.3	ppm
236-1804-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 130	8/9/2018	8/23/2018	A8H0249-09RE2	Lead	59.2	2.00	15	ppb
236-1804-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 130	8/9/2018	8/23/2018	A8H0249-10RE2	Copper	0.0842	0.00200	1.3	ppm
236-1804-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 130	8/9/2018	8/23/2018	A8H0249-10RE2	Lead	57.2	2.00	15	ppb
236-1798-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 136	8/9/2018	8/23/2018	A8H0249-11RE2	Copper	0.0320	0.00200	1.3	ppm
236-1798-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 136	8/9/2018	8/23/2018	A8H0249-11RE2	Lead	22.4	2.00	15	ppb
236-1798-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 136	8/9/2018	8/23/2018	A8H0249-12RE2	Copper	0.0619	0.00200	1.3	ppm

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

236-1798-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 136	8/9/2018	8/23/2018	A8H0249-12RE2	Lead	40.6	2.00	15	ppb
236-1384-N/A-001-A	Sink Bubblers - Classroom 198	8/9/2018	8/17/2018	A8H0249-13	Copper	0.936	0.00200	1.3	ppm
236-1384-N/A-001-A	Sink Bubblers - Classroom 198	8/9/2018	8/17/2018	A8H0249-13	Lead	2.84	0.200	15	ppb
236-1384-N/A-001-B	Sink Bubblers - Classroom 198	8/9/2018	8/23/2018	A8H0249-14RE3	Copper	1.16	0.0200	1.3	ppm
236-1384-N/A-001-B	Sink Bubblers - Classroom 198	8/9/2018	8/17/2018	A8H0249-14	Lead	0.958	0.200	15	ppb
236-1381-N/A-001-A	Sink Bubblers - Classroom 197	8/9/2018	8/17/2018	A8H0249-15	Copper	0.916	0.00200	1.3	ppm
236-1381-N/A-001-A	Sink Bubblers - Classroom 197	8/9/2018	8/17/2018	A8H0249-15	Lead	2.70	0.200	15	ppb
236-1381-N/A-001-B	Sink Bubblers - Classroom 197	8/9/2018	8/21/2018	A8H0249-16RE1	Copper	1.24	0.0100	1.3	ppm
236-1381-N/A-001-B	Sink Bubblers - Classroom 197	8/9/2018	8/17/2018	A8H0249-16	Lead	0.753	0.200	15	ppb
236-1808-N/A-001-A	Sink Bubblers - Classroom 195	8/9/2018	8/17/2018	A8H0249-17	Copper	0.576	0.00200	1.3	ppm
236-1808-N/A-001-A	Sink Bubblers - Classroom 195	8/9/2018	8/17/2018	A8H0249-17	Lead	15.6	0.200	15	ppb
236-1808-N/A-001-B	Sink Bubblers - Classroom 195	8/9/2018	8/17/2018	A8H0249-18	Copper	0.893	0.00200	1.3	ppm
236-1808-N/A-001-B	Sink Bubblers - Classroom 195	8/9/2018	8/17/2018	A8H0249-18	Lead	2.33	0.200	15	ppb
236-1805-N/A-001-A	Sink Bubblers - Classroom 194	8/9/2018	8/17/2018	A8H0249-19	Copper	0.743	0.00200	1.3	ppm
236-1805-N/A-001-A	Sink Bubblers - Classroom 194	8/9/2018	8/17/2018	A8H0249-19	Lead	10.8	0.200	15	ppb
236-1805-N/A-001-B	Sink Bubblers - Classroom 194	8/9/2018	8/17/2018	A8H0249-20	Copper	0.720	0.00200	1.3	ppm
236-1805-N/A-001-B	Sink Bubblers - Classroom 194	8/9/2018	8/17/2018	A8H0249-20	Lead	3.34	0.200	15	ppb
236-1802-N/A-001-A	Sink Bubblers - Classroom 159	8/9/2018	8/23/2018	A8H0249-21RE2	Copper	0.985	0.00200	1.3	ppm
236-1802-N/A-001-A	Sink Bubblers - Classroom 159	8/9/2018	8/23/2018	A8H0249-21RE2	Lead	17.0	2.00	15	ppb
236-1802-N/A-001-B	Sink Bubblers - Classroom 159	8/9/2018	8/17/2018	A8H0249-22	Copper	0.104	0.00200	1.3	ppm
236-1802-N/A-001-B	Sink Bubblers - Classroom 159	8/9/2018	8/17/2018	A8H0249-22	Lead	2.19	0.200	15	ppb
236-1799-N/A-001-A	Sink Bubblers - Classroom 166	8/9/2018	8/21/2018	A8H0249-23RE1	Copper	0.168	0.00200	1.3	ppm
236-1799-N/A-001-A	Sink Bubblers - Classroom 166	8/9/2018	8/21/2018	A8H0249-23RE1	Lead	3.22	0.200	15	ppb
236-1799-N/A-001-B	Sink Bubblers - Classroom 166	8/9/2018	8/21/2018	A8H0249-24RE1	Copper	0.0943	0.00200	1.3	ppm
236-1799-N/A-001-B	Sink Bubblers - Classroom 166	8/9/2018	8/21/2018	A8H0249-24RE1	Lead	1.80	0.200	15	ppb
236-1796-N/A-001-A	Sink Bubblers - Classroom 162	8/9/2018	8/21/2018	A8H0249-25RE1	Copper	0.869	0.00200	1.3	ppm
236-1796-N/A-001-A	Sink Bubblers - Classroom 162	8/9/2018	8/21/2018	A8H0249-25RE1	Lead	5.63	0.200	15	ppb
236-1796-N/A-001-B	Sink Bubblers - Classroom 162	8/9/2018	8/17/2018	A8H0249-26	Copper	0.421	0.00200	1.3	ppm

236-1796-N/A-001-B	Sink Bubbler - Classroom 162	8/9/2018	8/17/2018	A8H0249-26	Lead	0.867	0.200	15	ppb
236-1785-N/A-001-A	Sink (Food Prep) - Staff 167	8/9/2018	8/23/2018	A8H0249-27RE2	Copper	0.103	0.00200	1.3	ppm
236-1785-N/A-001-A	Sink (Food Prep) - Staff 167	8/9/2018	8/23/2018	A8H0249-27RE2	Lead	44.2	2.00	15	ppb
236-1785-N/A-001-B	Sink (Food Prep) - Staff 167	8/9/2018	8/17/2018	A8H0249-28RE1	Copper	0.0172	0.00200	1.3	ppm
236-1785-N/A-001-B	Sink (Food Prep) - Staff 167	8/9/2018	8/16/2018	A8H0249-28	Lead	5.33	0.200	15	ppb
236-1390-N/A-001-A	Sink Bubbler - Classroom 190	8/9/2018	8/17/2018	A8H0249-29RE2	Copper	0.843	0.0200	1.3	ppm
236-1390-N/A-001-A	Sink Bubbler - Classroom 190	8/9/2018	8/16/2018	A8H0249-29	Lead	8.26	0.200	15	ppb
236-1390-N/A-001-B	Sink Bubbler - Classroom 190	8/9/2018	8/17/2018	A8H0249-30RE2	Copper	1.29	0.0200	1.3	ppm
236-1390-N/A-001-B	Sink Bubbler - Classroom 190	8/9/2018	8/16/2018	A8H0249-30	Lead	1.84	0.200	15	ppb
236-1393-N/A-001-A	Sink Bubbler - Classroom 189	8/9/2018	8/17/2018	A8H0249-31RE1	Copper	0.494	0.00200	1.3	ppm
236-1393-N/A-001-A	Sink Bubbler - Classroom 189	8/9/2018	8/16/2018	A8H0249-31	Lead	8.75	2.00	15	ppb
236-1393-N/A-001-B	Sink Bubbler - Classroom 189	8/9/2018	8/17/2018	A8H0249-32RE2	Copper	1.14	0.0200	1.3	ppm
236-1393-N/A-001-B	Sink Bubbler - Classroom 189	8/9/2018	8/16/2018	A8H0249-32	Lead	1.40	0.200	15	ppb
236-1396-N/A-001-A	Sink Bubbler - Classroom 188	8/9/2018	8/17/2018	A8H0249-33RE1	Copper	0.898	0.00200	1.3	ppm
236-1396-N/A-001-A	Sink Bubbler - Classroom 188	8/9/2018	8/16/2018	A8H0249-33	Lead	2.63	0.200	15	ppb
236-1396-N/A-001-B	Sink Bubbler - Classroom 188	8/9/2018	8/25/2018	A8H0249-34RE6	Copper	1.16	0.0200	1.3	ppm
236-1396-N/A-001-B	Sink Bubbler - Classroom 188	8/9/2018	8/16/2018	A8H0249-34	Lead	1.21	0.200	15	ppb
236-1789-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 169	8/9/2018	8/23/2018	A8H0249-35RE2	Copper	0.0368	0.00200	1.3	ppm
236-1789-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 169	8/9/2018	8/23/2018	A8H0249-35RE2	Lead	14.3	2.00	15	ppb
236-1789-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 169	8/9/2018	8/23/2018	A8H0249-36RE2	Copper	0.212	0.00200	1.3	ppm
236-1789-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 169	8/9/2018	8/23/2018	A8H0249-36RE2	Lead	30.0	2.00	15	ppb
236-1786-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 163	8/9/2018	8/23/2018	A8H0249-37RE2	Copper	0.0232	0.00200	1.3	ppm
236-1786-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 163	8/9/2018	8/23/2018	A8H0249-37RE2	Lead	16.8	2.00	15	ppb
236-1786-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 163	8/9/2018	8/23/2018	A8H0249-38RE2	Copper	0.309	0.00200	1.3	ppm
236-1786-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 163	8/9/2018	8/23/2018	A8H0249-38RE2	Lead	51.6	2.00	15	ppb
236-1854-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 145	8/9/2018	8/17/2018	A8H0249-39RE1	Copper	0.0299	0.00200	1.3	ppm
236-1854-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 145	8/9/2018	8/16/2018	A8H0249-39	Lead	17.7	0.200	15	ppb
236-1854-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 145	8/9/2018	8/17/2018	A8H0249-40RE1	Copper	0.0331	0.00200	1.3	ppm

236-1854-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 145	8/9/2018	8/16/2018	A8H0249-40	Lead	9.02	0.200	15	ppb
236-1855-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 149	8/9/2018	8/17/2018	A8H0249-41RE1	Copper	0.0447	0.00200	1.3	ppm
236-1855-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 149	8/9/2018	8/16/2018	A8H0249-41	Lead	19.7	0.200	15	ppb
236-1855-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 149	8/9/2018	8/17/2018	A8H0249-42RE1	Copper	0.0449	0.00200	1.3	ppm
236-1855-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 149	8/9/2018	8/16/2018	A8H0249-42	Lead	10.5	0.200	15	ppb
236-1399-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 169-B	8/9/2018	8/17/2018	A8H0249-43RE1	Copper	0.638	0.00200	1.3	ppm
236-1399-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 169-B	8/9/2018	8/16/2018	A8H0249-43	Lead	17.5	0.200	15	ppb
236-1399-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 169-B	8/9/2018	8/17/2018	A8H0249-44RE1	Copper	0.236	0.00200	1.3	ppm
236-1399-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 169-B	8/9/2018	8/16/2018	A8H0249-44	Lead	2.78	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.