

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Harrison Park School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
236-CH1856-N/A-003-A	Cafeteria	3/29/2019	4/9/2019	A9C1063-01	Lead	8.86	0.20	15	ppb
236-CH1858-N/A-003-A	Hallway (172)	3/29/2019	4/9/2019	A9C1063-03	Lead	13	0.20	15	ppb
236-CHR171-N/A-003-A	Classroom 171	3/29/2019	4/9/2019	A9C1063-05	Lead	6.35	0.20	15	ppb
236-CH1387-N/A-003-A	Classroom 191	3/29/2019	4/9/2019	A9C1063-07	Lead	3.22	0.20	15	ppb
236-CH1810-N/A-003-A	Classroom 167	3/29/2019	4/9/2019	A9C1063-09	Lead	6.98	0.20	15	ppb
236-CH1791-N/A-003-A	Classroom 114	3/29/2019	4/9/2019	A9C1063-11	Lead	13.8	0.20	15	ppb
236-CH1797-N/A-003-A	Classroom 118	3/29/2019	4/9/2019	A9C1063-13	Lead	14.4	0.20	15	ppb
236-CH1800-N/A-003-A	Classroom 119	3/29/2019	4/9/2019	A9C1063-15	Lead	3.8	0.20	15	ppb
236-CH1806-N/A-003-A	Classroom 121	3/29/2019	4/9/2019	A9C1063-17	Lead	15.00	0.20	15	ppb
236-CH1793-N/A-003-A	Health Room (Across Rm 122)	3/29/2019	4/9/2019	A9C1063-19	Lead	28.20	0.20	15	ppb
236-CH1787-N/A-003-A	Gym	3/29/2019	4/9/2019	A9C1063-21	Lead	6.17	0.20	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.