

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Hayhurst Elementary School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
160-CH4362-N/A-003-A	Kitchen	3/28/2019	4/9/2019	A9C1069-01	Lead	0.53	0.20	15	ppb
160-CH4354-N/A-003-A	Classroom 26	3/28/2019	4/9/2019	A9C1069-03	Lead	7.57	0.20	15	ppb
160-CH4357-N/A-003-A	Classroom 15	3/28/2019	4/9/2019	A9C1069-05	Lead	4.28	0.20	15	ppb
160-CH4353-N/A-003-A	Library/Media	3/28/2019	4/9/2019	A9C1069-07	Lead	10.8	0.20	15	ppb
160-CH4361-N/A-003-A	Classroom 5	3/28/2019	4/9/2019	A9C1069-09	Lead	70.80	0.20	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.