Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Hosford Middle School - Test 3

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
257-CH3716-A-003-A	Hallway (Auditorium)	4/24/2019	5/8/2019	A9D0966-01	Lead	7.63	0.20	15	ppb
257-CH3716-B-003-A	Hallway (Auditorium)	4/24/2019	5/8/2019	A9D0966-02	Lead	4.2	0.20	15	ppb

*OHA Action Level = 15ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek