

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Humboldt School (Kairos PDX Charter School) - Test 2**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
164-CH2225-N/A-002-A	Portable P4	4/23/2019	5/8/2019	A9D0968-01	Lead	16.90	0.20	15	ppb
164-CH2226-N/A-002-A	Portable P3	4/23/2019	5/8/2019	A9D0968-02	Lead	14.8	0.20	15	ppb
164-CH2227-N/A-002-A	Portable P2	4/23/2019	5/8/2019	A9D0968-03	Lead	2.93	0.20	15	ppb
164-CH2238-N/A-002-A	Gym	4/23/2019	5/8/2019	A9D0968-04	Lead	6.95	0.20	15	ppb
164-CH2243-N/A-002-A	Classroom 35	4/23/2019	5/8/2019	A9D0968-05	Lead	5.98	0.20	15	ppb
164-CH2228-N/A-002-A	Classroom 37	4/23/2019	5/8/2019	A9D0968-06	Lead	28.00	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.