

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Irvington Elementary

Sample Identification #	Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
259-3841-A-001-A	Bubbler - Right of custodian room #2, left of staircase	7/18/2018	7/19/2018	A8G0453-01	Copper	0.0207	0.001	1.3	ppm
259-3841-A-001-A	Bubbler - Right of custodian room #2, left of staircase	7/18/2018	7/19/2018	A8G0453-01	Lead	3.26	0.2	15	ppb
259-3841-A-001-B	Bubbler - Right of custodian room #2, left of staircase	7/18/2018	7/19/2018	A8G0453-02	Copper	0.00613	0.001	1.3	ppm
259-3841-A-001-B	Bubbler - Right of custodian room #2, left of staircase	7/18/2018	7/19/2018	A8G0453-02	Lead	0.703	0.2	15	ppb
259-3841-B-001-A	Bubbler - Right of custodian room #2, left of staircase	7/18/2018	7/19/2018	A8G0453-03	Copper	0.0247	0.001	1.3	ppm
259-3841-B-001-A	Bubbler - Right of custodian room #2, left of staircase	7/18/2018	7/19/2018	A8G0453-03	Lead	4.54	0.2	15	ppb
259-3841-B-001-B	Bubbler - Right of custodian room #2, left of staircase	7/18/2018	7/19/2018	A8G0453-04	Copper	0.00342	0.001	1.3	ppm
259-3841-B-001-B	Bubbler - Right of custodian room #2, left of staircase	7/18/2018	7/19/2018	A8G0453-04	Lead	0.620	0.2	15	ppb
259-3847-NA-001-A	Cooler - Across from 105	7/18/2018	7/19/2018	A8G0453-05	Copper	0.0714	0.001	1.3	ppm
259-3847-NA-001-A	Cooler - Across from 105	7/18/2018	7/19/2018	A8G0453-05	Lead	2.17	0.2	15	ppb
259-3847-NA-001-B	Cooler - Across from 105	7/18/2018	7/19/2018	A8G0453-06	Copper	0.0520	0.001	1.3	ppm
259-3847-NA-001-B	Cooler - Across from 105	7/18/2018	7/19/2018	A8G0453-06	Lead	0.390	0.2	15	ppb
259-3850-NA-001-A	Bottle Filler - Across from 105	7/18/2018	7/19/2018	A8G0453-07	Copper	0.0976	0.001	1.3	ppm
259-3850-NA-001-A	Bottle Filler - Across from 105	7/18/2018	7/19/2018	A8G0453-07	Lead	0.793	0.2	15	ppb
259-3850-NA-001-B	Bottle Filler - Across from 105	7/18/2018	7/19/2018	A8G0453-08	Copper	0.0349	0.001	1.3	ppm
259-3850-NA-001-B	Bottle Filler - Across from 105	7/18/2018	7/19/2018	A8G0453-08	Lead	0.260	0.2	15	ppb
259-3853-NA-001-A	Cooler - Left of custodian office	7/18/2018	7/19/2018	A8G0453-09	Copper	0.0659	0.001	1.3	ppm
259-3853-NA-001-A	Cooler - Left of custodian office	7/18/2018	7/19/2018	A8G0453-09	Lead	1.69	0.2	15	ppb
259-3853-NA-001-B	Cooler - Left of custodian office	7/18/2018	7/19/2018	A8G0453-10	Copper	0.0412	0.001	1.3	ppm
259-3853-NA-001-B	Cooler - Left of custodian office	7/18/2018	7/19/2018	A8G0453-10	Lead	1.31	0.2	15	ppb
259-3863-NA-001-A	Drinking Fountain (Porcelain) - Classroom 111	7/18/2018	7/19/2018	A8G0453-11	Copper	0.164	0.001	1.3	ppm
259-3863-NA-001-A	Drinking Fountain (Porcelain) - Classroom 111	7/18/2018	7/19/2018	A8G0453-11	Lead	4.56	0.2	15	ppb
259-3863-NA-001-B	Drinking Fountain (Porcelain) - Classroom 111	7/18/2018	7/19/2018	A8G0453-12	Copper	0.0485	0.001	1.3	ppm

259-3863-NA-001-B	Drinking Fountain (Porcelain) - Classroom 111	7/18/2018	7/19/2018	A8G0453-12	Lead	1.11	0.2	15	ppb
259-3866-NA-001-A	Sink (Food Prep) - Teachers Lounge 118	7/18/2018	7/19/2018	A8G0453-13	Copper	0.675	0.001	1.3	ppm
259-3866-NA-001-A	Sink (Food Prep) - Teachers Lounge 118	7/18/2018	7/19/2018	A8G0453-13	Lead	4.08	0.2	15	ppb
259-3866-NA-001-B	Sink (Food Prep) - Teachers Lounge 118	7/18/2018	7/19/2018	A8G0453-14	Copper	0.615	0.001	1.3	ppm
259-3866-NA-001-B	Sink (Food Prep) - Teachers Lounge 118	7/18/2018	7/19/2018	A8G0453-14	Lead	1.16	0.2	15	ppb
259-3869-A-001-A	Bubbler - Gym	7/18/2018	7/19/2018	A8G0453-15	Copper	0.0353	0.001	1.3	ppm
259-3869-A-001-A	Bubbler - Gym	7/18/2018	7/19/2018	A8G0453-15	Lead	3.97	0.2	15	ppb
259-3869-A-001-B	Bubbler - Gym	7/18/2018	7/19/2018	A8G0453-16	Copper	0.00318	0.001	1.3	ppm
259-3869-A-001-B	Bubbler - Gym	7/18/2018	7/19/2018	A8G0453-16RE1	Lead	0.404	0.2	15	ppb
259-3869-B-001-A	Bubbler - Gym	7/18/2018	7/19/2018	A8G0453-17	Copper	0.0186	0.01	1.3	ppm
259-3869-B-001-A	Bubbler - Gym	7/18/2018	7/19/2018	A8G0453-17	Lead	0.811	0.2	15	ppb
259-3869-B-001-B	Bubbler - Gym	7/18/2018	7/19/2018	A8G0453-18	Copper	0.00355	0.001	1.3	ppm
259-3869-B-001-B	Bubbler - Gym	7/18/2018	7/19/2018	A8G0453-18RE1	Lead	0.218	0.2	15	ppb
259-3887-A-001-A	Bubbler - Left of 213	7/18/2018	7/19/2018	A8G0453-19	Copper	0.0337	0.001	1.3	ppm
259-3887-A-001-A	Bubbler - Left of 213	7/18/2018	7/19/2018	A8G0453-19RE1	Lead	1.46	0.2	15	ppb
259-3887-A-001-B	Bubbler - Left of 213	7/18/2018	7/19/2018	A8G0453-20	Copper	0.0109	0.001	1.3	ppm
259-3887-A-001-B	Bubbler - Left of 213	7/18/2018	7/19/2018	A8G0453-20RE1	Lead	0.684	0.2	15	ppb
259-3887-B-001-A	Bubbler - Left of 213	7/18/2018	7/19/2018	A8G0453-21	Copper	0.0260	0.001	1.3	ppm
259-3887-B-001-A	Bubbler - Left of 213	7/18/2018	7/19/2018	A8G0453-21	Lead	1.42	0.2	15	ppb
259-3887-B-001-B	Bubbler - Left of 213	7/18/2018	7/19/2018	A8G0453-22	Copper	0.0108	0.001	1.3	ppm
259-3887-B-001-B	Bubbler - Left of 213	7/18/2018	7/19/2018	A8G0453-22	Lead	0.722	0.2	15	ppb
259-3881-A-001-A	Bubbler - Across from 209	7/18/2018	7/19/2018	A8G0453-23	Copper	0.0716	0.001	1.3	ppm
259-3881-A-001-A	Bubbler - Across from 209	7/18/2018	7/19/2018	A8G0453-23	Lead	6.84	0.2	15	ppb
259-3881-A-001-B	Bubbler - Across from 209	7/18/2018	7/19/2018	A8G0453-24	Copper	0.0493	0.001	1.3	ppm
259-3881-A-001-B	Bubbler - Across from 209	7/18/2018	7/19/2018	A8G0453-24	Lead	4.41	0.2	15	ppb
259-3881-B-001-A	Bubbler - Across from 209	7/18/2018	7/19/2018	A8G0453-25	Copper	0.0367	0.001	1.3	ppm
259-3881-B-001-A	Bubbler - Across from 209	7/18/2018	7/19/2018	A8G0453-25	Lead	3.35	0.2	15	ppb
259-3881-B-001-B	Bubbler - Across from 209	7/18/2018	7/19/2018	A8G0453-26	Copper	0.0457	0.001	1.3	ppm

259-3881-B-001-B	Bubbler - Across from 209	7/18/2018	7/19/2018	A8G0453-26	Lead	2.32	0.2	15	ppb
259-3884-A-001-A	Bubbler - Across from 209	7/18/2018	7/19/2018	A8G0453-27RE1	Copper	0.0563	0.001	1.3	ppm
259-3884-A-001-A	Bubbler - Across from 209	7/18/2018	7/19/2018	A8G0453-27RE1	Lead	2.42	0.2	15	ppb
259-3884-A-001-B	Bubbler - Across from 209	7/18/2018	7/19/2018	A8G0453-28	Copper	0.0439	0.001	1.3	ppm
259-3884-A-001-B	Bubbler - Across from 209	7/18/2018	7/19/2018	A8G0453-28	Lead	1.88	0.2	15	ppb
259-3884-B-001-A	Bubbler - Across from 209	7/18/2018	7/19/2018	A8G0453-29	Copper	0.0505	0.001	1.3	ppm
259-3884-B-001-A	Bubbler - Across from 209	7/18/2018	7/19/2018	A8G0453-29	Lead	2.14	0.2	15	ppb
259-3884-B-001-B	Bubbler - Across from 209	7/18/2018	7/19/2018	A8G0453-30	Copper	0.0410	0.001	1.3	ppm
259-3884-B-001-B	Bubbler - Across from 209	7/18/2018	7/19/2018	A8G0453-30	Lead	1.86	0.2	15	ppb
259-3878-NA-001-A	Bottle Filler - Across from 206	7/18/2018	7/19/2018	A8G0453-31	Copper	0.0420	0.001	1.3	ppm
259-3878-NA-001-A	Bottle Filler - Across from 206	7/18/2018	7/19/2018	A8G0453-31	Lead	1.70	0.2	15	ppb
259-3878-NA-001-B	Bottle Filler - Across from 206	7/18/2018	7/19/2018	A8G0453-32	Copper	0.00572	0.001	1.3	ppm
259-3878-NA-001-B	Bottle Filler - Across from 206	7/18/2018	7/19/2018	A8G0453-32	Lead	0.403	0.2	15	ppb
259-3875-NA-001-A	Cooler - Across from 206	7/18/2018	7/19/2018	A8G0453-33	Copper	0.0521	0.001	1.3	ppm
259-3875-NA-001-A	Cooler - Across from 206	7/18/2018	7/19/2018	A8G0453-33	Lead	0.246	0.2	15	ppb
259-3875-NA-001-B	Cooler - Across from 206	7/18/2018	7/19/2018	A8G0453-34	Copper	0.00989	0.001	1.3	ppm
259-3875-NA-001-B	Cooler - Across from 206	7/18/2018	7/19/2018	A8G0453-34	Lead	ND	0.2	15	ppb
259-3872-A-001-A	Bubbler - Right of 203	7/18/2018	7/19/2018	A8G0453-35	Copper	0.0141	0.001	1.3	ppm
259-3872-A-001-A	Bubbler - Right of 203	7/18/2018	7/19/2018	A8G0453-35	Lead	6.52	0.2	15	ppb
259-3872-A-001-B	Bubbler - Right of 203	7/18/2018	7/19/2018	A8G0453-36	Copper	0.00482	0.001	1.3	ppm
259-3872-A-001-B	Bubbler - Right of 203	7/18/2018	7/19/2018	A8G0453-36	Lead	4.43	0.2	15	ppb
259-3872-B-001-A	Bubbler - Right of 203	7/18/2018	7/19/2018	A8G0453-37	Copper	0.0115	0.001	1.3	ppm
259-3872-B-001-A	Bubbler - Right of 203	7/18/2018	7/19/2018	A8G0453-37	Lead	6.53	0.2	15	ppb
259-3872-B-001-B	Bubbler - Right of 203	7/18/2018	7/19/2018	A8G0453-38	Copper	0.00391	0.001	1.3	ppm
259-3872-B-001-B	Bubbler - Right of 203	7/18/2018	7/19/2018	A8G0453-38	Lead	3.22	0.2	15	ppb
259-3846-A-001-A	Food Prep Sprayer - Kitchen	7/18/2018	7/19/2018	A8G0453-39	Copper	0.0300	0.001	1.3	ppm
259-3846-A-001-A	Food Prep Sprayer - Kitchen	7/18/2018	7/19/2018	A8G0453-39	Lead	0.579	0.2	15	ppb
259-3846-A-001-B	Food Prep Faucet - Kitchen	7/18/2018	7/19/2018	A8G0453-40	Copper	0.00422	0.001	1.3	ppm

259-3846-A-001-B	Food Prep Faucet - Kitchen	7/18/2018	7/19/2018	A8G0453-40	Lead	ND	0.2	15	ppb
259-3846-B-001-A	Food Prep Sprayer - Kitchen	7/18/2018	7/19/2018	A8G0453-41	Copper	0.0347	0.001	1.3	ppm
259-3846-B-001-A	Food Prep Sprayer - Kitchen	7/18/2018	7/19/2018	A8G0453-41	Lead	0.403	0.2	15	ppb
259-3846-B-001-B	Food Prep Faucet - Kitchen	7/18/2018	7/19/2018	A8G0453-42	Copper	0.00836	0.001	1.3	ppm
259-3846-B-001-B	Food Prep Faucet - Kitchen	7/18/2018	7/19/2018	A8G0453-42	Lead	ND	0.2	15	ppb