Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Jackson Middle School - Test 4

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
174-CH1869-A-004-A	Hallway (C111)	4/9/2019	4/22/2019	A9D0550-01	Lead	26.40	0.20	15	ppb
174-CH1869-B-004-A	Hallway (C111)	4/9/2019	4/24/2019	A9D0550-03	Lead	16.30	0.20	15	ppb
174-CH2001-N/A-004-A	Classroom C125	4/9/2019	4/24/2019	A9D0550-05	Lead	35.00	0.20	15	ppb
174-CH2002-N/A-004-A	Hallway (G215)	4/9/2019	4/24/2019	A9D0550-07	Lead	ND	0.20	15	ppb
174-CH2003-N/A-004-A	Hallway (G215)	4/9/2019	4/24/2019	A9D0550-09	Lead	ND	0.20	15	ppb
174-CH2004-N/A-004-A	Hallway (G224)	4/9/2019	4/24/2019	A9D0550-11	Lead	9.04	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

*OHA Action Level = 15ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek