

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Jackson Middle School - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
174-CH-1883-A-005-A	Hallway (B-117)	9/11/2019	9/11/2019	A9I0288-07	Lead	0.482	0.20	15	ppb
174-CH-1883-B-005-A	Hallway (B-117)	9/11/2019	9/11/2019	A9I0288-08	Lead	ND	0.20	15	ppb
174-CH-1883-C-005-A	Hallway (B-117)	9/11/2019	9/11/2019	A9I0288-09	Lead	0.234	0.20	15	ppb
174-CH-1871-A-005-A	Hallway (C-131)	9/11/2019	9/11/2019	A9I0288-10	Lead	1.54	0.20	15	ppb
174-CH-1871-B-005-A	Hallway (C-131)	9/11/2019	9/11/2019	A9I0288-11	Lead	0.474	0.20	15	ppb
174-CH-1871-C-005-A	Hallway (C-131)	9/11/2019	9/11/2019	A9I0288-12	Lead	0.526	0.20	15	ppb
174-CH-1869-A-005-A	Hallway (C-111)	9/11/2019	9/11/2019	A9I0288-13	Lead	6.69	0.20	15	ppb
174-CH-1869-B-005-A	Hallway (C-111)	9/11/2019	9/11/2019	A9I0288-14	Lead	9.34	0.20	15	ppb
174-CH-1869-C-005-A	Hallway (C-111)	9/11/2019	9/11/2019	A9I0288-15	Lead	5.07	0.20	15	ppb
174-CH-5703-A-005-A	Hallway (G-119)	9/11/2019	9/11/2019	A9I0288-16	Lead	2.91	0.20	15	ppb
174-CH-5703-B-005-A	Hallway (G-119)	9/11/2019	9/11/2019	A9I0288-17	Lead	4.05	0.20	15	ppb
174-CH-5703-C-005-A	Hallway (G-119)	9/11/2019	9/11/2019	A9I0288-18	Lead	0.827	0.20	15	ppb
174-CH-2002-A-005-A	Hallway (G-215)	9/11/2019	9/11/2019	A9I0288-19	Lead	0.56	0.20	15	ppb
174-CH-2002-B-005-A	Hallway (G-215)	9/11/2019	9/11/2019	A9I0288-20	Lead	1.2	0.20	15	ppb
174-CH-2002-C-005-A	Hallway (G-215)	9/11/2019	9/11/2019	A9I0288-21	Lead	0.632	0.20	15	ppb
174-CH-2004-A-005-A	Hallway (G-224)	9/11/2019	9/11/2019	A9I0288-22	Lead	3.29	0.20	15	ppb
174-CH-2004-B-005-A	Hallway (G-224)	9/11/2019	9/11/2019	A9I0288-23	Lead	2.8	0.20	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb

174-CH-2004-C-005-A	Hallway (G-224)	9/11/2019	9/11/2019	A9I0288-24	Lead	5.61	0.20	15	ppb
---------------------	-----------------	-----------	-----------	------------	------	------	------	----	-----

*OHA Action Level = 15ppb