

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
James John

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
166-CH1781-N/A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-13	Copper	0.0460	0.00100	1.3	ppm
166-CH1781-N/A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-13	Lead	11.3	0.200	15	ppb
166-CH1781-N/A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-14	Copper	0.00493	0.00100	1.3	ppm
166-CH1781-N/A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-14	Lead	3.10	0.200	15	ppb
166-CH1782-N/A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-15	Copper	0.0320	0.00100	1.3	ppm
166-CH1782-N/A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-15	Lead	6.00	0.200	15	ppb
166-CH1782-N/A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-16	Copper	0.00351	0.00100	1.3	ppm
166-CH1782-N/A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-16	Lead	0.952	0.200	15	ppb
166-CH2759-A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-45	Copper	0.0339	0.00100	1.3	ppm
166-CH2759-A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-45	Lead	50.3	0.200	15	ppb
166-CH2759-A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-46	Copper	0.00205	0.00100	1.3	ppm
166-CH2759-A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-46	Lead	0.790	0.200	15	ppb
166-CH2759-B-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-47	Copper	0.0302	0.00100	1.3	ppm
166-CH2759-B-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-47	Lead	60.7	0.200	15	ppb
166-CH2759-B-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-48	Copper	0.00258	0.00100	1.3	ppm
166-CH2759-B-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-48	Lead	0.701	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Page 1 of 5

166-CH2763-A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-27	Copper	0.0228	0.00100	1.3	ppm
166-CH2763-A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-27	Lead	5.77	0.200	15	ppb
166-CH2763-A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-28	Copper	0.00272	0.00100	1.3	ppm
166-CH2763-A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-28	Lead	0.351	0.200	15	ppb
166-CH2763-B-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-29	Copper	0.0114	0.00100	1.3	ppm
166-CH2763-B-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-29	Lead	0.534	0.200	15	ppb
166-CH2763-B-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-30	Copper	0.00294	0.00100	1.3	ppm
166-CH2763-B-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-30	Lead	0.234	0.200	15	ppb
166-CH2766-N/A-001-A	Gym Bubbler	3/9/2018	3/22/2018	A8C0414-39	Copper	0.0248	0.00100	1.3	ppm
166-CH2766-N/A-001-A	Gym Bubbler	3/9/2018	3/22/2018	A8C0414-39	Lead	6.57	0.200	15	ppb
166-CH2766-N/A-001-B	Gym Bubbler	3/9/2018	3/22/2018	A8C0414-40	Copper	0.00350	0.00100	1.3	ppm
166-CH2766-N/A-001-B	Gym Bubbler	3/9/2018	3/22/2018	A8C0414-40	Lead	3.93	0.200	15	ppb
166-CH2767-A-001-A	Kitchen Sprayer	3/9/2018	3/22/2018	A8C0414-01	Copper	0.0394	0.00100	1.3	ppm
166-CH2767-A-001-A	Kitchen Sprayer	3/9/2018	3/22/2018	A8C0414-01	Lead	7.53	0.200	15	ppb
166-CH2767-A-001-B	Kitchen Sprayer	3/9/2018	3/22/2018	A8C0414-02	Copper	0.00549	0.00100	1.3	ppm
166-CH2767-A-001-B	Kitchen Sprayer	3/9/2018	3/22/2018	A8C0414-02	Lead	2.70	0.200	15	ppb
166-CH2767-B-001-A	Kitchen Faucet	3/9/2018	3/22/2018	A8C0414-03	Copper	0.0296	0.00100	1.3	ppm
166-CH2767-B-001-A	Kitchen Faucet	3/9/2018	3/22/2018	A8C0414-03	Lead	1.23	0.200	15	ppb
166-CH2767-B-001-B	Kitchen Faucet	3/9/2018	3/22/2018	A8C0414-04	Copper	0.00569	0.00100	1.3	ppm
166-CH2767-B-001-B	Kitchen Faucet	3/9/2018	3/22/2018	A8C0414-04	Lead	ND	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

166-CH2768-A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-41	Copper	0.0157	0.00100	1.3	ppm
166-CH2768-A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-41	Lead	15.7	0.200	15	ppb
166-CH2768-A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-42	Copper	0.00270	0.00100	1.3	ppm
166-CH2768-A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-42	Lead	0.272	0.200	15	ppb
166-CH2768-B-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-43	Copper	0.0115	0.00100	1.3	ppm
166-CH2768-B-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-43	Lead	10.5	0.200	15	ppb
166-CH2768-B-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-44	Copper	0.00284	0.00100	1.3	ppm
166-CH2768-B-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-44	Lead	ND	0.200	15	ppb
166-CH2769-N/A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-25	Copper	0.0287	0.00100	1.3	ppm
166-CH2769-N/A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-25	Lead	6.72	0.200	15	ppb
166-CH2769-N/A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-26	Copper	0.00320	0.00100	1.3	ppm
166-CH2769-N/A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-26	Lead	2.82	0.200	15	ppb
166-CH2770-N/A-001-A	Kitchen Faucet	3/9/2018	3/22/2018	A8C0414-05	Copper	0.0617	0.00100	1.3	ppm
166-CH2770-N/A-001-A	Kitchen Faucet	3/9/2018	3/22/2018	A8C0414-05	Lead	0.346	0.200	15	ppb
166-CH2770-N/A-001-B	Kitchen Faucet	3/9/2018	3/22/2018	A8C0414-06	Copper	0.00881	0.00100	1.3	ppm
166-CH2770-N/A-001-B	Kitchen Faucet	3/9/2018	3/22/2018	A8C0414-06	Lead	ND	0.200	15	ppb
166-CH2772-A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-21	Copper	0.0125	0.00100	1.3	ppm
166-CH2772-A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-21	Lead	14.5	0.200	15	ppb
166-CH2772-A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-22	Copper	0.00201	0.00100	1.3	ppm
166-CH2772-A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-22	Lead	0.695	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Page 3 of 5

166-CH2772-B-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-23	Copper	0.0151	0.00100	1.3	ppm
166-CH2772-B-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-23	Lead	11.1	0.200	15	ppb
166-CH2772-B-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-24	Copper	0.00245	0.00100	1.3	ppm
166-CH2772-B-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-24	Lead	0.579	0.200	15	ppb
166-CH2773-A-001-A	Cafteria Bubbler	3/9/2018	3/22/2018	A8C0414-31	Copper	0.0404	0.00100	1.3	ppm
166-CH2773-A-001-A	Cafteria Bubbler	3/9/2018	3/22/2018	A8C0414-31	Lead	8.39	0.200	15	ppb
166-CH2773-A-001-B	Cafteria Bubbler	3/9/2018	3/22/2018	A8C0414-32	Copper	0.00315	0.00100	1.3	ppm
166-CH2773-A-001-B	Cafteria Bubbler	3/9/2018	3/22/2018	A8C0414-32	Lead	2.14	0.200	15	ppb
166-CH2773-B-001-A	Cafteria Bubbler	3/9/2018	3/22/2018	A8C0414-33	Copper	0.0187	0.00100	1.3	ppm
166-CH2773-B-001-A	Cafteria Bubbler	3/9/2018	3/22/2018	A8C0414-33	Lead	2.44	0.200	15	ppb
166-CH2773-B-001-B	Cafteria Bubbler	3/9/2018	3/22/2018	A8C0414-34	Copper	0.00790	0.00100	1.3	ppm
166-CH2773-B-001-B	Cafteria Bubbler	3/9/2018	3/22/2018	A8C0414-34	Lead	1.10	0.200	15	ppb
166-CH2776-N/A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-37	Copper	0.0105	0.00100	1.3	ppm
166-CH2776-N/A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-07	Copper	0.0809	0.00100	1.3	ppm
166-CH2776-N/A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-37	Lead	0.761	0.200	15	ppb
166-CH2776-N/A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-07	Lead	1.26	0.200	15	ppb
166-CH2776-N/A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-38	Copper	0.00448	0.00100	1.3	ppm
166-CH2776-N/A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-08	Copper	0.00461	0.00100	1.3	ppm
166-CH2776-N/A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-38	Lead	0.497	0.200	15	ppb
166-CH2776-N/A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-08	Lead	ND	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

166-CH2779-A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-09	Copper	0.0158	0.00100	1.3	ppm
166-CH2779-A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-09	Lead	8.08	0.200	15	ppb
166-CH2779-A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-10	Copper	0.00216	0.00100	1.3	ppm
166-CH2779-A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-10	Lead	3.33	0.200	15	ppb
166-CH2779-B-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-11	Copper	0.0134	0.00100	1.3	ppm
166-CH2779-B-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-11	Lead	3.70	0.200	15	ppb
166-CH2779-B-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-12	Copper	0.00249	0.00100	1.3	ppm
166-CH2779-B-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-12	Lead	3.68	0.200	15	ppb
166-CH2780-N/A-001-A	Hall Water Bottle F	3/9/2018	3/22/2018	A8C0414-35	Copper	0.0151	0.00100	1.3	ppm
166-CH2780-N/A-001-A	Hall Water Bottle F	3/9/2018	3/22/2018	A8C0414-35	Lead	0.519	0.200	15	ppb
166-CH2780-N/A-001-B	Hall Water Bottle F	3/9/2018	3/22/2018	A8C0414-36	Copper	0.00297	0.00100	1.3	ppm
166-CH2780-N/A-001-B	Hall Water Bottle F	3/9/2018	3/22/2018	A8C0414-36	Lead	ND	0.200	15	ppb
166-CH2781-N/A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-19	Copper	0.0216	0.00100	1.3	ppm
166-CH2781-N/A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-19	Lead	0.982	0.200	15	ppb
166-CH2781-N/A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-20	Copper	0.0164	0.00100	1.3	ppm
166-CH2781-N/A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-20	Lead	0.282	0.200	15	ppb
166-CH2783-N/A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-17	Copper	0.0163	0.00100	1.3	ppm
166-CH2783-N/A-001-A	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-17	Lead	1.40	0.200	15	ppb
166-CH2783-N/A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-18	Copper	0.00749	0.00100	1.3	ppm
166-CH2783-N/A-001-B	Hall Bubbler	3/9/2018	3/22/2018	A8C0414-18	Lead	ND	0.200	15	ppb

Results highlighted yellow indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Page 5 of 5