

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
James John Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
166-2759-A-002A Hallway 40	11/14/18 6:23 AM	11/19/18 1:21 PM	18030094	Copper	0.1	1.3	ppm
166-2759-A-002A Hallway 40	11/14/18 6:23 AM	11/19/18 1:21 PM	18030094	Lead	15	15	ppb
166-2759-A-002B Hallway 40	11/14/18 6:24 AM	11/19/18 1:22 PM	18030117	Copper	< 0.1	1.3	ppm
166-2759-A-002B Hallway 40	11/14/18 6:24 AM	11/19/18 1:22 PM	18030117	Lead	< 1	15	ppb
166-2759-B-002A Hallway 40	11/14/18 6:25 AM	11/19/18 1:31 PM	18030113	Copper	< 0.1	1.3	ppm
166-2759-B-002A Hallway 40	11/14/18 6:25 AM	11/19/18 1:31 PM	18030113	Lead	2	15	ppb
166-2759-B-002B Hallway 40	11/14/18 6:26 AM	11/19/18 1:32 PM	18030097	Copper	< 0.1	1.3	ppm
166-2759-B-002B Hallway 40	11/14/18 6:26 AM	11/19/18 1:32 PM	18030097	Lead	< 1	15	ppb
166-2768-A-002A Hallway 39	11/14/18 6:33 AM	11/19/18 1:33 PM	18030114	Copper	< 0.1	1.3	ppm
166-2768-A-002A Hallway 39	11/14/18 6:33 AM	11/19/18 1:33 PM	18030114	Lead	15	15	ppb
166-2768-A-002B Hallway 39	11/14/18 6:34 AM	11/19/18 1:34 PM	18030098	Copper	< 0.1	1.3	ppm
166-2768-A-002B Hallway 39	11/14/18 6:34 AM	11/19/18 1:34 PM	18030098	Lead	< 1	15	ppb
166-2768-B-002A Hallway 39	11/14/18 6:35 AM	11/19/18 1:35 PM	18030090	Copper	< 0.1	1.3	ppm
166-2768-B-002A Hallway 39	11/14/18 6:35 AM	11/19/18 1:35 PM	18030090	Lead	4	15	ppb
166-2768-B-002B Hallway 39	11/14/18 6:36 AM	11/19/18 1:37 PM	18030087	Copper	< 0.1	1.3	ppm
166-2768-B-002B Hallway 39	11/14/18 6:36 AM	11/19/18 1:37 PM	18030087	Lead	< 1	15	ppb
166-2765-A-002A Classroom 37	11/14/18 6:40 AM	11/19/18 1:38 PM	18030111	Copper	0.2	1.3	ppm
166-2765-A-002A Classroom 37	11/14/18 6:40 AM	11/19/18 1:38 PM	18030111	Lead	9	15	ppb
166-2765-A-002B Classroom 37	11/14/18 6:41 AM	11/19/18 1:39 PM	18030099	Copper	0.4	1.3	ppm
166-2765-A-002B Classroom 37	11/14/18 6:41 AM	11/19/18 1:39 PM	18030099	Lead	3	15	ppb
166-2771-A-002A Classroom 39	11/14/18 6:45 AM	11/19/18 1:40 PM	18030095	Copper	0.8	1.3	ppm
166-2771-A-002A Classroom 39	11/14/18 6:45 AM	11/19/18 1:40 PM	18030095	Lead	15	15	ppb
166-2771-A-002B Classroom 39	11/14/18 6:46 AM	11/19/18 1:41 PM	18030091	Copper	1	1.3	ppm
166-2771-A-002B Classroom 39	11/14/18 6:46 AM	11/19/18 1:41 PM	18030091	Lead	3	15	ppb
166-2774-A-002A Classroom 38	11/14/18 6:50 AM	11/19/18 1:54 PM	18030116	Copper	< 0.1	1.3	ppm
166-2774-A-002A Classroom 38	11/14/18 6:50 AM	11/19/18 1:54 PM	18030116	Lead	3	15	ppb
166-2774-A-002B Classroom 38	11/14/18 6:51 AM	11/19/18 1:55 PM	18030112	Copper	< 0.1	1.3	ppm
166-2774-A-002B Classroom 38	11/14/18 6:51 AM	11/19/18 1:55 PM	18030112	Lead	3	15	ppb
166-2777-A-002A Classroom 30	11/14/18 6:57 AM	11/19/18 1:56 PM	18030106	Copper	0.5	1.3	ppm
166-2777-A-002A Classroom 30	11/14/18 6:57 AM	11/19/18 1:56 PM	18030106	Lead	12	15	ppb
166-2777-A-002B Classroom 30	11/14/18 6:58 AM	11/19/18 1:57 PM	18030104	Copper	0.5	1.3	ppm
166-2777-A-002B Classroom 30	11/14/18 6:58 AM	11/19/18 1:57 PM	18030104	Lead	2	15	ppb
166-2757-A-002A Classroom 29	11/14/18 7:02 AM	11/19/18 1:58 PM	18030101	Copper	0.6	1.3	ppm
166-2757-A-002A Classroom 29	11/14/18 7:02 AM	11/19/18 1:58 PM	18030101	Lead	11	15	ppb
166-2757-A-002B Classroom 29	11/14/18 7:03 AM	11/19/18 1:59 PM	18030102	Copper	0.5	1.3	ppm
166-2757-A-002B Classroom 29	11/14/18 7:03 AM	11/19/18 1:59 PM	18030102	Lead	2	15	ppb
166-2775-A-002A Classroom 21	11/14/18 7:12 AM	11/19/18 2:01 PM	18030103	Copper	0.2	1.3	ppm
166-2775-A-002A Classroom 21	11/14/18 7:12 AM	11/19/18 2:01 PM	18030103	Lead	7	15	ppb
166-2775-A-002B Classroom 21	11/14/18 7:13 AM	11/19/18 2:02 PM	18030108	Copper	0.8	1.3	ppm
166-2775-A-002B Classroom 21	11/14/18 7:13 AM	11/19/18 2:02 PM	18030108	Lead	3	15	ppb
166-2778-A-002A Classroom 20	11/14/18 7:17 AM	11/19/18 2:03 PM	18030110	Copper	< 0.1	1.3	ppm
166-2778-A-002A Classroom 20	11/14/18 7:17 AM	11/19/18 2:03 PM	18030110	Lead	10	15	ppb
166-2778-A-002B Classroom 20	11/14/18 7:18 AM	11/19/18 2:04 PM	18030115	Copper	< 0.1	1.3	ppm
166-2778-A-002B Classroom 20	11/14/18 7:18 AM	11/19/18 2:04 PM	18030115	Lead	8	15	ppb
166-2758-A-002A Classroom 19	11/14/18 7:22 AM	11/19/18 2:12 PM	18030092	Copper	< 0.1	1.3	ppm
166-2758-A-002A Classroom 19	11/14/18 7:22 AM	11/19/18 2:12 PM	18030092	Lead	19	15	ppb
166-2758-A-002B Classroom 19	11/14/18 7:23 AM	11/19/18 2:14 PM	18030100	Copper	< 0.1	1.3	ppm
166-2758-A-002B Classroom 19	11/14/18 7:23 AM	11/19/18 2:14 PM	18030100	Lead	22	15	ppb
166-2760-A-002A Classroom 28	11/14/18 7:08 AM	11/19/18 2:15 PM	18030165	Copper	< 0.10	1.3	ppm
166-2760-A-002A Classroom 28	11/14/18 7:08 AM	11/19/18 2:15 PM	18030165	Lead	52	15	ppb
166-2760-A-002B Classroom 28	11/14/18 7:09 AM	11/19/18 2:16 PM	18030166	Copper	< 0.1	1.3	ppm
166-2760-A-002B Classroom 28	11/14/18 7:09 AM	11/19/18 2:16 PM	18030166	Lead	14	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.