

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
James John Elementary School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
166-CH2780-N/A-003-A	Hallway (29)	4/2/2019	4/16/2019	A9D0330-01	Lead	2	0.20	15	ppb
166-CH2762-N/A-003-A	Classroom 40	4/2/2019	4/16/2019	A9D0330-03	Lead	28.20	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.