

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Jefferson

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
118-CH3595-NA-004-A	Staff A 12	9/20/2018	9/24/2018	A8I0549-35	Copper	0.0405	0.00200	1.3	ppm
118-CH3595-NA-004-A	Staff A 12	9/20/2018	9/24/2018	A8I0549-35	Lead	5.65	0.200	15	ppb
118-CH3595-NA-004-B	Staff A 12	9/20/2018	9/24/2018	A8I0549-36	Copper	0.0217	0.00200	1.3	ppm
118-CH3595-NA-004-B	Staff A 12	9/20/2018	9/24/2018	A8I0549-36	Lead	11.3	0.200	15	ppb
118-CH3601-NA-004-A	Staff A 11	9/20/2018	9/24/2018	A8I0549-39RE1	Copper	0.0181	0.00200	1.3	ppm
118-CH3601-NA-004-A	Staff A 11	9/20/2018	9/24/2018	A8I0549-39RE1	Lead	19.1	0.200	15	ppb
118-CH3601-NA-004-B	Staff A 11	9/20/2018	9/24/2018	A8I0549-40	Copper	0.00245	0.00200	1.3	ppm
118-CH3601-NA-004-B	Staff A 11	9/20/2018	9/24/2018	A8I0549-40	Lead	9.01	0.200	15	ppb
118-CH3604-A-004-A	Staff A 11	9/20/2018	9/24/2018	A8I0549-41	Copper	0.0295	0.00200	1.3	ppm
118-CH3604-A-004-A	Staff A 11	9/20/2018	9/24/2018	A8I0549-41	Lead	17.8	0.200	15	ppb
118-CH3604-A-004-B	Staff A 11	9/20/2018	9/24/2018	A8I0549-42	Copper	0.00848	0.00200	1.3	ppm
118-CH3604-A-004-B	Staff A 11	9/20/2018	9/24/2018	A8I0549-42	Lead	11.3	0.200	15	ppb
118-CH3604-B-004-A	Staff A 11	9/20/2018	9/24/2018	A8I0549-43	Copper	0.0126	0.00200	1.3	ppm
118-CH3604-B-004-A	Staff A 11	9/20/2018	9/24/2018	A8I0549-43	Lead	9.73	0.200	15	ppb
118-CH3604-B-004-B	Staff A 11	9/20/2018	9/24/2018	A8I0549-44	Copper	0.00300	0.00200	1.3	ppm
118-CH3604-B-004-B	Staff A 11	9/20/2018	9/24/2018	A8I0549-44	Lead	7.26	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

118-CH3607-NA-004-A	Staff A 10	9/20/2018	9/24/2018	A8I0549-37	Copper	0.162	0.00200	1.3	ppm
118-CH3607-NA-004-A	Staff A 10	9/20/2018	9/24/2018	A8I0549-37	Lead	113	0.200	15	ppb
118-CH3607-NA-004-B	Staff A 10	9/20/2018	9/24/2018	A8I0549-38	Copper	0.00883	0.00200	1.3	ppm
118-CH3607-NA-004-B	Staff A 10	9/20/2018	9/24/2018	A8I0549-38	Lead	8.51	0.200	15	ppb
118-CH3609-NA-004-A	Staff A 8	9/20/2018	9/24/2018	A8I0549-33	Copper	0.0899	0.00200	1.3	ppm
118-CH3609-NA-004-A	Staff A 8	9/20/2018	9/24/2018	A8I0549-33	Lead	51.9	0.200	15	ppb
118-CH3609-NA-004-B	Staff A 8	9/20/2018	9/24/2018	A8I0549-34RE1	Copper	0.0908	0.00200	1.3	ppm
118-CH3609-NA-004-B	Staff A 8	9/20/2018	9/24/2018	A8I0549-34RE1	Lead	19.0	0.200	15	ppb
118-CH3610-N/A-004-A	Indian Ed. Office	9/20/2018	9/24/2018	A8I0549-01	Copper	0.202	0.00200	1.3	ppm
118-CH3610-N/A-004-A	Indian Ed. Office	9/20/2018	9/24/2018	A8I0549-01	Lead	22.7	0.200	15	ppb
118-CH3610-N/A-004-B	Indian Ed. Office	9/20/2018	9/24/2018	A8I0549-02	Copper	0.196	0.00200	1.3	ppm
118-CH3610-N/A-004-B	Indian Ed. Office	9/20/2018	9/24/2018	A8I0549-02	Lead	2.38	0.200	15	ppb
118-CH3612-NA-004-A	Staff A 7	9/20/2018	9/24/2018	A8I0549-29	Copper	0.0404	0.00200	1.3	ppm
118-CH3612-NA-004-A	Staff A 7	9/20/2018	9/24/2018	A8I0549-29	Lead	58.8	0.200	15	ppb
118-CH3612-NA-004-B	Staff A 7	9/20/2018	9/24/2018	A8I0549-30	Copper	0.0165	0.00200	1.3	ppm
118-CH3612-NA-004-B	Staff A 7	9/20/2018	9/24/2018	A8I0549-30	Lead	11.5	0.200	15	ppb
118-CH3613-N/A-004-A	A 41	9/20/2018	9/24/2018	A8I0549-03	Copper	0.478	0.00200	1.3	ppm
118-CH3613-N/A-004-A	A 41	9/20/2018	9/24/2018	A8I0549-03	Lead	154	0.200	15	ppb
118-CH3613-N/A-004-B	A 41	9/20/2018	9/24/2018	A8I0549-04	Copper	0.283	0.00200	1.3	ppm
118-CH3613-N/A-004-B	A 41	9/20/2018	9/24/2018	A8I0549-04	Lead	13.8	0.200	15	ppb

118-CH3615-NA-004-A	Staff A 7	9/20/2018	9/24/2018	A8I0549-31	Copper	0.0428	0.00200	1.3	ppm
118-CH3615-NA-004-A	Staff A 7	9/20/2018	9/24/2018	A8I0549-31	Lead	21.3	0.200	15	ppb
118-CH3615-NA-004-B	Staff A 7	9/20/2018	9/24/2018	A8I0549-32	Copper	0.0136	0.00200	1.3	ppm
118-CH3615-NA-004-B	Staff A 7	9/20/2018	9/24/2018	A8I0549-32	Lead	11.0	0.200	15	ppb
118-CH3618-NA-004-A	Staff A 7	9/20/2018	9/24/2018	A8I0549-27	Copper	0.0402	0.00200	1.3	ppm
118-CH3618-NA-004-A	Staff A 7	9/20/2018	9/24/2018	A8I0549-27	Lead	11.1	0.200	15	ppb
118-CH3618-NA-004-B	Staff A 7	9/20/2018	9/24/2018	A8I0549-28	Copper	0.0266	0.00200	1.3	ppm
118-CH3618-NA-004-B	Staff A 7	9/20/2018	9/24/2018	A8I0549-28	Lead	6.87	0.200	15	ppb
118-CH3620-N/A-004-A	A 44	9/20/2018	9/24/2018	A8I0549-07RE1	Copper	3.97	0.0200	1.3	ppm
118-CH3620-N/A-004-A	A 44	9/20/2018	9/24/2018	A8I0549-07	Lead	21.6	0.200	15	ppb
118-CH3620-N/A-004-B	A 44	9/20/2018	9/24/2018	A8I0549-08	Copper	0.206	0.00200	1.3	ppm
118-CH3620-N/A-004-B	A 44	9/20/2018	9/24/2018	A8I0549-08	Lead	1.41	0.200	15	ppb
118-CH3623-N/A-004-A	A 42 Weight Room	9/20/2018	9/24/2018	A8I0549-09	Copper	0.253	0.00200	1.3	ppm
118-CH3623-N/A-004-A	A 42 Weight Room	9/20/2018	9/24/2018	A8I0549-09	Lead	56.2	0.200	15	ppb
118-CH3623-N/A-004-B	A 42 Weight Room	9/20/2018	9/24/2018	A8I0549-10	Copper	0.129	0.00200	1.3	ppm
118-CH3623-N/A-004-B	A 42 Weight Room	9/20/2018	9/24/2018	A8I0549-10	Lead	33.0	0.200	15	ppb
118-CH3626-NA-004-A	East Gym	9/20/2018	9/24/2018	A8I0549-45	Copper	0.0172	0.00200	1.3	ppm
118-CH3626-NA-004-A	East Gym	9/20/2018	9/24/2018	A8I0549-45	Lead	0.815	0.200	15	ppb
118-CH3626-NA-004-B	East Gym	9/20/2018	9/24/2018	A8I0549-46	Copper	0.169	0.00200	1.3	ppm
118-CH3626-NA-004-B	East Gym	9/20/2018	9/24/2018	A8I0549-46	Lead	1.05	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

118-CH3634-NA-004-A	Portable	9/20/2018	9/24/2018	A8I0549-61RE1	Copper	0.0463	0.00200	1.3	ppm
118-CH3634-NA-004-A	Portable	9/20/2018	9/24/2018	A8I0549-61RE1	Lead	15.3	0.200	15	ppb
118-CH3634-NA-004-B	Portable	9/20/2018	9/24/2018	A8I0549-62RE1	Copper	0.0587	0.00200	1.3	ppm
118-CH3634-NA-004-B	Portable	9/20/2018	9/24/2018	A8I0549-62RE1	Lead	24.7	0.200	15	ppb
118-CH3637-N/A-004-A	Main Gym Entry	9/20/2018	9/24/2018	A8I0549-17	Copper	0.457	0.00200	1.3	ppm
118-CH3637-N/A-004-A	Main Gym Entry	9/20/2018	9/24/2018	A8I0549-17	Lead	2.63	0.200	15	ppb
118-CH3637-N/A-004-B	Main Gym Entry	9/20/2018	9/24/2018	A8I0549-18	Copper	0.0366	0.00200	1.3	ppm
118-CH3637-N/A-004-B	Main Gym Entry	9/20/2018	9/24/2018	A8I0549-18	Lead	1.18	0.200	15	ppb
118-CH3644-NA-004-A	Hall to Dance Wing	9/20/2018	9/24/2018	A8I0549-59RE1	Copper	0.0121	0.00200	1.3	ppm
118-CH3644-NA-004-A	Hall to Dance Wing	9/20/2018	9/24/2018	A8I0549-59RE1	Lead	8.02	0.200	15	ppb
118-CH3644-NA-004-B	Hall to Dance Wing	9/20/2018	9/24/2018	A8I0549-60RE2	Copper	0.00276	0.00200	1.3	ppm
118-CH3644-NA-004-B	Hall to Dance Wing	9/20/2018	9/24/2018	A8I0549-60RE2	Lead	1.67	0.200	15	ppb
118-CH3646-N/A-004-A	Locker Room	9/20/2018	9/24/2018	A8I0549-15	Copper	0.0386	0.00200	1.3	ppm
118-CH3646-N/A-004-A	Locker Room	9/20/2018	9/24/2018	A8I0549-15	Lead	52.8	0.200	15	ppb
118-CH3646-N/A-004-B	Locker Room	9/20/2018	9/24/2018	A8I0549-16	Copper	0.0341	0.00200	1.3	ppm
118-CH3646-N/A-004-B	Locker Room	9/20/2018	9/24/2018	A8I0549-16	Lead	2.05	0.200	15	ppb
118-CH3648-A-004-A	Transition Room	9/20/2018	9/24/2018	A8I0549-11	Copper	0.0360	0.00200	1.3	ppm
118-CH3648-A-004-A	Transition Room	9/20/2018	9/24/2018	A8I0549-11	Lead	9.35	0.200	15	ppb
118-CH3648-A-004-B	Transition Room	9/20/2018	9/24/2018	A8I0549-12	Copper	0.00908	0.00200	1.3	ppm
118-CH3648-A-004-B	Transition Room	9/20/2018	9/24/2018	A8I0549-12	Lead	2.62	0.200	15	ppb

118-CH3648-B-004-A	Transition Room	9/20/2018	9/24/2018	A8I0549-13	Copper	0.0285	0.00200	1.3	ppm
118-CH3648-B-004-A	Transition Room	9/20/2018	9/24/2018	A8I0549-13	Lead	24.1	0.200	15	ppb
118-CH3648-B-004-B	Transition Room	9/20/2018	9/24/2018	A8I0549-14	Copper	0.00243	0.00200	1.3	ppm
118-CH3648-B-004-B	Transition Room	9/20/2018	9/24/2018	A8I0549-14	Lead	3.22	0.200	15	ppb
118-CH3650-N/A-004-A	Main Gym	9/20/2018	9/24/2018	A8I0549-19	Copper	0.434	0.00200	1.3	ppm
118-CH3650-N/A-004-A	Main Gym	9/20/2018	9/24/2018	A8I0549-19	Lead	15.9	0.200	15	ppb
118-CH3650-N/A-004-B	Main Gym	9/20/2018	9/24/2018	A8I0549-20	Copper	0.144	0.00200	1.3	ppm
118-CH3650-N/A-004-B	Main Gym	9/20/2018	9/24/2018	A8I0549-20	Lead	5.05	0.200	15	ppb
118-CH3651-NA-004-A	Faculty Break Room	9/20/2018	9/24/2018	A8I0549-51RE1	Copper	0.0766	0.00200	1.3	ppm
118-CH3651-NA-004-A	Faculty Break Room	9/20/2018	9/24/2018	A8I0549-51RE1	Lead	16.2	0.200	15	ppb
118-CH3651-NA-004-B	Faculty Break Room	9/20/2018	9/24/2018	A8I0549-52RE1	Copper	0.0102	0.00200	1.3	ppm
118-CH3651-NA-004-B	Faculty Break Room	9/20/2018	9/24/2018	A8I0549-52RE1	Lead	5.09	0.200	15	ppb
118-CH3652-NA-004-A	Hall to Studio A	9/20/2018	9/24/2018	A8I0549-49	Copper	0.0187	0.00200	1.3	ppm
118-CH3652-NA-004-A	Hall to Studio A	9/20/2018	9/24/2018	A8I0549-49	Lead	87.9	0.200	15	ppb
118-CH3652-NA-004-B	Hall to Studio A	9/20/2018	9/24/2018	A8I0549-50	Copper	0.00652	0.00200	1.3	ppm
118-CH3652-NA-004-B	Hall to Studio A	9/20/2018	9/24/2018	A8I0549-50	Lead	60.5	0.200	15	ppb
118-CH3653-N/A-004-A	Concession	9/20/2018	9/24/2018	A8I0549-21	Copper	0.0290	0.00200	1.3	ppm
118-CH3653-N/A-004-A	Concession	9/20/2018	9/24/2018	A8I0549-21	Lead	4.96	0.200	15	ppb
118-CH3653-N/A-004-B	Concession	9/20/2018	9/24/2018	A8I0549-22	Copper	0.0218	0.00200	1.3	ppm
118-CH3653-N/A-004-B	Concession	9/20/2018	9/24/2018	A8I0549-22	Lead	2.10	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

118-CH3656-N/A-004-A	Concession	9/20/2018	9/24/2018	A8I0549-23	Copper	0.0426	0.00200	1.3	ppm
118-CH3656-N/A-004-A	Concession	9/20/2018	9/24/2018	A8I0549-23	Lead	12.6	0.200	15	ppb
118-CH3656-N/A-004-B	Concession	9/20/2018	9/24/2018	A8I0549-24	Copper	0.0234	0.00200	1.3	ppm
118-CH3656-N/A-004-B	Concession	9/20/2018	9/24/2018	A8I0549-24	Lead	2.74	0.200	15	ppb
118-CH3666-NA-004-A	Hall A 78	9/20/2018	9/24/2018	A8I0549-57RE1	Copper	0.00672	0.00200	1.3	ppm
118-CH3666-NA-004-A	Hall A 78	9/20/2018	9/24/2018	A8I0549-57RE1	Lead	16.8	0.200	15	ppb
118-CH3666-NA-004-B	Hall A 78	9/20/2018	9/24/2018	A8I0549-58RE1	Copper	0.00225	0.00200	1.3	ppm
118-CH3666-NA-004-B	Hall A 78	9/20/2018	9/24/2018	A8I0549-58RE1	Lead	27.9	0.200	15	ppb
118-CH3668-N/A-004-A	A 43	9/20/2018	9/24/2018	A8I0549-05RE1	Copper	1.15	0.0100	1.3	ppm
118-CH3668-N/A-004-A	A 43	9/20/2018	9/24/2018	A8I0549-05RE1	Lead	232	1.00	15	ppb
118-CH3668-N/A-004-B	A 43	9/20/2018	9/24/2018	A8I0549-06	Copper	0.0135	0.00200	1.3	ppm
118-CH3668-N/A-004-B	A 43	9/20/2018	9/24/2018	A8I0549-06	Lead	3.75	0.200	15	ppb
118-CH3983-NA-004-A	Staff C 20	9/20/2018	9/24/2018	A8I0549-55RE1	Copper	0.0411	0.00200	1.3	ppm
118-CH3983-NA-004-A	Staff C 20	9/20/2018	9/24/2018	A8I0549-55RE1	Lead	10.1	0.200	15	ppb
118-CH3983-NA-004-B	Staff C 20	9/20/2018	9/24/2018	A8I0549-56RE1	Copper	0.00556	0.00200	1.3	ppm
118-CH3983-NA-004-B	Staff C 20	9/20/2018	9/24/2018	A8I0549-56RE1	Lead	2.00	0.200	15	ppb
118-CH3986-NA-004-A	Staff C 19	9/20/2018	9/24/2018	A8I0549-53RE1	Copper	0.0458	0.00200	1.3	ppm
118-CH3986-NA-004-A	Staff C 19	9/20/2018	9/24/2018	A8I0549-53RE1	Lead	7.82	0.200	15	ppb
118-CH3986-NA-004-B	Staff C 19	9/20/2018	9/24/2018	A8I0549-54RE1	Copper	0.00603	0.00200	1.3	ppm
118-CH3986-NA-004-B	Staff C 19	9/20/2018	9/24/2018	A8I0549-54RE1	Lead	6.81	0.200	15	ppb

118-CH3992-N/A-004-A	D 13	9/20/2018	9/24/2018	A8I0549-25	Copper	0.0433	0.00200	1.3	ppm
118-CH3992-N/A-004-A	D 13	9/20/2018	9/24/2018	A8I0549-25	Lead	13.4	0.200	15	ppb
118-CH3992-N/A-004-B	D 13	9/20/2018	9/24/2018	A8I0549-26	Copper	0.00466	0.00200	1.3	ppm
118-CH3992-N/A-004-B	D 13	9/20/2018	9/24/2018	A8I0549-26	Lead	5.68	0.200	15	ppb
118-CH3995-NA-004-A	Downstairs B 23	9/20/2018	9/24/2018	A8I0549-47	Copper	0.0226	0.00200	1.3	ppm
118-CH3995-NA-004-A	Downstairs B 23	9/20/2018	9/24/2018	A8I0549-47	Lead	28.2	0.200	15	ppb
118-CH3995-NA-004-B	Downstairs B 23	9/20/2018	9/24/2018	A8I0549-48	Copper	0.0456	0.00200	1.3	ppm
118-CH3995-NA-004-B	Downstairs B 23	9/20/2018	9/24/2018	A8I0549-48RE1	Lead	23.8	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.