

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Jefferson High School - Test 4**

| Sample Identification # | Location                      | Date/Time Collected | Date Analyzed | Lab ID     | Analyte | Results | Detection Limit | PPS Action Level* | Units |
|-------------------------|-------------------------------|---------------------|---------------|------------|---------|---------|-----------------|-------------------|-------|
| 118-CH3641-N/A-004-A    | Hallway (TV Wing/Boys Locker) | 5/24/2019           | 6/5/2019      | A9E0811-28 | Lead    | 16.90   | 0.20            | 15                | ppb   |
| 118-CH3664-N/A-004-A    | Hallway (Engineering Studio)  | 5/24/2019           | 6/5/2019      | A9E0811-29 | Lead    | 13.8    | 0.20            | 15                | ppb   |
| 118-CH3655-N/A-004-A    | TV Studio A Balcony           | 5/24/2019           | 6/5/2019      | A9E0811-30 | Lead    | 97.50   | 0.20            | 15                | ppb   |
| 118-CH3658-N/A-004-A    | Staff (B-38)                  | 5/24/2019           | 6/5/2019      | A9E0811-31 | Lead    | 1.34    | 0.20            | 15                | ppb   |

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.