Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Kellogg Middle School - Test 1

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
261-DF-6422-N/A-001-A	Kitchen-Servery 120	7/28/2021	08/05/2021	A1G0852-66	Lead	1.45	0.2	15	ppb
261-DF-6423-N/A-001-A	Kitchen-121	7/28/2021	08/05/2021	A1G0852-67	Lead	0.813	0.2	15	ppb
261-DF-6424-N/A-001-A	Kitchen-121	7/28/2021	08/10/2021	A1G0852-68	Lead	4.37	0.2	15	ppb
261-DF-6425-N/A-001-A	Kitchen-Dishwashing 121a	7/28/2021	08/10/2021	A1G0852-69	Lead	3.18	0.2	15	ppb
261-DF-6426-N/A-001-A	Kitchen-Steamer	7/28/2021	08/05/2021	A1G0852-70	Lead	0.616	0.2	15	ppb
261-DF-6427-N/A-001-A	Kitchen-Boiler	7/28/2021	08/05/2021	A1G0852-71	Lead	9.45	0.2	15	ppb
261-DF-6420-N/A-001-A	Staff 136	7/28/2021	08/05/2021	A1G0852-72	Lead	1.82	0.2	15	ppb
261-DF-6421-N/A-001-A	Health Room 100i	7/28/2021	08/05/2021	A1G0852-73	Lead	4.64	0.2	15	ppb
261-DF-6431-A-001-A	Lobby H107 (Restroom 131)	7/28/2021	08/05/2021	A1G0852-74	Lead	ND	0.2	15	ppb
261-DF-6417-A-001-A	Corridor H103 (Restroom 105)	7/28/2021	08/05/2021	A1G0852-75	Lead	0.230	0.2	15	ppb
261-DF-6416-N/A-001-A	Intensive Skills 107	7/28/2021	08/05/2021	A1G0852-76	Lead	5.09	0.2	15	ppb
261-DF-6418-N/A-001-A	Art 108	7/28/2021	08/10/2021	A1G0852-77	Lead	5.32	0.2	15	ppb
261-DF-6415-N/A-001-A	Parent Community Room 111	7/28/2021	08/05/2021	A1G0852-78	Lead	3.61	0.2	15	ppb
261-DF-6419-N/A-001-A	Textbook Storage 113a	7/28/2021	08/05/2021	A1G0852-79	Lead	8.42	0.2	15	ppb
261-DF-6432-A-001-A	Corridor H202 (206)	7/28/2021	08/05/2021	A1G0852-80	Lead	ND	0.2	15	ppb
261-DF-6433-A-001-A	Corridor H302 (306)	7/28/2021	08/05/2021	A1G0852-81	Lead	0.238	0.2	15	ppb

*OHA Action Level = 15ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek