

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Kelly Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
258-5392-A-001A Outside Gym	08/01/18 7:50 AM	08/03/18 6:55 PM	18017170	Copper	0.8	1.3	ppm
258-5392-A-001A Outside Gym	08/01/18 7:50 AM	08/03/18 6:55 PM	18017170	Lead	1	15	ppb
258-5392-A-001B Outside Gym	08/01/18 7:50 AM	08/06/18 10:56 AM	18017165	Copper	1.0	1.3	ppm
258-5392-A-001B Outside Gym	08/01/18 7:50 AM	08/03/18 6:57 PM	18017165	Lead	<1	15	ppb
258-5336-A-001A Gym	08/01/18 8:05 AM	08/06/18 10:59 AM	18017160	Copper	1.5	1.3	ppm
258-5336-A-001A Gym	08/01/18 8:05 AM	08/03/18 7:00 PM	18017160	Lead	6	15	ppb
258-5336-A-001B Gym	08/01/18 8:05 AM	08/06/18 11:02 AM	18017172	Copper	2.0	1.3	ppm
258-5336-A-001B Gym	08/01/18 8:05 AM	08/03/18 7:17 PM	18017172	Lead	2	15	ppb
258-5330-A-001A Outside Room 118	08/01/18 8:13 AM	08/03/18 7:19 PM	18017161	Copper	0.8	1.3	ppm
258-5330-A-001A Outside Room 118	08/01/18 8:13 AM	08/03/18 7:19 PM	18017161	Lead	4	15	ppb
258-5330-A-001B Outside Room 118	08/01/18 8:13 AM	08/06/18 11:09 AM	18017168	Copper	1.4	1.3	ppm
258-5330-A-001B Outside Room 118	08/01/18 8:13 AM	08/03/18 7:21 PM	18017168	Lead	<1	15	ppb
258-5337-A-001A Cafeteria (Left)	08/01/18 8:20 AM	08/03/18 7:24 PM	18017158	Copper	0.8	1.3	ppm
258-5337-A-001A Cafeteria (Left)	08/01/18 8:20 AM	08/03/18 7:24 PM	18017158	Lead	6	15	ppb
258-5337-A-001B Cafeteria (Left)	08/01/18 8:20 AM	08/06/18 11:12 AM	18017169	Copper	1.1	1.3	ppm
258-5337-A-001B Cafeteria (Left)	08/01/18 8:20 AM	08/03/18 7:26 PM	18017169	Lead	1	15	ppb
258-5337-B-001A Cafeteria (Right)	08/01/18 8:26 AM	08/06/18 11:15 AM	18017157	Copper	1.0	1.3	ppm
258-5337-B-001A Cafeteria (Right)	08/01/18 8:26 AM	08/03/18 7:29 PM	18017157	Lead	1	15	ppb
258-5337-B-001B Cafeteria (Right)	08/01/18 8:26 AM	08/06/18 12:32 PM	18017162	Copper	1.1	1.3	ppm
258-5337-B-001B Cafeteria (Right)	08/01/18 8:26 AM	08/03/18 7:31 PM	18017162	Lead	<1	15	ppb
258-5380-A-001A Outside Main Office	08/01/18 8:34 AM	08/03/18 7:34 PM	18017163	Copper	0.8	1.3	ppm
258-5380-A-001A Outside Main Office	08/01/18 8:34 AM	08/03/18 7:34 PM	18017163	Lead	5	15	ppb
258-5380-A-001B Outside Main Office	08/01/18 8:34 AM	08/06/18 12:34 PM	18017173	Copper	1.2	1.3	ppm
258-5380-A-001B Outside Main Office	08/01/18 8:34 AM	08/03/18 7:36 PM	18017173	Lead	1	15	ppb
258-5386-A-001A Kitchen Food Prep Faucet	08/01/18 8:49 AM	08/03/18 7:38 PM	18017159	Copper	0.1	1.3	ppm
258-5386-A-001A Kitchen Food Prep Faucet	08/01/18 8:49 AM	08/03/18 7:38 PM	18017159	Lead	1	15	ppb
258-5386-A-001B Kitchen Food Prep Faucet	08/01/18 8:49 AM	08/03/18 7:57 PM	18017164	Copper	<0.1	1.3	ppm
258-5386-A-001B Kitchen Food Prep Faucet	08/01/18 8:49 AM	08/03/18 7:57 PM	18017164	Lead	<1	15	ppb
258-5386-B-001A Kitchen Food Prep Sprayer	08/01/18 8:54 AM	08/03/18 8:00 PM	18017166	Copper	<0.1	1.3	ppm
258-5386-B-001A Kitchen Food Prep Sprayer	08/01/18 8:54 AM	08/03/18 8:00 PM	18017166	Lead	1	15	ppb
258-5386-B-001B Kitchen Food Prep Sprayer	08/01/18 8:54 AM	08/03/18 8:02 PM	18017167	Copper	<0.1	1.3	ppm
258-5386-B-001B Kitchen Food Prep Sprayer	08/01/18 8:54 AM	08/03/18 8:02 PM	18017167	Lead	<1	15	ppb
258-5376-A-001A Drinking Fountain between Bathroom	08/01/18 9:03 AM	08/06/18 12:36 PM	18017176	Copper	1.2	1.3	ppm
258-5376-A-001A Drinking Fountain between Bathroom	08/01/18 9:03 AM	08/03/18 8:05 PM	18017176	Lead	7	15	ppb
258-5376-A-001B Drinking Fountain between Bathroom	08/01/18 9:03 AM	08/06/18 12:37 PM	18017177	Copper	1.2	1.3	ppm
258-5376-A-001B Drinking Fountain between Bathroom	08/01/18 9:03 AM	08/03/18 8:07 PM	18017177	Lead	1	15	ppb
258-5381-A-001A Outside Room 20	08/01/18 9:15 AM	08/03/18 8:09 PM	18017178	Copper	0.1	1.3	ppm
258-5381-A-001A Outside Room 20	08/01/18 9:15 AM	08/03/18 8:09 PM	18017178	Lead	5	15	ppb
258-5381-A-001B Outside Room 20	08/01/18 9:15 AM	08/03/18 8:12 PM	18017179	Copper	<0.1	1.3	ppm
258-5381-A-001B Outside Room 20	08/01/18 9:15 AM	08/03/18 8:12 PM	18017179	Lead	6	15	ppb
258-5378-A-001A Outside Room 20	08/01/18 9:18 AM	08/03/18 8:14 PM	18017180	Copper	0.1	1.3	ppm
258-5378-A-001A Outside Room 20	08/01/18 9:18 AM	08/03/18 8:14 PM	18017180	Lead	3	15	ppb
258-5378-A-001B Outside Room 20	08/01/18 9:18 AM	08/06/18 12:03 PM	18017181	Copper	<0.1	1.3	ppm
258-5378-A-001B Outside Room 20	08/01/18 9:18 AM	08/06/18 12:03 PM	18017181	Lead	1	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.