

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Kelly

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
258-CH5321-N/A-002-A	Room 114	11/3/2018	11/8/2018	A8K0195-31RE1	Copper	2.52	0.0200	1.3	ppm
258-CH5321-N/A-002-A	Room 114	11/3/2018	11/8/2018	A8K0195-31	Lead	122	0.200	15	ppb
258-CH5321-N/A-002-B	Room 114	11/3/2018	11/8/2018	A8K0195-32	Copper	0.538	0.00200	1.3	ppm
258-CH5321-N/A-002-B	Room 114	11/3/2018	11/8/2018	A8K0195-32	Lead	9.73	0.200	15	ppb
258-CH5322-N/A-002-A	Room 123	11/3/2018	11/8/2018	A8K0195-37	Copper	0.0141	0.00200	1.3	ppm
258-CH5322-N/A-002-A	Room 123	11/3/2018	11/8/2018	A8K0195-37	Lead	9.67	0.200	15	ppb
258-CH5322-N/A-002-B	Room 123	11/3/2018	11/8/2018	A8K0195-38	Copper	0.00446	0.00200	1.3	ppm
258-CH5322-N/A-002-B	Room 123	11/3/2018	11/8/2018	A8K0195-38	Lead	1.67	0.200	15	ppb
258-CH5325-N/A-002-A	Room 124	11/3/2018	11/8/2018	A8K0195-39	Copper	0.463	0.00200	1.3	ppm
258-CH5325-N/A-002-A	Room 124	11/3/2018	11/8/2018	A8K0195-39	Lead	25.2	0.200	15	ppb
258-CH5325-N/A-002-B	Room 124	11/3/2018	11/8/2018	A8K0195-40RE1	Copper	0.314	0.00200	1.3	ppm
258-CH5325-N/A-002-B	Room 124	11/3/2018	11/8/2018	A8K0195-40RE1	Lead	4.40	0.200	15	ppb
258-CH5328-N/A-002-A	Room 125	11/3/2018	11/8/2018	A8K0195-41	Copper	0.00997	0.00200	1.3	ppm
258-CH5328-N/A-002-A	Room 125	11/3/2018	11/8/2018	A8K0195-41	Lead	1.22	0.200	15	ppb
258-CH5328-N/A-002-B	Room 125	11/3/2018	11/8/2018	A8K0195-42	Copper	0.00353	0.00200	1.3	ppm
258-CH5328-N/A-002-B	Room 125	11/3/2018	11/8/2018	A8K0195-42	Lead	0.350	0.200	15	ppb

Analyzed by:

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

Page 1 of 6

258-CH5330-N/A-002-A	Hall Bubbler	11/3/2018	11/8/2018	A8K0195-33	Copper	0.587	0.00200	1.3	ppm
258-CH5330-N/A-002-A	Hall Bubbler	11/3/2018	11/8/2018	A8K0195-33	Lead	2.58	0.200	15	ppb
258-CH5330-N/A-002-B	Hall Bubbler	11/3/2018	11/8/2018	A8K0195-34	Copper	0.519	0.00200	1.3	ppm
258-CH5330-N/A-002-B	Hall Bubbler	11/3/2018	11/8/2018	A8K0195-34	Lead	0.326	0.200	15	ppb
258-CH5331-N/A-002-A	Room 126	11/3/2018	11/8/2018	A8K0195-43	Copper	0.429	0.00200	1.3	ppm
258-CH5331-N/A-002-A	Room 126	11/3/2018	11/8/2018	A8K0195-43	Lead	3.30	0.200	15	ppb
258-CH5331-N/A-002-B	Room 126	11/3/2018	11/8/2018	A8K0195-44	Copper	0.543	0.00200	1.3	ppm
258-CH5331-N/A-002-B	Room 126	11/3/2018	11/8/2018	A8K0195-44	Lead	1.74	0.200	15	ppb
258-CH5334-N/A-002-A	Room 127	11/3/2018	11/8/2018	A8K0195-45	Copper	0.144	0.00200	1.3	ppm
258-CH5334-N/A-002-A	Room 127	11/3/2018	11/8/2018	A8K0195-45	Lead	4.40	0.200	15	ppb
258-CH5334-N/A-002-B	Room 127	11/3/2018	11/8/2018	A8K0195-46	Copper	0.208	0.00200	1.3	ppm
258-CH5334-N/A-002-B	Room 127	11/3/2018	11/8/2018	A8K0195-46	Lead	2.32	0.200	15	ppb
258-CH5336-N/A-002-A	Gym Bubbler	11/3/2018	11/8/2018	A8K0195-49RE1	Copper	1.23	0.0100	1.3	ppm
258-CH5336-N/A-002-A	Gym Bubbler	11/3/2018	11/8/2018	A8K0195-49	Lead	3.93	0.200	15	ppb
258-CH5336-N/A-002-B	Gym Bubbler	11/3/2018	11/8/2018	A8K0195-50RE1	Copper	1.52	0.0100	1.3	ppm
258-CH5336-N/A-002-B	Gym Bubbler	11/3/2018	11/8/2018	A8K0195-50	Lead	1.06	0.200	15	ppb
258-CH5345-N/A-002-A	Room 122	11/3/2018	11/8/2018	A8K0195-35	Copper	0.257	0.00200	1.3	ppm
258-CH5345-N/A-002-A	Room 122	11/3/2018	11/8/2018	A8K0195-35	Lead	3.90	0.200	15	ppb
258-CH5345-N/A-002-B	Room 122	11/3/2018	11/8/2018	A8K0195-36	Copper	0.270	0.00200	1.3	ppm
258-CH5345-N/A-002-B	Room 122	11/3/2018	11/8/2018	A8K0195-36	Lead	1.12	0.200	15	ppb

Analyzed by:

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

Page 2 of 6

258-CH5375-N/A-002-A	Music Room	11/3/2018	11/8/2018	A8K0195-47	Copper	0.177	0.00200	1.3	ppm
258-CH5375-N/A-002-A	Music Room	11/3/2018	11/8/2018	A8K0195-47	Lead	15.0	0.200	15	ppb
258-CH5375-N/A-002-B	Music Room	11/3/2018	11/8/2018	A8K0195-48	Copper	0.184	0.00200	1.3	ppm
258-CH5375-N/A-002-B	Music Room	11/3/2018	11/8/2018	A8K0195-48	Lead	11.3	0.200	15	ppb
258-CH5379-N/A-002-A	Room 108	11/3/2018	11/8/2018	A8K0195-11	Copper	0.0140	0.00200	1.3	ppm
258-CH5379-N/A-002-A	Room 108	11/3/2018	11/8/2018	A8K0195-11	Lead	11.5	0.200	15	ppb
258-CH5379-N/A-002-B	Room 108	11/3/2018	11/8/2018	A8K0195-12	Copper	0.00719	0.00200	1.3	ppm
258-CH5379-N/A-002-B	Room 108	11/3/2018	11/8/2018	A8K0195-12	Lead	9.05	0.200	15	ppb
258-CH5382-N/A-002-A	Room 102	11/3/2018	11/8/2018	A8K0195-09	Copper	0.0144	0.00200	1.3	ppm
258-CH5382-N/A-002-A	Room 102	11/3/2018	11/8/2018	A8K0195-09	Lead	7.56	0.200	15	ppb
258-CH5382-N/A-002-B	Room 102	11/3/2018	11/8/2018	A8K0195-10	Copper	0.0112	0.00200	1.3	ppm
258-CH5382-N/A-002-B	Room 102	11/3/2018	11/8/2018	A8K0195-10	Lead	3.74	0.200	15	ppb
258-CH5384-N/A-002-A	Room 29	11/3/2018	11/8/2018	A8K0195-21	Copper	0.0963	0.00200	1.3	ppm
258-CH5384-N/A-002-A	Room 29	11/3/2018	11/8/2018	A8K0195-21	Lead	5.16	0.200	15	ppb
258-CH5384-N/A-002-B	Room 29	11/3/2018	11/8/2018	A8K0195-22	Copper	0.0895	0.00200	1.3	ppm
258-CH5384-N/A-002-B	Room 29	11/3/2018	11/8/2018	A8K0195-22	Lead	3.88	0.200	15	ppb
258-CH5385-N/A-002-A	Room 109	11/3/2018	11/8/2018	A8K0195-07	Copper	0.00915	0.00200	1.3	ppm
258-CH5385-N/A-002-A	Room 109	11/3/2018	11/8/2018	A8K0195-07	Lead	8.88	0.200	15	ppb
258-CH5385-N/A-002-B	Room 109	11/3/2018	11/8/2018	A8K0195-08	Copper	0.00830	0.00200	1.3	ppm
258-CH5385-N/A-002-B	Room 109	11/3/2018	11/8/2018	A8K0195-08	Lead	6.78	0.200	15	ppb

Analyzed by:

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

Page 3 of 6

258-CH5387-N/A-002-A	Room 10	11/3/2018	11/8/2018	A8K0195-23	Copper	0.0956	0.00200	1.3	ppm
258-CH5387-N/A-002-A	Room 10	11/3/2018	11/8/2018	A8K0195-23	Lead	13.0	0.200	15	ppb
258-CH5387-N/A-002-B	Room 10	11/3/2018	11/8/2018	A8K0195-24	Copper	0.0136	0.00200	1.3	ppm
258-CH5387-N/A-002-B	Room 10	11/3/2018	11/8/2018	A8K0195-24	Lead	2.94	0.200	15	ppb
258-CH5388-N/A-002-A	Room 103	11/3/2018	11/8/2018	A8K0195-05	Copper	0.0172	0.00200	1.3	ppm
258-CH5388-N/A-002-A	Room 103	11/3/2018	11/8/2018	A8K0195-05	Lead	12.6	0.200	15	ppb
258-CH5388-N/A-002-B	Room 103	11/3/2018	11/8/2018	A8K0195-06	Copper	0.00880	0.00200	1.3	ppm
258-CH5388-N/A-002-B	Room 103	11/3/2018	11/8/2018	A8K0195-06	Lead	3.01	0.200	15	ppb
258-CH5390-N/A-002-A	Room 106	11/3/2018	11/8/2018	A8K0195-17	Copper	0.00661	0.00200	1.3	ppm
258-CH5390-N/A-002-A	Room 106	11/3/2018	11/8/2018	A8K0195-17	Lead	5.07	0.200	15	ppb
258-CH5390-N/A-002-B	Room 106	11/3/2018	11/8/2018	A8K0195-18	Copper	0.00233	0.00200	1.3	ppm
258-CH5390-N/A-002-B	Room 106	11/3/2018	11/8/2018	A8K0195-18	Lead	1.23	0.200	15	ppb
258-CH5393-N/A-002-A	Room 100	11/3/2018	11/8/2018	A8K0195-19RE1	Copper	1.44	0.0100	1.3	ppm
258-CH5393-N/A-002-A	Room 100	11/3/2018	11/8/2018	A8K0195-19	Lead	14.3	0.200	15	ppb
258-CH5393-N/A-002-B	Room 100	11/3/2018	11/8/2018	A8K0195-20	Copper	0.690	0.00200	1.3	ppm
258-CH5393-N/A-002-B	Room 100	11/3/2018	11/8/2018	A8K0195-20	Lead	3.60	0.200	15	ppb
258-CH5395-N/A-002-A	Room 117	11/3/2018	11/8/2018	A8K0195-25RE1	Copper	10.1	0.100	1.3	ppm
258-CH5395-N/A-002-A	Room 117	11/3/2018	11/8/2018	A8K0195-25	Lead	474	0.200	15	ppb
258-CH5395-N/A-002-B	Room 117	11/3/2018	11/8/2018	A8K0195-26RE1	Copper	1.00	0.0100	1.3	ppm
258-CH5395-N/A-002-B	Room 117	11/3/2018	11/8/2018	A8K0195-26	Lead	21.9	0.200	15	ppb

Analyzed by:

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

Page 4 of 6

258-CH5396-N/A-002-A	Room 107	11/3/2018	11/8/2018	A8K0195-13	Copper	0.278	0.00200	1.3	ppm
258-CH5396-N/A-002-A	Room 107	11/3/2018	11/8/2018	A8K0195-13	Lead	1.99	0.200	15	ppb
258-CH5396-N/A-002-B	Room 107	11/3/2018	11/8/2018	A8K0195-14	Copper	0.356	0.00200	1.3	ppm
258-CH5396-N/A-002-B	Room 107	11/3/2018	11/8/2018	A8K0195-14	Lead	0.706	0.200	15	ppb
258-CH5397-N/A-002-A	Room 111	11/3/2018	11/8/2018	A8K0195-03	Copper	0.00796	0.00200	1.3	ppm
258-CH5397-N/A-002-A	Room 111	11/3/2018	11/8/2018	A8K0195-03	Lead	9.18	0.200	15	ppb
258-CH5397-N/A-002-B	Room 111	11/3/2018	11/8/2018	A8K0195-04	Copper	0.0114	0.00200	1.3	ppm
258-CH5397-N/A-002-B	Room 111	11/3/2018	11/8/2018	A8K0195-04	Lead	18.5	0.200	15	ppb
258-CH5398-N/A-002-A	Room 116	11/3/2018	11/8/2018	A8K0195-27RE1	Copper	3.32	0.0200	1.3	ppm
258-CH5398-N/A-002-A	Room 116	11/3/2018	11/8/2018	A8K0195-27	Lead	55.9	0.200	15	ppb
258-CH5398-N/A-002-B	Room 116	11/3/2018	11/8/2018	A8K0195-28RE1	Copper	1.52	0.0100	1.3	ppm
258-CH5398-N/A-002-B	Room 116	11/3/2018	11/8/2018	A8K0195-28	Lead	39.5	0.200	15	ppb
258-CH5399-N/A-002-A	Room 101	11/3/2018	11/8/2018	A8K0195-15	Copper	0.228	0.00200	1.3	ppm
258-CH5399-N/A-002-A	Room 101	11/3/2018	11/8/2018	A8K0195-15	Lead	3.36	0.200	15	ppb
258-CH5399-N/A-002-B	Room 101	11/3/2018	11/8/2018	A8K0195-16	Copper	0.0165	0.00200	1.3	ppm
258-CH5399-N/A-002-B	Room 101	11/3/2018	11/8/2018	A8K0195-16	Lead	0.371	0.200	15	ppb
258-CH5400-N/A-002-A	Room 105	11/3/2018	11/8/2018	A8K0195-01	Copper	0.0635	0.00200	1.3	ppm
258-CH5400-N/A-002-A	Room 105	11/3/2018	11/8/2018	A8K0195-01	Lead	8.86	0.200	15	ppb
258-CH5400-N/A-002-B	Room 105	11/3/2018	11/8/2018	A8K0195-02	Copper	0.0446	0.00200	1.3	ppm
258-CH5400-N/A-002-B	Room 105	11/3/2018	11/8/2018	A8K0195-02	Lead	6.95	0.200	15	ppb

Analyzed by:

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

Page 5 of 6

258-CH5401-N/A-002-A	Room 115	11/3/2018	11/8/2018	A8K0195-29	Copper	0.287	0.00200	1.3	ppm
258-CH5401-N/A-002-A	Room 115	11/3/2018	11/8/2018	A8K0195-29	Lead	7.09	0.200	15	ppb
258-CH5401-N/A-002-B	Room 115	11/3/2018	11/8/2018	A8K0195-30	Copper	0.588	0.00200	1.3	ppm
258-CH5401-N/A-002-B	Room 115	11/3/2018	11/8/2018	A8K0195-30	Lead	8.21	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

Analyzed by: