

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Kelly Elementary School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level	Units
258-CH5394-N/A-003-A	Classroom 104	3/29/2019	4/9/2019	A9C1067-01	Lead	1.17	0.20	15	ppb
258-CH5391-N/A-003-A	Classroom 110	3/29/2019	4/9/2019	A9C1067-03	Lead	2.22	0.20	15	ppb
258-CH5327-N/A-003-A	Classroom 112	3/29/2019	4/9/2019	A9C1067-05	Lead	8.16	0.20	15	ppb
258-CH5339-N/A-003-A	Girls Locker Room	3/29/2019	4/9/2019	A9C1067-07	Lead	62.20	0.20	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.