

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Kenton Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
168-3096-B-001A Hallway (106) Metal Drinking Fountain	12/12/18 6:07 AM	12/13/18 5:35 PM	18033575	Copper	0.1	1.3	ppm
168-3096-B-001A Hallway (106) Metal Drinking Fountain	12/12/18 6:07 AM	12/13/18 5:35 PM	18033575	Lead	< 1	15	ppb
168-3096-B-001B Hallway (106) Metal Drinking Fountain	12/12/18 6:07 AM	12/13/18 5:38 PM	18033576	Copper	0.2	1.3	ppm
168-3096-B-001B Hallway (106) Metal Drinking Fountain	12/12/18 6:07 AM	12/13/18 5:38 PM	18033576	Lead	< 1	15	ppb
168-3096-A-001A Hallway (106) Bottle Filler	12/12/18 6:09 AM	12/13/18 5:42 PM	18033577	Copper	0.2	1.3	ppm
168-3096-A-001A Hallway (106) Bottle Filler	12/12/18 6:09 AM	12/13/18 5:42 PM	18033577	Lead	< 1	15	ppb
168-3096-A-001B Hallway (106) Bottle Filler	12/12/18 6:09 AM	12/13/18 5:46 PM	18033578	Copper	0.1	1.3	ppm
168-3096-A-001B Hallway (106) Bottle Filler	12/12/18 6:09 AM	12/13/18 5:46 PM	18033578	Lead	< 1	15	ppb
168-3081-N/A-001A Kitchen Food Prep Faucet	12/12/18 6:26 AM	12/13/18 5:12 PM	18033579	Copper	0.1	1.3	ppm
168-3081-N/A-001A Kitchen Food Prep Faucet	12/12/18 6:26 AM	12/13/18 5:12 PM	18033579	Lead	< 1	15	ppb
168-3081-N/A-001B Kitchen Food Prep Faucet	12/12/18 6:26 AM	12/13/18 5:15 PM	18033580	Copper	< 0.1	1.3	ppm
168-3081-N/A-001B Kitchen Food Prep Faucet	12/12/18 6:26 AM	12/13/18 5:15 PM	18033580	Lead	< 1	15	ppb
168-3084-N/A-001A Kitchen Food Prep Faucet	12/12/18 6:27 AM	12/13/18 5:19 PM	18033581	Copper	< 0.1	1.3	ppm
168-3084-N/A-001A Kitchen Food Prep Faucet	12/12/18 6:27 AM	12/13/18 5:19 PM	18033581	Lead	< 1	15	ppb
168-3084-N/A-001B Kitchen Food Prep Faucet	12/12/18 6:27 AM	12/13/18 6:11 PM	18033582	Copper	< 0.1	1.3	ppm
168-3084-N/A-001B Kitchen Food Prep Faucet	12/12/18 6:27 AM	12/13/18 6:11 PM	18033582	Lead	< 1	15	ppb
168-3087-N/A-001A Kitchen Ice Maker	12/12/18 6:34 AM	12/13/18 6:15 PM	18033583	Copper	< 0.1	1.3	ppm
168-3087-N/A-001A Kitchen Ice Maker	12/12/18 6:34 AM	12/13/18 6:15 PM	18033583	Lead	< 1	15	ppb
168-3087-N/A-001B Kitchen Ice Maker	12/12/18 6:34 AM	12/13/18 6:18 PM	18033584	Copper	< 0.1	1.3	ppm
168-3087-N/A-001B Kitchen Ice Maker	12/12/18 6:34 AM	12/13/18 6:18 PM	18033584	Lead	< 1	15	ppb
168-UNK-A-001A Hallway (2-3 Basement) Porcelain Drinking Fountain	12/12/18 6:40 AM	12/13/18 6:22 PM	18033585	Copper	0.5	1.3	ppm
168-UNK-A-001A Hallway (2-3 Basement) Porcelain Drinking Fountain	12/12/18 6:40 AM	12/13/18 6:22 PM	18033585	Lead	8	15	ppb
168-UNK-A-001B Hallway (2-3 Basement) Porcelain Drinking Fountain	12/12/18 6:40 AM	12/13/18 6:25 PM	18033586	Copper	0.4	1.3	ppm
168-UNK-A-001B Hallway (2-3 Basement) Porcelain Drinking Fountain	12/12/18 6:40 AM	12/13/18 6:25 PM	18033586	Lead	2	15	ppb
168-UNK-B-001A Hallway (2-3 Basement) Porcelain Drinking Fountain	12/12/18 6:41 AM	12/13/18 6:29 PM	18033587	Copper	0.4	1.3	ppm
168-UNK-B-001A Hallway (2-3 Basement) Porcelain Drinking Fountain	12/12/18 6:41 AM	12/13/18 6:29 PM	18033587	Lead	3	15	ppb
168-UNK-B-001B Hallway (2-3 Basement) Porcelain Drinking Fountain	12/12/18 6:41 AM	12/13/18 6:33 PM	18033588	Copper	0.3	1.3	ppm
168-UNK-B-001B Hallway (2-3 Basement) Porcelain Drinking Fountain	12/12/18 6:41 AM	12/13/18 6:33 PM	18033588	Lead	< 1	15	ppb
168-3082-A-001A Portable 2 Sink Bubbler	12/12/18 6:49 AM	12/13/18 6:36 PM	18033589	Copper	0.1	1.3	ppm
168-3082-A-001A Portable 2 Sink Bubbler	12/12/18 6:49 AM	12/13/18 6:36 PM	18033589	Lead	6	15	ppb
168-3082-A-001B Portable 2 Sink Bubbler	12/12/18 6:49 AM	12/13/18 6:40 PM	18033590	Copper	< 0.1	1.3	ppm
168-3082-A-001B Portable 2 Sink Bubbler	12/12/18 6:49 AM	12/13/18 6:40 PM	18033590	Lead	3	15	ppb

Analyzed by: Pixis Labs

Reviewed by: TRC Environmental Corporation

*EPA action level for lead is 20 ppb and 1.3 for copper