

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Kenton De La Salle School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
168-DF-3096-A-003-A	Hallway	11/11/2021	11/17/2021	A1K0548-01	Lead	ND	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb