Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Lane Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
263-1308-A-001A Kitchen	08/01/18 9:15 AM	08/02/18 8:17 PM	18016976	Copper	0.1	1.3	ppm
263-1308-A-001A Kitchen	08/01/18 9:15 AM	08/02/18 8:17 PM	18016976	Lead	2	15	ppb
263-1308-A-001B Kitchen	08/01/18 9:15 AM	08/02/18 8:19 PM	18016983	Copper	<0.1	1.3	ppm
263-1308-A-001B Kitchen	08/01/18 9:15 AM	08/02/18 8:19 PM	18016983	Lead	<1	15	ppb
263-1309-A-001A Kitchen	08/01/18 9:16 AM	08/02/18 8:54 PM	18016979	Copper	0.1	1.3	ppm
263-1309-A-001A Kitchen	08/01/18 9:16 AM	08/02/18 8:54 PM	18016979	Lead	1	15	ppb
263-1309-A-001B Kitchen	08/01/18 9:16 AM	08/02/18 8:56 PM	18016985	Copper	0.2	1.3	ppm
263-1309-A-001B Kitchen	08/01/18 9:16 AM	08/02/18 8:56 PM	18016985	Lead	<1	15	ppb
263-1299-A-001A Gymnasium	08/01/18 9:22 AM	08/02/18 8:58 PM	18016978	Copper	0.8	1.3	ppm
263-1299-A-001A Gymnasium	08/01/18 9:22 AM	08/02/18 8:58 PM	18016978	Lead	1	15	ppb
263-1299-A-001B Gymnasium	08/01/18 9:22 AM	08/02/18 9:00 PM	18016987	Copper	0.7	1.3	ppm
263-1299-A-001B Gymnasium	08/01/18 9:22 AM	08/02/18 9:00 PM	18016987	Lead	<1	15	ppb
263-1302-A-001A Gymnasium	08/01/18 9:26 AM	08/02/18 9:03 PM	18016981	Copper	0.6	1.3	ppm
263-1302-A-001A Gymnasium	08/01/18 9:26 AM	08/02/18 9:03 PM	18016981	Lead	2	15	ppb
263-1302-A-001B Gymnasium	08/01/18 9:26 AM	08/03/18 7:55 PM	18016986	Copper	1.1	1.3	ppm
263-1302-A-001B Gymnasium	08/01/18 9:26 AM	08/02/18 9:05 PM	18016986	Lead	1	15	ppb
263-1223A-001A Hallway Near Rm 117	08/01/18 9:32 AM	08/02/18 8:21 PM	18016982	Copper	0.5	1.3	ppm
263-1223A-001A Hallway Near Rm 117	08/01/18 9:32 AM	08/02/18 8:21 PM	18016982	Lead	3	15	ppb
263-1223A-001B Hallway Near Rm 117	08/01/18 9:32 AM	08/02/18 8:23 PM	18016977	Copper	0.8	1.3	ppm
263-1223A-001B Hallway Near Rm 117	08/01/18 9:32 AM	08/02/18 8:23 PM	18016977	Lead	1	15	ppb
263-1218A-001A Hallway Near Rm 169	08/01/18 9:37 AM	08/02/18 8:25 PM	18016989	Copper	<0.1	1.3	ppm
263-1218A-001A Hallway Near Rm 169	08/01/18 9:37 AM	08/02/18 8:25 PM	18016989	Lead	<1	15	ppb
263-1218A-001B Hallway Near Rm 169	08/01/18 9:37 AM	08/02/18 8:28 PM	18016984	Copper	0.4	1.3	ppm
263-1218A-001B Hallway Near Rm 169	08/01/18 9:37 AM	08/02/18 8:28 PM	18016984	Lead	1	15	ppb
263-1219A-001A Hallway Near Storage 197	08/01/18 9:43 AM	08/02/18 8:30 PM	18016980	Copper	<0.1	1.3	ppm
263-1219A-001A Hallway Near Storage 197	08/01/18 9:43 AM	08/02/18 8:30 PM	18016980	Lead	6	15	ppb
263-1219A-001B Hallway Near Storage 197	08/01/18 9:43 AM	08/02/18 8:32 PM	18016988	Copper	<0.1	1.3	ppm
263-1219A-001B Hallway Near Storage 197	08/01/18 9:43 AM	08/02/18 8:32 PM	18016988	Lead	3	15	ppb
263-1301A-001A Hallway Near Kitchen	08/01/18 9:49 AM	08/02/18 9:07 PM	18016990	Copper	0.6	1.3	ppm
263-1301A-001A Hallway Near Kitchen	08/01/18 9:49 AM	08/02/18 9:07 PM	18016990	Lead	1	15	ppb
263-1301A-001B Hallway Near Kitchen	08/01/18 9:49 AM	08/02/18 9:09 PM	18016991	Copper	0.3	1.3	ppm
263-1301A-001B Hallway Near Kitchen	08/01/18 9:49 AM	08/02/18 9:09 PM	18016991	Lead	<1	15	ppb
263-1300A-001A Hallway Near Rm 218	08/01/18 9:56 AM	08/02/18 7:41 PM	18016992	Copper	0.3	1.3	ppm
263-1300A-001A Hallway Near Rm 218	08/01/18 9:56 AM	08/02/18 7:41 PM	18016992	Lead	13	15	ppb
263-1300A-001B Hallway Near Rm 218	08/01/18 9:56 AM	08/02/18 7:44 PM	18016993	Copper	0.4	1.3	ppm
263-1300A-001B Hallway Near Rm 218	08/01/18 9:56 AM	08/02/18 7:44 PM	18016993	Lead	3	15	ppb
263-1300B-001A Hallway Near Rm 218	08/01/18 9:57 AM	08/02/18 7:46 PM	18016994	Copper	0.3	1.3	ppm
263-1300B-001A Hallway Near Rm 218	08/01/18 9:57 AM	08/02/18 7:46 PM	18016994	Lead	3	15	ppb
263-1300B-001B Hallway Near Rm 218	08/01/18 9:57 AM	08/02/18 7:48 PM	18016995	Copper	0.1	1.3	ppm
263-1300B-001B Hallway Near Rm 218	08/01/18 9:57 AM	08/02/18 7:48 PM	18016995	Lead	16	15	ppb
263-1303A-001A Hallway Near Rm 204	08/01/18 10:02 AM	08/02/18 7:50 PM	18016996	Copper	0.1	1.3	ppm
263-1303A-001A Hallway Near Rm 204	08/01/18 10:02 AM	08/02/18 7:50 PM	18016996	Lead	10	15	ppb
263-1303A-001B Hallway Near Rm 204	08/01/18 10:02 AM	08/02/18 7:52 PM	18016997	Copper	<0.1	1.3	ppm
263-1303A-001B Hallway Near Rm 204	08/01/18 10:02 AM	08/02/18 7:52 PM	18016997	Lead	9	15	ppb
263-1303B-001A Hallway Near Rm 204	08/01/18 10:04 AM	08/02/18 8:34 PM	18016998	Copper	<0.1	1.3	ppm
263-1303B-001A Hallway Near Rm 204	08/01/18 10:04 AM	08/02/18 8:34 PM	18016998	Lead	9	15	ppb
263-1303B-001B Hallway Near Rm 204	08/01/18 10:04 AM	08/02/18 8:36 PM	18016999	Copper	<0.1	1.3	ppm
263-1303B-001B Hallway Near Rm 204	08/01/18 10:04 AM	08/02/18 8:36 PM	18016999	Lead	3	15	ppb

Analyzed by: Pixis Labs
Reviewed by: TRC Environmental Corporation

*EPA action level for lead is 20 ppb and 1.3 for copper