

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Laurelhurst Elementary

Sample Identification #		Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
265-3733-N/A-001-A		Bubbler - Cafeteria	8/3/2018	8/3/2018	A8H0086-01	Copper	0.152	0.00200	1.3	ppm
265-3733-N/A-001-A		Bubbler - Cafeteria	8/3/2018	8/3/2018	A8H0086-01	Lead	3.01	0.200	15	ppb
265-3733-N/A-001-B		Bubbler - Cafeteria	8/3/2018	8/3/2018	A8H0086-02	Copper	0.521	0.00200	1.3	ppm
265-3733-N/A-001-B		Bubbler - Cafeteria	8/3/2018	8/3/2018	A8H0086-02	Lead	0.868	0.200	15	ppb
265-3753-N/A-001-A		Food Prep Faucet - Kitchen	8/3/2018	8/3/2018	A8H0086-03	Copper	0.286	0.00200	1.3	ppm
265-3753-N/A-001-A		Food Prep Faucet - Kitchen	8/3/2018	8/3/2018	A8H0086-03	Lead	0.387	0.200	15	ppb
265-3753-N/A-001-B		Food Prep Faucet - Kitchen	8/3/2018	8/3/2018	A8H0086-04	Copper	0.323	0.00200	1.3	ppm
265-3753-N/A-001-B		Food Prep Faucet - Kitchen	8/3/2018	8/3/2018	A8H0086-04	Lead	0.251	0.200	15	ppb
265-3744-A-001-A		Bubbler - To the right of the custodian closet, right of the main office	8/3/2018	8/3/2018	A8H0086-05	Copper	0.0423	0.00200	1.3	ppm
265-3744-A-001-A		Bubbler - To the right of the custodian closet, right of the main office	8/3/2018	8/3/2018	A8H0086-05	Lead	3.61	0.200	15	ppb
265-3744-A-001-B		Bubbler - To the right of the custodian closet, right of the main office	8/3/2018	8/3/2018	A8H0086-06	Copper	0.0380	0.00200	1.3	ppm
265-3744-A-001-B		Bubbler - To the right of the custodian closet, right of the main office	8/3/2018	8/3/2018	A8H0086-06	Lead	0.898	0.200	15	ppb
265-3744-B-001-A		Bubbler - To the right of the custodian closet, right of the main office	8/3/2018	8/3/2018	A8H0086-07	Copper	0.0347	0.00200	1.3	ppm
265-3744-B-001-A		Bubbler - To the right of the custodian closet, right of the main office	8/3/2018	8/3/2018	A8H0086-07	Lead	3.62	0.200	15	ppb
265-3744-B-001-B		Bubbler - To the right of the custodian closet, right of the main office	8/3/2018	8/3/2018	A8H0086-08	Copper	0.0363	0.00200	1.3	ppm
265-3744-B-001-B		Bubbler - To the right of the custodian closet, right of the main office	8/3/2018	8/3/2018	A8H0086-08	Lead	0.990	0.200	15	ppb
265-3747-N/A-001-A		Drinking Fountain (Stainless) - Right of the custodian closet	8/3/2018	8/3/2018	A8H0086-09	Copper	0.366	0.00200	1.3	ppm

265-3747-N/A-001-A	Drinking Fountain (Stainless) - Right of the custodian closet	8/3/2018	8/3/2018	A8H0086-09	Lead	8.66	0.200	15	ppb
265-3747-N/A-001-B	Drinking Fountain (Stainless) - Right of the custodian closet	8/3/2018	8/3/2018	A8H0086-10	Copper	0.129	0.00200	1.3	ppm
265-3747-N/A-001-B	Drinking Fountain (Stainless) - Right of the custodian closet	8/3/2018	8/3/2018	A8H0086-10	Lead	0.996	0.200	15	ppb
265-3741-A-001-A	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-11	Copper	0.626	0.00200	1.3	ppm
265-3741-A-001-A	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-11	Lead	4.71	0.200	15	ppb
265-3741-A-001-B	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-12	Copper	0.275	0.00200	1.3	ppm
265-3741-A-001-B	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-12	Lead	4.14	0.200	15	ppb
265-3741-B-001-A	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-13	Copper	0.597	0.00200	1.3	ppm
265-3741-B-001-A	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-13	Lead	5.15	0.200	15	ppb
265-3741-B-001-B	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-14	Copper	0.396	0.00200	1.3	ppm
265-3741-B-001-B	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-14	Lead	3.15	0.200	15	ppb
265-3738-A-001-A	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-15	Copper	0.192	0.00200	1.3	ppm
265-3738-A-001-A	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-15	Lead	3.37	0.200	15	ppb
265-3738-A-001-B	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-16	Copper	0.0838	0.00200	1.3	ppm
265-3738-A-001-B	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-16	Lead	1.66	0.200	15	ppb
265-3738-B-001-A	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-17	Copper	0.109	0.00200	1.3	ppm
265-3738-B-001-A	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-17	Lead	2.19	0.200	15	ppb
265-3738-B-001-B	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-18	Copper	0.0789	0.00200	1.3	ppm
265-3738-B-001-B	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-18	Lead	1.77	0.200	15	ppb
265-3735-A-001-A	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-19	Copper	0.146	0.00200	1.3	ppm
265-3735-A-001-A	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-19	Lead	2.26	0.200	15	ppb
265-3735-A-001-B	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-20	Copper	0.0894	0.00200	1.3	ppm
265-3735-A-001-B	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-20	Lead	2.23	0.200	15	ppb
265-3735-B-001-A	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-21	Copper	0.120	0.00200	1.3	ppm
265-3735-B-001-A	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-21	Lead	2.69	0.200	15	ppb
265-3735-B-001-B	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-22	Copper	0.103	0.00200	1.3	ppm

265-3735-B-001-B	Bubbler - Right of the fan room, left of the main office	8/3/2018	8/3/2018	A8H0086-22	Lead	2.04	0.200	15	ppb
265-3736-N/A-001-A	Bubbler - Gym	8/3/2018	8/3/2018	A8H0086-23	Copper	0.00549	0.00200	1.3	ppm
265-3736-N/A-001-A	Bubbler - Gym	8/3/2018	8/3/2018	A8H0086-23	Lead	8.07	0.200	15	ppb
265-3736-N/A-001-B	Bubbler - Gym	8/3/2018	8/7/2018	A8H0086-24	Copper	0.00336	0.00200	1.3	ppm
265-3736-N/A-001-B	Bubbler - Gym	8/3/2018	8/7/2018	A8H0086-24	Lead	7.74	0.200	15	ppb
265-3745-A-001-A	Bubbler - Across from 17A	8/3/2018	8/7/2018	A8H0086-25	Copper	0.0369	0.00200	1.3	ppm
265-3745-A-001-A	Bubbler - Across from 17A	8/3/2018	8/7/2018	A8H0086-25	Lead	9.46	0.200	15	ppb
265-3745-A-001-B	Bubbler - Across from 17A	8/3/2018	8/7/2018	A8H0086-26	Copper	0.0451	0.00200	1.3	ppm
265-3745-A-001-B	Bubbler - Across from 17A	8/3/2018	8/7/2018	A8H0086-26	Lead	1.42	0.200	15	ppb
265-3745-B-001-A	Bubbler - Across from 17A	8/3/2018	8/7/2018	A8H0086-27	Copper	0.0418	0.00200	1.3	ppm
265-3745-B-001-A	Bubbler - Across from 17A	8/3/2018	8/7/2018	A8H0086-27	Lead	11.4	0.200	15	ppb
265-3745-B-001-B	Bubbler - Across from 17A	8/3/2018	8/7/2018	A8H0086-28	Copper	0.0430	0.00200	1.3	ppm
265-3745-B-001-B	Bubbler - Across from 17A	8/3/2018	8/7/2018	A8H0086-28	Lead	1.36	0.200	15	ppb