

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
2nd Site Visit - Laurelhurst Elementary

Sample Identification #	Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
265-3739-NA-001-A	Drinking Fountain (Porcelain) - Faculty Room	11/8/2018	11/9/2018	A8K0265-01	Copper	0.0319	0.00200	1.3	ppm
265-3739-NA-001-A	Drinking Fountain (Porcelain) - Faculty Room	11/8/2018	11/9/2018	A8K0265-01	Lead	19.0	0.200	15	ppb
265-3739-NA-001-B	Drinking Fountain (Porcelain) - Faculty Room	11/8/2018	11/9/2018	A8K0265-02	Copper	0.0260	0.00200	1.3	ppm
265-3739-NA-001-B	Drinking Fountain (Porcelain) - Faculty Room	11/8/2018	11/9/2018	A8K0265-02	Lead	7.95	0.200	15	ppb
265-3701-NA-001-A	Drinking Fountain (Porcelain) - Classroom 114	11/8/2018	11/9/2018	A8K0265-03RE1	Copper	0.00547	0.00200	1.3	ppm
265-3701-NA-001-A	Drinking Fountain (Porcelain) - Classroom 114	11/8/2018	11/9/2018	A8K0265-03	Lead	4.99	0.200	15	ppb
265-3701-NA-001-B	Drinking Fountain (Porcelain) - Classroom 114	11/8/2018	11/9/2018	A8K0265-04	Copper	0.00203	0.00200	1.3	ppm
265-3701-NA-001-B	Drinking Fountain (Porcelain) - Classroom 114	11/8/2018	11/9/2018	A8K0265-04	Lead	2.11	0.200	15	ppb
265-3704-NA-001-A	Sink Bubbler - Classroom 115	11/8/2018	#####	A8K0265-05RE1	Copper	1.62	0.0100	1.3	ppm
265-3704-NA-001-A	Sink Bubbler - Classroom 115	11/8/2018	11/9/2018	A8K0265-05	Lead	9.37	0.200	15	ppb
265-3704-NA-001-B	Sink Bubbler - Classroom 115	11/8/2018	11/9/2018	A8K0265-06	Copper	0.0255	0.00200	1.3	ppm
265-3704-NA-001-B	Sink Bubbler - Classroom 115	11/8/2018	11/9/2018	A8K0265-06	Lead	3.42	0.200	15	ppb
265-3707-NA-001-A	Sink Bubbler - Classroom 116	11/8/2018	11/9/2018	A8K0265-07	Copper	0.189	0.00200	1.3	ppm
265-3707-NA-001-A	Sink Bubbler - Classroom 116	11/8/2018	11/9/2018	A8K0265-07	Lead	13.9	0.200	15	ppb
265-3707-NA-001-B	Sink Bubbler - Classroom 116	11/8/2018	11/9/2018	A8K0265-08	Copper	0.00979	0.00200	1.3	ppm
265-3707-NA-001-B	Sink Bubbler - Classroom 116	11/8/2018	11/9/2018	A8K0265-08	Lead	2.04	0.200	15	ppb
265-3748-NA-001-A	Drinking Fountain (Porcelain) - Classroom 111	11/8/2018	#####	A8K0265-09	Copper	0.00966	0.00200	1.3	ppm
265-3748-NA-001-A	Drinking Fountain (Porcelain) - Classroom 111	11/8/2018	#####	A8K0265-09	Lead	2.13	0.200	15	ppb
265-3748-NA-001-B	Drinking Fountain (Porcelain) - Classroom 111	11/8/2018	#####	A8K0265-10	Copper	0.00438	0.00200	1.3	ppm
265-3748-NA-001-B	Drinking Fountain (Porcelain) - Classroom 111	11/8/2018	#####	A8K0265-10	Lead	2.12	0.200	15	ppb
265-3751-NA-001-A	Drinking Fountain (Porcelain) - Classroom 112	11/8/2018	11/9/2018	A8K0265-11	Copper	0.00760	0.00200	1.3	ppm
265-3751-NA-001-A	Drinking Fountain (Porcelain) - Classroom 112	11/8/2018	11/9/2018	A8K0265-11	Lead	7.62	0.200	15	ppb
265-3751-NA-001-B	Drinking Fountain (Porcelain) - Classroom 112	11/8/2018	#####	A8K0265-12	Copper	0.00323	0.00200	1.3	ppm
265-3751-NA-001-B	Drinking Fountain (Porcelain) - Classroom 112	11/8/2018	#####	A8K0265-12	Lead	1.84	0.200	15	ppb
265-3754-NA-001-A	Drinking Fountain (Porcelain) - Classroom 113	11/8/2018	11/9/2018	A8K0265-13	Copper	0.0622	0.00200	1.3	ppm

265-3754-NA-001-A	Drinking Fountain (Porcelain) - Classroom 113	11/8/2018	11/9/2018	A8K0265-13	Lead	42.6	0.200	15	ppb
265-3754-NA-001-B	Drinking Fountain (Porcelain) - Classroom 113	11/8/2018	11/9/2018	A8K0265-14	Copper	0.0380	0.00200	1.3	ppm
265-3754-NA-001-B	Drinking Fountain (Porcelain) - Classroom 113	11/8/2018	11/9/2018	A8K0265-14	Lead	27.3	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.