

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Jason Lee Elementary

Sample Identification #	Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
264-3768-N/A-001-A	Classroom Sink Bubbler - Classroom 100	7/27/2018	7/31/2018	A8G0752-01	Copper	0.296	0.00200	1.3	ppm
264-3768-N/A-001-A	Classroom Sink Bubbler - Classroom 100	7/27/2018	7/31/2018	A8G0752-01	Lead	28.0	0.200	15	ppb
264-3768-N/A-001-B	Classroom Sink Bubbler - Classroom 100	7/27/2018	7/31/2018	A8G0752-02	Copper	0.0845	0.00200	1.3	ppm
264-3768-N/A-001-B	Classroom Sink Bubbler - Classroom 100	7/27/2018	7/31/2018	A8G0752-02	Lead	11.3	0.200	15	ppb
264-3774-N/A-001-A	Classroom Sink Bubbler - Classroom 101	7/27/2018	8/1/2018	A8G0752-03RE1	Copper	2.06	0.0200	1.3	ppm
264-3774-N/A-001-A	Classroom Sink Bubbler - Classroom 101	7/27/2018	7/31/2018	A8G0752-03	Lead	213	0.200	15	ppb
264-3774-N/A-001-B	Classroom Sink Bubbler - Classroom 101	7/27/2018	7/31/2018	A8G0752-04	Copper	0.897	0.00200	1.3	ppm
264-3774-N/A-001-B	Classroom Sink Bubbler - Classroom 101	7/27/2018	7/31/2018	A8G0752-04	Lead	30.1	0.200	15	ppb
264-3756-N/A-001-A	Classroom Sink Bubbler - Classroom 105	7/27/2018	7/31/2018	A8G0752-05	Copper	0.801	0.00200	1.3	ppm
264-3756-N/A-001-A	Classroom Sink Bubbler - Classroom 105	7/27/2018	7/31/2018	A8G0752-05	Lead	23.2	0.200	15	ppb
264-3756-N/A-001-B	Classroom Sink Bubbler - Classroom 105	7/27/2018	8/1/2018	A8G0752-06RE2	Copper	1.10	0.0100	1.3	ppm
264-3756-N/A-001-B	Classroom Sink Bubbler - Classroom 105	7/27/2018	7/31/2018	A8G0752-06	Lead	2.80	0.200	15	ppb
264-3776-N/A-001-A	Classroom Sink Bubbler - Classroom 109	7/27/2018	8/1/2018	A8G0752-07RE1	Copper	0.986	0.0100	1.3	ppm
264-3776-N/A-001-A	Classroom Sink Bubbler - Classroom 109	7/27/2018	7/31/2018	A8G0752-07	Lead	13.0	0.200	15	ppb
264-3776-N/A-001-B	Classroom Sink Bubbler - Classroom 109	7/27/2018	7/31/2018	A8G0752-08	Copper	0.867	0.00200	1.3	ppm
264-3776-N/A-001-B	Classroom Sink Bubbler - Classroom 109	7/27/2018	7/31/2018	A8G0752-08	Lead	2.89	0.200	15	ppb
264-3765-N/A-001-A	Classroom Sink Bubbler - Classroom 100A	7/27/2018	8/1/2018	A8G0752-09RE1	Copper	0.986	0.0100	1.3	ppm
264-3765-N/A-001-A	Classroom Sink Bubbler - Classroom 100A	7/27/2018	7/31/2018	A8G0752-09	Lead	4.23	0.200	15	ppb
264-3765-N/A-001-B	Classroom Sink Bubbler - Classroom 100A	7/27/2018	7/31/2018	A8G0752-10	Copper	0.878	0.00200	1.3	ppm
264-3765-N/A-001-B	Classroom Sink Bubbler - Classroom 100A	7/27/2018	7/31/2018	A8G0752-10	Lead	1.16	0.200	15	ppb
264-3777-N/A-001-A	Classroom Sink Bubbler - Classroom 101A	7/27/2018	7/31/2018	A8G0752-11	Copper	0.856	0.00200	1.3	ppm
264-3777-N/A-001-A	Classroom Sink Bubbler - Classroom 101A	7/27/2018	7/31/2018	A8G0752-11	Lead	16.2	0.200	15	ppb
264-3777-N/A-001-B	Classroom Sink Bubbler - Classroom 101A	7/27/2018	7/31/2018	A8G0752-12	Copper	0.333	0.00200	1.3	ppm

264-3777-N/A-001-B	Classroom Sink Bubblers - Classroom 101A	7/27/2018	7/31/2018	A8G0752-12	Lead	8.13	0.200	15	ppb
264-3780-N/A-001-A	Classroom Sink Bubblers - Classroom 102	7/27/2018	8/1/2018	A8G0752-13RE1	Copper	1.05	0.0100	1.3	ppm
264-3780-N/A-001-A	Classroom Sink Bubblers - Classroom 102	7/27/2018	7/31/2018	A8G0752-13	Lead	13.3	0.200	15	ppb
264-3780-N/A-001-B	Classroom Sink Bubblers - Classroom 102	7/27/2018	8/1/2018	A8G0752-14RE1	Copper	1.08	0.0100	1.3	ppm
264-3780-N/A-001-B	Classroom Sink Bubblers - Classroom 102	7/27/2018	7/31/2018	A8G0752-14	Lead	2.78	0.200	15	ppb
264-3757-N/A-001-A	Classroom Sink Bubblers - Classroom 104	7/27/2018	7/31/2018	A8G0752-15	Copper	0.00600	0.00200	1.3	ppm
264-3757-N/A-001-A	Classroom Sink Bubblers - Classroom 104	7/27/2018	7/31/2018	A8G0752-15	Lead	4.03	0.200	15	ppb
264-3757-N/A-001-B	Classroom Sink Bubblers - Classroom 104	7/27/2018	7/31/2018	A8G0752-16	Copper	0.00205	0.00200	1.3	ppm
264-3757-N/A-001-B	Classroom Sink Bubblers - Classroom 104	7/27/2018	7/31/2018	A8G0752-16	Lead	0.447	0.200	15	ppb
264-3760-N/A-001-A	Classroom Sink Bubblers - Classroom 106	7/27/2018	7/31/2018	A8G0752-17	Copper	0.968	0.00200	1.3	ppm
264-3760-N/A-001-A	Classroom Sink Bubblers - Classroom 106	7/27/2018	7/31/2018	A8G0752-17	Lead	6.10	0.200	15	ppb
264-3760-N/A-001-B	Classroom Sink Bubblers - Classroom 106	7/27/2018	7/31/2018	A8G0752-18	Copper	0.947	0.00200	1.3	ppm
264-3760-N/A-001-B	Classroom Sink Bubblers - Classroom 106	7/27/2018	7/31/2018	A8G0752-18	Lead	2.20	0.200	15	ppb
264-3772-N/A-001-A	Classroom Sink Bubblers - Classroom 108	7/27/2018	8/1/2018	A8G0752-19RE1	Copper	1.03	0.0100	1.3	ppm
264-3772-N/A-001-A	Classroom Sink Bubblers - Classroom 108	7/27/2018	7/31/2018	A8G0752-19	Lead	10.1	0.200	15	ppb
264-3772-N/A-001-B	Classroom Sink Bubblers - Classroom 108	7/27/2018	7/31/2018	A8G0752-20	Copper	0.606	0.00200	1.3	ppm
264-3772-N/A-001-B	Classroom Sink Bubblers - Classroom 108	7/27/2018	7/31/2018	A8G0752-20	Lead	2.26	0.200	15	ppb
264-3778-N/A-001-A	Sink (Food Prep) - Faculty	7/27/2018	7/31/2018	A8G0752-21	Copper	0.535	0.00200	1.3	ppm
264-3778-N/A-001-A	Sink (Food Prep) - Faculty	7/27/2018	7/31/2018	A8G0752-21	Lead	1.46	0.200	15	ppb
264-3778-N/A-001-B	Sink (Food Prep) - Faculty	7/27/2018	7/31/2018	A8G0752-22	Copper	0.309	0.00200	1.3	ppm
264-3778-N/A-001-B	Sink (Food Prep) - Faculty	7/27/2018	7/31/2018	A8G0752-22	Lead	0.639	0.200	15	ppb
264-3796-N/A-001-A	Classroom Sink Bubblers - Classroom 117	7/27/2018	8/1/2018	A8G0752-23RE1	Copper	1.06	0.0100	1.3	ppm
264-3796-N/A-001-A	Classroom Sink Bubblers - Classroom 117	7/27/2018	7/31/2018	A8G0752-23	Lead	23.8	0.200	15	ppb
264-3796-N/A-001-B	Classroom Sink Bubblers - Classroom 117	7/27/2018	8/1/2018	A8G0752-24RE1	Copper	1.21	0.0100	1.3	ppm
264-3796-N/A-001-B	Classroom Sink Bubblers - Classroom 117	7/27/2018	7/31/2018	A8G0752-24	Lead	6.04	0.200	15	ppb
264-3761-N/A-001-A	Classroom Sink Bubblers - Classroom 121	7/27/2018	8/1/2018	A8G0752-25RE1	Copper	1.09	0.0100	1.3	ppm
264-3761-N/A-001-A	Classroom Sink Bubblers - Classroom 121	7/27/2018	7/31/2018	A8G0752-25	Lead	44.3	0.200	15	ppb
264-3761-N/A-001-B	Classroom Sink Bubblers - Classroom 121	7/27/2018	8/1/2018	A8G0752-26RE1	Copper	1.24	0.0100	1.3	ppm

264-3761-N/A-001-B	Classroom Sink Bubblers - Classroom 121	7/27/2018	7/31/2018	A8G0752-26	Lead	7.93	0.200	15	ppb
264-3758-N/A-001-A	Classroom Sink Bubblers - Classroom 123	7/27/2018	8/3/2018	A8G0752-27	Copper	0.274	0.00200	1.3	ppm
264-3758-N/A-001-A	Classroom Sink Bubblers - Classroom 123	7/27/2018	8/3/2018	A8G0752-27	Lead	9.69	0.200	15	ppb
264-3758-N/A-001-B	Classroom Sink Bubblers - Classroom 123	7/27/2018	7/31/2018	A8G0752-28	Copper	0.165	0.200	1.3	ppm
264-3758-N/A-001-B	Classroom Sink Bubblers - Classroom 123	7/27/2018	7/31/2018	A8G0752-28	Lead	3.27	0.00200	15	ppb
264-3808-N/A-001-A	Classroom Sink Bubblers - Classroom 120	7/27/2018	7/31/2018	A8G0752-29	Copper	0.0171	0.200	1.3	ppm
264-3808-N/A-001-A	Classroom Sink Bubblers - Classroom 120	7/27/2018	7/31/2018	A8G0752-29	Lead	5.35	0.00200	15	ppb
264-3808-N/A-001-B	Classroom Sink Bubblers - Classroom 120	7/27/2018	7/31/2018	A8G0752-30	Copper	0.00363	0.200	1.3	ppm
264-3808-N/A-001-B	Classroom Sink Bubblers - Classroom 120	7/27/2018	7/31/2018	A8G0752-30	Lead	1.00	0.00200	15	ppb
264-3802-N/A-001-A	Classroom Sink Bubblers - Classroom 118	7/27/2018	7/31/2018	A8G0752-31RE1	Copper	1.21	0.200	1.3	ppm
264-3802-N/A-001-A	Classroom Sink Bubblers - Classroom 118	7/27/2018	8/1/2018	A8G0752-31	Lead	60.6	0.0100	15	ppb
264-3802-N/A-001-B	Classroom Sink Bubblers - Classroom 118	7/27/2018	7/31/2018	A8G0752-32RE1	Copper	1.23	0.200	1.3	ppm
264-3802-N/A-001-B	Classroom Sink Bubblers - Classroom 118	7/27/2018	8/1/2018	A8G0752-32	Lead	27.5	0.0100	15	ppb
264-3799-N/A-001-A	Classroom Sink Bubblers - Classroom 116	7/27/2018	7/31/2018	A8G0752-33	Copper	0.0392	0.200	1.3	ppm
264-3799-N/A-001-A	Classroom Sink Bubblers - Classroom 116	7/27/2018	7/31/2018	A8G0752-33	Lead	9.11	0.00200	15	ppb
264-3799-N/A-001-B	Classroom Sink Bubblers - Classroom 116	7/27/2018	7/31/2018	A8G0752-34	Copper	0.0022	0.200	1.3	ppm
264-3799-N/A-001-B	Classroom Sink Bubblers - Classroom 116	7/27/2018	7/31/2018	A8G0752-34	Lead	1.76	0.00200	15	ppb
264-3790-N/A-001-A	Classroom Sink Bubblers - Classroom 110	7/27/2018	7/31/2018	A8G0752-35	Copper	0.712	0.200	1.3	ppm
264-3790-N/A-001-A	Classroom Sink Bubblers - Classroom 110	7/27/2018	7/31/2018	A8G0752-35	Lead	22.7	0.00200	15	ppb
264-3790-N/A-001-B	Classroom Sink Bubblers - Classroom 110	7/27/2018	7/31/2018	A8G0752-36RE1	Copper	1.49	0.200	1.3	ppm
264-3790-N/A-001-B	Classroom Sink Bubblers - Classroom 110	7/27/2018	8/1/2018	A8G0752-36	Lead	5.15	0.0100	15	ppb
264-3787-N/A-001-A	Classroom Sink Bubblers - Classroom 110	7/27/2018	7/31/2018	A8G0752-37RE1	Copper	0.999	0.200	1.3	ppm
264-3787-N/A-001-A	Classroom Sink Bubblers - Classroom 110	7/27/2018	8/1/2018	A8G0752-37	Lead	140	0.0100	15	ppb
264-3787-N/A-001-B	Classroom Sink Bubblers - Classroom 110	7/27/2018	7/31/2018	A8G0752-38RE1	Copper	1.36	0.200	1.3	ppm
264-3787-N/A-001-B	Classroom Sink Bubblers - Classroom 110	7/27/2018	8/1/2018	A8G0752-38	Lead	14.6	0.0100	15	ppb
264-3755-N/A-001-A	Classroom Sink Bubblers - Classroom 122	7/27/2018	7/31/2018	A8G0752-39	Copper	0.0153	0.200	1.3	ppm
264-3755-N/A-001-A	Classroom Sink Bubblers - Classroom 122	7/27/2018	7/31/2018	A8G0752-39	Lead	5.57	0.00200	15	ppb
264-3755-N/A-001-B	Classroom Sink Bubblers - Classroom 122	7/27/2018	7/31/2018	A8G0752-40	Copper	0.00551	0.200	1.3	ppm

264-3755-N/A-001-B	Classroom Sink Bubbler - Classroom 122	7/27/2018	7/31/2018	A8G0752-40	Lead	0.744	0.00200	15	ppb
--------------------	--	-----------	-----------	------------	------	-------	---------	----	-----

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.