

**Portland Public Schools  
Lead Water Sampling Results  
Initial Flush Sample Data  
Jason Lee Elementary School - Test 4**

| Sample Identification # | Location      | Date/Time Collected | Date Analyzed | Lab ID     | Analyte | Results | Detection Limit | PPS Action Level* | Units |
|-------------------------|---------------|---------------------|---------------|------------|---------|---------|-----------------|-------------------|-------|
| 264-CH3770-N/A-004-A    | Gym           | 4/25/2019           | 5/8/2019      | A9D0958-01 | Lead    | 0.531   | 0.20            | 15                | ppb   |
| 264-CH3805-N/A-004-A    | Hallway (121) | 4/25/2019           | 5/6/2019      | A9D0958-02 | Lead    | 1.5     | 0.20            | 15                | ppb   |
| 264-CHR115-N/A-004-A    | Staffroom 115 | 4/25/2019           | 5/8/2019      | A9D0958-03 | Lead    | 2.31    | 0.20            | 15                | ppb   |