

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Lent K-8 School - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
266-CH5257-N/A-004-A	Hallway Office	5/2/2019	5/14/2019	A9E0109-01	Lead	3.28	0.20	15	ppb
266-CH5306-N/A-004-A	Cafeteria	5/2/2019	5/14/2019	A9E0109-02	Lead	13.3	0.20	15	ppb
266-CH5307-N/A-004-A	Classroom 145	5/2/2019	5/14/2019	A9E0109-03	Lead	16.60	0.20	15	ppb
266-CH5245-N/A-004-A	Classroom 120	5/2/2019	5/14/2019	A9E0109-04	Lead	2.52	0.20	15	ppb
266-CH5256-N/A-004-A	Classroom 121	5/2/2019	5/14/2019	A9E0109-05	Lead	10.1	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.