

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Lewis Elementary

Sample Identification #	Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
267-1059-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 4	8/29/2018	9/4/2018	A8H0819-01	Copper	0.685	0.00200	1.3	ppm
267-1059-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 4	8/29/2018	9/4/2018	A8H0819-01	Lead	3.88	0.200	15	ppb
267-1059-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 4	8/29/2018	9/4/2018	A8H0819-02	Copper	0.301	0.00200	1.3	ppm
267-1059-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 4	8/29/2018	9/4/2018	A8H0819-02	Lead	0.963	0.200	15	ppb
267-1055-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 3	8/29/2018	9/4/2018	A8H0819-03	Copper	0.707	0.00200	1.3	ppm
267-1055-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 3	8/29/2018	9/4/2018	A8H0819-03	Lead	7.31	0.200	15	ppb
267-1055-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 3	8/29/2018	9/4/2018	A8H0819-04	Copper	0.358	0.00200	1.3	ppm
267-1055-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 3	8/29/2018	9/4/2018	A8H0819-04	Lead	0.707	0.200	15	ppb
267-1056-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 6	8/29/2018	9/5/2018	A8H0819-05RE2	Copper	2.27	0.0200	1.3	ppm
267-1056-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 6	8/29/2018	9/4/2018	A8H0819-05	Lead	9.84	0.200	15	ppb
267-1056-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 6	8/29/2018	9/4/2018	A8H0819-06	Copper	0.546	0.00200	1.3	ppm
267-1056-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 6	8/29/2018	9/4/2018	A8H0819-06	Lead	1.41	0.200	15	ppb
267-1041-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 8	8/29/2018	9/5/2018	A8H0819-07RE2	Copper	1.98	0.0200	1.3	ppm
267-1041-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 8	8/29/2018	9/4/2018	A8H0819-07	Lead	18.1	0.200	15	ppb
267-1041-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 8	8/29/2018	9/4/2018	A8H0819-08	Copper	0.405	0.00200	1.3	ppm
267-1041-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 8	8/29/2018	9/4/2018	A8H0819-08	Lead	3.13	0.200	15	ppb
267-1046-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 5	8/29/2018	9/4/2018	A8H0819-09	Copper	0.00484	0.00200	1.3	ppm
267-1046-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 5	8/29/2018	9/4/2018	A8H0819-09	Lead	3.08	0.200	15	ppb
267-1046-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 5	8/29/2018	9/4/2018	A8H0819-10	Copper	0.00508	0.00200	1.3	ppm
267-1046-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 5	8/29/2018	9/4/2018	A8H0819-10	Lead	0.546	0.200	15	ppb
267-1049-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 10	8/29/2018	9/5/2018	A8H0819-11RE2	Copper	1.62	0.0200	1.3	ppm
267-1049-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 10	8/29/2018	9/4/2018	A8H0819-11	Lead	4.47	0.200	15	ppb
267-1049-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 10	8/29/2018	9/4/2018	A8H0819-12	Copper	0.300	0.00200	1.3	ppm
267-1049-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 10	8/29/2018	9/4/2018	A8H0819-12	Lead	1.11	0.200	15	ppb
267-1052-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 7	8/29/2018	9/4/2018	A8H0819-13	Copper	0.442	0.00200	1.3	ppm

267-1052-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 7	8/29/2018	9/4/2018	A8H0819-13	Lead	3.78	0.200	15	ppb
267-1052-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 7	8/29/2018	9/4/2018	A8H0819-14	Copper	0.459	0.00200	1.3	ppm
267-1052-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 7	8/29/2018	9/4/2018	A8H0819-14	Lead	0.897	0.200	15	ppb
267-1044-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 12	8/29/2018	9/4/2018	A8H0819-15	Copper	0.600	0.00200	1.3	ppm
267-1044-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 12	8/29/2018	9/4/2018	A8H0819-15	Lead	10.4	0.200	15	ppb
267-1044-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 12	8/29/2018	9/4/2018	A8H0819-16	Copper	0.220	0.00200	1.3	ppm
267-1044-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 12	8/29/2018	9/4/2018	A8H0819-16	Lead	3.07	0.200	15	ppb
267-1050-N/A-001-A	Classroom Sink Bubbler - Classroom 13	8/29/2018	9/4/2018	A8H0819-17	Copper	0.590	0.00200	1.3	ppm
267-1050-N/A-001-A	Classroom Sink Bubbler - Classroom 13	8/29/2018	9/4/2018	A8H0819-17	Lead	24.5	0.200	15	ppb
267-1050-N/A-001-B	Classroom Sink Bubbler - Classroom 13	8/29/2018	9/4/2018	A8H0819-18	Copper	0.476	0.00200	1.3	ppm
267-1050-N/A-001-B	Classroom Sink Bubbler - Classroom 13	8/29/2018	9/4/2018	A8H0819-18	Lead	1.13	0.200	15	ppb
267-1079-N/A-001-A	Classroom Sink Bubbler - Classroom 15	8/29/2018	9/4/2018	A8H0819-19	Copper	0.132	0.00200	1.3	ppm
267-1079-N/A-001-A	Classroom Sink Bubbler - Classroom 15	8/29/2018	9/4/2018	A8H0819-19	Lead	3.25	0.200	15	ppb
267-1079-N/A-001-B	Classroom Sink Bubbler - Classroom 15	8/29/2018	9/4/2018	A8H0819-20	Copper	0.209	0.00200	1.3	ppm
267-1079-N/A-001-B	Classroom Sink Bubbler - Classroom 15	8/29/2018	9/4/2018	A8H0819-20	Lead	2.21	0.200	15	ppb
267-1057-N/A-001-A	Classroom Sink Bubbler - Classroom 16	8/29/2018	9/4/2018	A8H0819-21	Copper	0.237	0.00200	1.3	ppm
267-1057-N/A-001-A	Classroom Sink Bubbler - Classroom 16	8/29/2018	9/4/2018	A8H0819-21	Lead	13.7	0.200	15	ppb
267-1057-N/A-001-B	Classroom Sink Bubbler - Classroom 16	8/29/2018	9/4/2018	A8H0819-22	Copper	0.451	0.00200	1.3	ppm
267-1057-N/A-001-B	Classroom Sink Bubbler - Classroom 16	8/29/2018	9/4/2018	A8H0819-22	Lead	6.83	0.200	15	ppb
267-1060-N/A-001-A	Classroom Sink Bubbler - Classroom 17	8/29/2018	9/4/2018	A8H0819-23	Copper	0.447	0.00200	1.3	ppm
267-1060-N/A-001-A	Classroom Sink Bubbler - Classroom 17	8/29/2018	9/4/2018	A8H0819-23	Lead	6.27	0.200	15	ppb
267-1060-N/A-001-B	Classroom Sink Bubbler - Classroom 17	8/29/2018	9/4/2018	A8H0819-24	Copper	0.367	0.00200	1.3	ppm
267-1060-N/A-001-B	Classroom Sink Bubbler - Classroom 17	8/29/2018	9/4/2018	A8H0819-24	Lead	1.47	0.200	15	ppb
267-1063-N/A-001-A	Classroom Sink Bubbler - Classroom 18	8/29/2018	9/4/2018	A8H0819-25	Copper	0.142	0.00200	1.3	ppm
267-1063-N/A-001-A	Classroom Sink Bubbler - Classroom 18	8/29/2018	9/4/2018	A8H0819-25	Lead	1.83	0.200	15	ppb
267-1063-N/A-001-B	Classroom Sink Bubbler - Classroom 18	8/29/2018	9/4/2018	A8H0819-26	Copper	0.274	0.00200	1.3	ppm
267-1063-N/A-001-B	Classroom Sink Bubbler - Classroom 18	8/29/2018	9/4/2018	A8H0819-26	Lead	0.528	0.200	15	ppb
267-1070-A-001-A	Sink (Food Prep) - Kitchen	8/29/2018	9/4/2018	A8H0819-27	Copper	0.206	0.00200	1.3	ppm
267-1070-A-001-A	Sink (Food Prep) - Kitchen	8/29/2018	9/4/2018	A8H0819-27	Lead	0.597	0.200	15	ppb

267-1070-A-001-B	Sink (Food Prep) - Kitchen	8/29/2018	9/4/2018	A8H0819-28	Copper	0.281	0.00200	1.3	ppm
267-1070-A-001-B	Sink (Food Prep) - Kitchen	8/29/2018	9/4/2018	A8H0819-28	Lead	ND	0.200	15	ppb
267-1070-B-001-A	Sink (Food Prep) - Kitchen	8/29/2018	9/4/2018	A8H0819-29	Copper	0.150	0.00200	1.3	ppm
267-1070-B-001-A	Sink (Food Prep) - Kitchen	8/29/2018	9/4/2018	A8H0819-29	Lead	1.35	0.200	15	ppb
267-1070-B-001-B	Sink (Food Prep) - Kitchen	8/29/2018	9/4/2018	A8H0819-30	Copper	0.271	0.00200	1.3	ppm
267-1070-B-001-B	Sink (Food Prep) - Kitchen	8/29/2018	9/4/2018	A8H0819-30	Lead	ND	0.200	15	ppb
267-1065-N/A-001-A	Classroom Sink Bubbler - Classroom 19	8/29/2018	9/4/2018	A8H0819-31	Copper	0.140	0.00200	1.3	ppm
267-1065-N/A-001-A	Classroom Sink Bubbler - Classroom 19	8/29/2018	9/4/2018	A8H0819-31	Lead	10.1	0.200	15	ppb
267-1065-N/A-001-B	Classroom Sink Bubbler - Classroom 19	8/29/2018	9/4/2018	A8H0819-32	Copper	0.354	0.00200	1.3	ppm
267-1065-N/A-001-B	Classroom Sink Bubbler - Classroom 19	8/29/2018	9/4/2018	A8H0819-32	Lead	3.82	0.200	15	ppb
267-1078-N/A-001-A	Classroom Sink Bubbler - Classroom 20	8/29/2018	9/4/2018	A8H0819-33	Copper	0.562	0.00200	1.3	ppm
267-1078-N/A-001-A	Classroom Sink Bubbler - Classroom 20	8/29/2018	9/4/2018	A8H0819-33	Lead	15.9	0.200	15	ppb
267-1078-N/A-001-B	Classroom Sink Bubbler - Classroom 20	8/29/2018	9/4/2018	A8H0819-34	Copper	0.389	0.00200	1.3	ppm
267-1078-N/A-001-B	Classroom Sink Bubbler - Classroom 20	8/29/2018	9/4/2018	A8H0819-34	Lead	4.30	0.200	15	ppb
267-1075-N/A-001-A	Classroom Sink Bubbler - Classroom 21	8/29/2018	9/4/2018	A8H0819-35	Copper	0.592	0.00200	1.3	ppm
267-1075-N/A-001-A	Classroom Sink Bubbler - Classroom 21	8/29/2018	9/4/2018	A8H0819-35	Lead	7.97	0.200	15	ppb
267-1075-N/A-001-B	Classroom Sink Bubbler - Classroom 21	8/29/2018	9/4/2018	A8H0819-36	Copper	0.482	0.00200	1.3	ppm
267-1075-N/A-001-B	Classroom Sink Bubbler - Classroom 21	8/29/2018	9/4/2018	A8H0819-36	Lead	1.67	0.200	15	ppb
267-1071-N/A-001-A	Classroom Sink Bubbler - Classroom 24	8/29/2018	9/4/2018	A8H0819-37	Copper	0.167	0.00200	1.3	ppm
267-1071-N/A-001-A	Classroom Sink Bubbler - Classroom 24	8/29/2018	9/4/2018	A8H0819-37	Lead	3.15	0.200	15	ppb
267-1071-N/A-001-B	Classroom Sink Bubbler - Classroom 24	8/29/2018	9/4/2018	A8H0819-38	Copper	0.277	0.00200	1.3	ppm
267-1071-N/A-001-B	Classroom Sink Bubbler - Classroom 24	8/29/2018	9/4/2018	A8H0819-38	Lead	1.40	0.200	15	ppb
267-1074-N/A-001-A	Classroom Sink Bubbler - Classroom 23	8/29/2018	9/4/2018	A8H0819-39	Copper	0.549	0.00200	1.3	ppm
267-1074-N/A-001-A	Classroom Sink Bubbler - Classroom 23	8/29/2018	9/4/2018	A8H0819-39	Lead	9.15	0.200	15	ppb
267-1074-N/A-001-B	Classroom Sink Bubbler - Classroom 23	8/29/2018	9/4/2018	A8H0819-40	Copper	0.479	0.00200	1.3	ppm
267-1074-N/A-001-B	Classroom Sink Bubbler - Classroom 23	8/29/2018	9/4/2018	A8H0819-40	Lead	2.68	0.200	15	ppb
267-1077-N/A-001-A	Classroom Sink Bubbler - Classroom 22	8/29/2018	9/5/2018	A8H0819-41RE1	Copper	0.618	0.00200	1.3	ppm
267-1077-N/A-001-A	Classroom Sink Bubbler - Classroom 22	8/29/2018	9/4/2018	A8H0819-41	Lead	5.51	0.200	15	ppb
267-1077-N/A-001-B	Classroom Sink Bubbler - Classroom 22	8/29/2018	9/5/2018	A8H0819-42RE1	Copper	0.584	0.00200	1.3	ppm

267-1077-N/A-001-B	Classroom Sink Bubbler - Classroom 22	8/29/2018	9/4/2018	A8H0819-42	Lead	0.971	0.200	15	ppb
267-1061-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 1	8/29/2018	9/5/2018	A8H0819-43RE2	Copper	0.701	0.00200	1.3	ppm
267-1061-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 1	8/29/2018	9/4/2018	A8H0819-43	Lead	3.27	0.200	15	ppb
267-1061-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 1	8/29/2018	9/5/2018	A8H0819-44RE1	Copper	0.688	0.00200	1.3	ppm
267-1061-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 1	8/29/2018	9/4/2018	A8H0819-44	Lead	0.903	0.200	15	ppb
267-1062-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 2	8/29/2018	9/5/2018	A8H0819-45RE1	Copper	0.740	0.00200	1.3	ppm
267-1062-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 2	8/29/2018	9/4/2018	A8H0819-45	Lead	3.85	0.200	15	ppb
267-1062-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 2	8/29/2018	9/5/2018	A8H0819-46RE1	Copper	0.286	0.00200	1.3	ppm
267-1062-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 2	8/29/2018	9/4/2018	A8H0819-46	Lead	1.24	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.