Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Lincoln High School - Test 3

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
120-CH1957-A-003-A	Boys Locker Room	4/3/2019	4/16/2019	A9D0357-01	Lead	3.74	0.20	15	ppb
120-CH1957-B-003-A	Boys Locker Room	4/3/2019	4/16/2019	A9D0357-03	Lead	1.04	0.20	15	ppb
120-CH1951-N/A-003-A	Gym (Weight Room)	4/3/2019	4/16/2019	A9D0357-05	Lead	23.20	0.20	15	ppb
120-CH1943-A-003-A	Hallway (Lunch Room 9)	4/3/2019	4/16/2019	A9D0357-07	Lead	ND	0.20	15	ppb
120-CH1943-B-003-A	Hallway (Lunch Room 9)	4/3/2019	4/16/2019	A9D0357-09	Lead	ND	0.20	15	ppb
120-CH1944-N/A-003-A	Hallway (Lunch Room 9)	4/3/2019	4/16/2019	A9D0357-11	Lead	ND	0.20	15	ppb
120-CH1961-A-003-A	Hallway (123)	4/3/2019	4/16/2019	A9D0357-13	Lead	4.69	0.20	15	ppb
120-CH1961-B-003-A	Hallway (123)	4/3/2019	4/16/2019	A9D0357-15	Lead	4.06	0.20	15	ppb
120-CH1961-C-003-A	Hallway (123)	4/3/2019	4/16/2019	A9D0357-17	Lead	4.52	0.20	15	ppb
120-CH1968-C-003-A	Outside Concessions	4/3/2019	4/16/2019	A9D0357-19	Lead	3.02	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

*OHA Action Level = 15ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek