

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Llewellyn

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
269-CH1183-NA-001-A	Classroom 103	9/26/2018	9/27/2018	A8I0719-01	Copper	0.532	0.00200	1.3	ppm
269-CH1183-NA-001-A	Classroom 103	9/26/2018	9/27/2018	A8I0719-01	Lead	9.75	0.200	15	ppb
269-CH1183-NA-001-B	Classroom 103	9/26/2018	9/27/2018	A8I0719-02	Copper	0.356	0.00200	1.3	ppm
269-CH1183-NA-001-B	Classroom 103	9/26/2018	9/27/2018	A8I0719-02	Lead	2.44	0.200	15	ppb
269-CH1271-NA-001-A	Classroom 102	9/26/2018	9/27/2018	A8I0719-03	Copper	0.632	0.00200	1.3	ppm
269-CH1271-NA-001-A	Classroom 102	9/26/2018	9/27/2018	A8I0719-03	Lead	12.1	0.200	15	ppb
269-CH1271-NA-001-B	Classroom 102	9/26/2018	9/27/2018	A8I0719-04	Copper	0.351	0.00200	1.3	ppm
269-CH1271-NA-001-B	Classroom 102	9/26/2018	9/27/2018	A8I0719-04	Lead	4.45	0.200	15	ppb
269-CH1272-NA-001-A	Classroom 109	9/26/2018	9/27/2018	A8I0719-09RE1	Copper	1.12	0.0100	1.3	ppm
269-CH1272-NA-001-A	Classroom 109	9/26/2018	9/27/2018	A8I0719-09	Lead	30.7	0.200	15	ppb
269-CH1272-NA-001-B	Classroom 109	9/26/2018	9/27/2018	A8I0719-10RE1	Copper	1.26	0.0100	1.3	ppm
269-CH1272-NA-001-B	Classroom 109	9/26/2018	9/27/2018	A8I0719-10	Lead	26.2	0.200	15	ppb
269-CH1273-NA-001-A	Classroom 110	9/26/2018	9/27/2018	A8I0719-11	Copper	0.0107	0.00200	1.3	ppm
269-CH1273-NA-001-A	Classroom 110	9/26/2018	9/27/2018	A8I0719-11	Lead	9.00	0.200	15	ppb
269-CH1273-NA-001-B	Classroom 110	9/26/2018	9/27/2018	A8I0719-12	Copper	0.00675	0.00200	1.3	ppm
269-CH1273-NA-001-B	Classroom 110	9/26/2018	9/27/2018	A8I0719-12	Lead	9.51	0.200	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

269-CH1281-NA-001-A	Classroom 202	9/26/2018	9/27/2018	A8I0719-05	Copper	0.487	0.00200	1.3	ppm
269-CH1281-NA-001-A	Classroom 202	9/26/2018	9/27/2018	A8I0719-05	Lead	8.16	0.200	15	ppb
269-CH1281-NA-001-B	Classroom 202	9/26/2018	9/27/2018	A8I0719-06	Copper	0.634	0.00200	1.3	ppm
269-CH1281-NA-001-B	Classroom 202	9/26/2018	9/27/2018	A8I0719-06	Lead	2.41	0.200	15	ppb
269-CH1282-NA-001-A	Classroom 210	9/26/2018	9/27/2018	A8I0719-07	Copper	0.657	0.00200	1.3	ppm
269-CH1282-NA-001-A	Classroom 210	9/26/2018	9/27/2018	A8I0719-07	Lead	15.3	0.200	15	ppb
269-CH1282-NA-001-B	Classroom 210	9/26/2018	9/27/2018	A8I0719-08	Copper	0.879	0.00200	1.3	ppm
269-CH1282-NA-001-B	Classroom 210	9/26/2018	9/27/2018	A8I0719-08	Lead	3.12	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.