

**Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Llewellyn 2**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
269-CH1186-A-002-A	Hallway by Office	10/1/2018	10/2/2018	A8J0012-03	Copper	0.0177	0.00200	1.3	ppm
269-CH1186-A-002-A	Hallway by Office	10/1/2018	10/2/2018	A8J0012-03	Lead	77.9	0.200	15	ppb
269-CH1186-A-002-B	Hallway by Office	10/1/2018	10/2/2018	A8J0012-04	Copper	0.00482	0.00200	1.3	ppm
269-CH1186-A-002-B	Hallway by Office	10/1/2018	10/2/2018	A8J0012-04	Lead	6.59	0.200	15	ppb
269-CH1186-B-002-A	Hallway by Office	10/1/2018	10/2/2018	A8J0012-05	Copper	0.0143	0.00200	1.3	ppm
269-CH1186-B-002-A	Hallway by Office	10/1/2018	10/2/2018	A8J0012-05	Lead	9.64	0.200	15	ppb
269-CH1186-B-002-B	Hallway by Office	10/1/2018	10/2/2018	A8J0012-06	Copper	0.00383	0.00200	1.3	ppm
269-CH1186-B-002-B	Hallway by Office	10/1/2018	10/2/2018	A8J0012-06	Lead	6.53	0.200	15	ppb
269-CH1274-NA-002-A	Hallway 101	10/1/2018	10/2/2018	A8J0012-01	Copper	0.0301	0.00200	1.3	ppm
269-CH1274-NA-002-A	Hallway 101	10/1/2018	10/2/2018	A8J0012-01	Lead	87.8	0.200	15	ppb
269-CH1274-NA-002-B	Hallway 101	10/1/2018	10/2/2018	A8J0012-02	Copper	0.00634	0.00200	1.3	ppm
269-CH1274-NA-002-B	Hallway 101	10/1/2018	10/2/2018	A8J0012-02	Lead	10.3	0.200	15	ppb
269-CH1277-NA-002-A	Hallway by Cafeteria	10/1/2018	10/2/2018	A8J0012-07	Copper	0.00512	0.00200	1.3	ppm
269-CH1277-NA-002-A	Hallway by Cafeteria	10/1/2018	10/2/2018	A8J0012-07	Lead	63.8	0.200	15	ppb
269-CH1277-NA-002-B	Hallway by Cafeteria	10/1/2018	10/2/2018	A8J0012-08	Copper	0.00242	0.00200	1.3	ppm
269-CH1277-NA-002-B	Hallway by Cafeteria	10/1/2018	10/2/2018	A8J0012-08	Lead	13.0	0.200	15	ppb
269-CH1279-A-002-A	Hallway by 205	10/1/2018	10/2/2018	A8J0012-25	Copper	0.0264	0.00200	1.3	ppm

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

269-CH1279-A-002-A	Hallway by 205	10/1/2018	10/2/2018 A8J0012-25	Lead	36.9	0.200	15	ppb
269-CH1279-A-002-B	Hallway by 205	10/1/2018	10/2/2018 A8J0012-26	Copper	0.00515	0.00200	1.3	ppm
269-CH1279-A-002-B	Hallway by 205	10/1/2018	10/2/2018 A8J0012-26	Lead	6.11	0.200	15	ppb
269-CH1279-B-002-A	Hallway by 205	10/1/2018	10/2/2018 A8J0012-27	Copper	0.0106	0.00200	1.3	ppm
269-CH1279-B-002-A	Hallway by 205	10/1/2018	10/2/2018 A8J0012-27	Lead	5.03	0.200	15	ppb
269-CH1279-B-002-B	Hallway by 205	10/1/2018	10/2/2018 A8J0012-28	Copper	0.00431	0.00200	1.3	ppm
269-CH1279-B-002-B	Hallway by 205	10/1/2018	10/2/2018 A8J0012-28	Lead	3.56	0.200	15	ppb
269-CH1280-A-002-A	Hallway by 108	10/1/2018	10/2/2018 A8J0012-15	Copper	0.0181	0.00200	1.3	ppm
269-CH1280-A-002-A	Hallway by 108	10/1/2018	10/2/2018 A8J0012-15	Lead	12.7	0.200	15	ppb
269-CH1280-A-002-B	Hallway by 108	10/1/2018	10/2/2018 A8J0012-16	Copper	0.00313	0.00200	1.3	ppm
269-CH1280-A-002-B	Hallway by 108	10/1/2018	10/2/2018 A8J0012-16	Lead	4.59	0.200	15	ppb
269-CH1280-B-002-A	Hallway by 108	10/1/2018	10/2/2018 A8J0012-17	Copper	0.0191	0.00200	1.3	ppm
269-CH1280-B-002-A	Hallway by 108	10/1/2018	10/2/2018 A8J0012-17	Lead	3.61	0.200	15	ppb
269-CH1280-B-002-B	Hallway by 108	10/1/2018	10/2/2018 A8J0012-18	Copper	0.00571	0.00200	1.3	ppm
269-CH1280-B-002-B	Hallway by 108	10/1/2018	10/2/2018 A8J0012-18	Lead	3.70	0.200	15	ppb
269-CH1284-NA-002-A	Hallway by 210	10/1/2018	10/2/2018 A8J0012-23	Copper	0.0105	0.00200	1.3	ppm
269-CH1284-NA-002-A	Hallway by 210	10/1/2018	10/2/2018 A8J0012-23	Lead	86.0	0.200	15	ppb
269-CH1284-NA-002-B	Hallway by 210	10/1/2018	10/2/2018 A8J0012-24	Copper	0.00550	0.00200	1.3	ppm
269-CH1284-NA-002-B	Hallway by 210	10/1/2018	10/2/2018 A8J0012-24	Lead	17.3	0.200	15	ppb
269-CH1286-NA-002-A	Hallway by 109	10/1/2018	10/2/2018 A8J0012-19	Copper	0.141	0.00200	1.3	ppm
269-CH1286-NA-002-A	Hallway by 109	10/1/2018	10/2/2018 A8J0012-19	Lead	9.11	0.200	15	ppb
269-CH1286-NA-002-B	Hallway by 109	10/1/2018	10/2/2018 A8J0012-20	Copper	0.00986	0.00200	1.3	ppm

Analyzed by: Apex Laboratories

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

269-CH1286-NA-002-B	Hallway by 109	10/1/2018	10/2/2018	A8J0012-20	Lead	43.4	0.200	15	ppb
269-CH1289-NA-002-A	Hallway by 109	10/1/2018	10/2/2018	A8J0012-21	Copper	0.178	0.00200	1.3	ppm
269-CH1289-NA-002-A	Hallway by 109	10/1/2018	10/2/2018	A8J0012-21	Lead	14.2	0.200	15	ppb
269-CH1289-NA-002-B	Hallway by 109	10/1/2018	10/2/2018	A8J0012-22	Copper	0.0105	0.00200	1.3	ppm
269-CH1289-NA-002-B	Hallway by 109	10/1/2018	10/2/2018	A8J0012-22RE1	Lead	4.70	0.200	15	ppb
269-CH1290-NA-002-A	Kitchen	10/1/2018	10/2/2018	A8J0012-09	Copper	0.0475	0.00200	1.3	ppm
269-CH1290-NA-002-A	Kitchen	10/1/2018	10/2/2018	A8J0012-09	Lead	1.53	0.200	15	ppb
269-CH1290-NA-002-B	Kitchen	10/1/2018	10/2/2018	A8J0012-10	Copper	0.00745	0.00200	1.3	ppm
269-CH1290-NA-002-B	Kitchen	10/1/2018	10/2/2018	A8J0012-10	Lead	4.31	0.200	15	ppb
269-CH1292-NA-002-A	Hallway by 202	10/1/2018	10/2/2018	A8J0012-29	Copper	0.0279	0.00200	1.3	ppm
269-CH1292-NA-002-A	Hallway by 202	10/1/2018	10/2/2018	A8J0012-29	Lead	273	0.200	15	ppb
269-CH1292-NA-002-B	Hallway by 202	10/1/2018	10/2/2018	A8J0012-30RE1	Copper	ND	0.00200	1.3	ppm
269-CH1292-NA-002-B	Hallway by 202	10/1/2018	10/2/2018	A8J0012-30RE1	Lead	22.7	0.200	15	ppb
269-CH1293-A-002-A	Kitchen	10/1/2018	10/2/2018	A8J0012-11	Copper	0.0110	0.00200	1.3	ppm
269-CH1293-A-002-A	Kitchen	10/1/2018	10/2/2018	A8J0012-11	Lead	6.23	0.200	15	ppb
269-CH1293-A-002-B	Kitchen	10/1/2018	10/2/2018	A8J0012-12	Copper	0.00822	0.00200	1.3	ppm
269-CH1293-A-002-B	Kitchen	10/1/2018	10/2/2018	A8J0012-12	Lead	4.02	0.200	15	ppb
269-CH1293-B-002-A	Kitchen	10/1/2018	10/2/2018	A8J0012-13	Copper	0.0188	0.00200	1.3	ppm
269-CH1293-B-002-A	Kitchen	10/1/2018	10/2/2018	A8J0012-13	Lead	4.75	0.200	15	ppb
269-CH1293-B-002-B	Kitchen	10/1/2018	10/2/2018	A8J0012-14	Copper	0.00799	0.00200	1.3	ppm
269-CH1293-B-002-B	Kitchen	10/1/2018	10/2/2018	A8J0012-14	Lead	4.12	0.200	15	ppb

Analyzed by: Apex Laboratories

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental