

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Llewellyn Elementary School - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
269-CH1283-N/A-004-A	Hallway (109)	4/4/2019	4/16/2019	A9D0328-01	Lead	3.93	0.20	15	ppb
269-CH1286-N/A-004-A	Hallway (109)	4/4/2019	4/16/2019	A9D0328-03	Lead	3.05	0.20	15	ppb
269-CH1295-N/A-004-A	Portable 1	4/4/2019	4/16/2019	A9D0328-05	Lead	36.30	0.20	15	ppb
269-CH1278-N/A-004-A	Hallway (206)	4/4/2019	4/16/2019	A9D0328-07	Lead	9.14	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.