

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Madison - Test 4**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
218-CH1421-B-004-A	Hallway C42	3/27/2019	4/9/2019	A9C1071-01	Lead	10.5	0.20	15	ppb
218-CH1421-C-004-A	Hallway C42	3/27/2019	4/9/2019	A9C1071-03	Lead	8.22	0.20	15	ppb
218-CH1424-B-004-A	Hallway C25	3/27/2019	4/9/2019	A9C1071-05	Lead	5.88	0.20	15	ppb
218-CH1430-A-004-A	Hallway B40	3/27/2019	4/9/2019	A9C1071-07	Lead	2.05	0.20	15	ppb
218-CH1430-B-004-A	Hallway B40	3/27/2019	4/9/2019	A9C1071-09	Lead	2.12	0.20	15	ppb
218-CH1422-C-004-A	Hallway B42	3/27/2019	4/9/2019	A9C1071-11	Lead	8.79	0.20	15	ppb
218-CH4672-A-004-A	Classroom B65	3/27/2019	4/9/2019	A9C1071-13	Lead	5.2	0.20	15	ppb
218-CH4663-N/A-004-A	Cafeteria	3/27/2019	4/9/2019	A9C1071-15	Lead	0.968	0.20	15	ppb
218-CH4719-N/A-004-A	Gym	3/27/2019	4/9/2019	A9C1071-17	Lead	3.52	0.20	15	ppb
218-CH4711-N/A-004-A	Men's Locker Room	3/27/2019	4/9/2019	A9C1071-19	Lead	31.30	0.20	15	ppb
218-CH5161-N/A-004-A	Classroom B71	3/27/2019	4/9/2019	A9C1071-21	Lead	63.40	0.20	15	ppb
218-CH4714-N/A-004-A	Outside (Entrance)	3/27/2019	4/9/2019	A9C1071-23	Lead	8.52	0.20	15	ppb
218-CH5160-A-004-A	Classroom B71	3/27/2019	4/9/2019	A9C1071-25	Lead	284.00	0.20	15	ppb
218-CH5160-B-004-A	Classroom B71	3/27/2019	4/9/2019	A9C1071-27	Lead	226.00	0.20	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.