

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Maplewood Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
172-4398-A-001A Near Rm 105	08/07/18 7:15 AM	08/08/18 5:39 PM	18018028	Copper	0.2	1.3	ppm
172-4398-A-001A Near Rm 105	08/07/18 7:15 AM	08/08/18 5:39 PM	18018028	Lead	20	15	ppb
172-4398-A-001B Near Rm 105	08/07/18 7:15 AM	08/08/18 5:41 PM	18018030	Copper	< 0.1	1.3	ppm
172-4398-A-001B Near Rm 105	08/07/18 7:15 AM	08/08/18 5:41 PM	18018030	Lead	2	15	ppb
172-4398-B-001A Near Rm 105	08/07/18 7:15 AM	08/08/18 5:42 PM	18018029	Copper	0.2	1.3	ppm
172-4398-B-001A Near Rm 105	08/07/18 7:15 AM	08/08/18 5:42 PM	18018029	Lead	15	15	ppb
172-4398-B-001B Near Rm 105	08/07/18 7:15 AM	08/08/18 5:59 PM	18018025	Copper	< 0.1	1.3	ppm
172-4398-B-001B Near Rm 105	08/07/18 7:15 AM	08/08/18 5:59 PM	18018025	Lead	2	15	ppb
172-4389-A-001A Kitchen	08/07/18 7:20 AM	08/08/18 6:01 PM	18018027	Copper	0.1	1.3	ppm
172-4389-A-001A Kitchen	08/07/18 7:20 AM	08/08/18 6:01 PM	18018027	Lead	5	15	ppb
172-4389-A-001B Kitchen	08/07/18 7:20 AM	08/08/18 6:02 PM	18018026	Copper	0.1	1.3	ppm
172-4389-A-001B Kitchen	08/07/18 7:20 AM	08/08/18 6:02 PM	18018026	Lead	1	15	ppb
172-4395-A-001A Kitchen	08/07/18 7:30 AM	08/08/18 6:04 PM	18018031	Copper	0.3	1.3	ppm
172-4395-A-001A Kitchen	08/07/18 7:30 AM	08/08/18 6:04 PM	18018031	Lead	7	15	ppb
172-4395-A-001B Kitchen	08/07/18 7:30 AM	08/08/18 6:06 PM	18018032	Copper	0.5	1.3	ppm
172-4395-A-001B Kitchen	08/07/18 7:30 AM	08/08/18 6:06 PM	18018032	Lead	< 1	15	ppb
172-4380-A-001A Cafeteria	08/07/18 7:37 AM	08/09/18 6:14 PM	18018033	Copper	0.9	1.3	ppm
172-4380-A-001A Cafeteria	08/07/18 7:37 AM	08/08/18 6:08 PM	18018033	Lead	4	15	ppb
172-4380-A-001B Cafeteria	08/07/18 7:37 AM	08/09/18 6:17 PM	18018034	Copper	1.1	1.3	ppm
172-4380-A-001B Cafeteria	08/07/18 7:37 AM	08/08/18 6:10 PM	18018034	Lead	1	15	ppb
172-4377-A-001A Cafeteria	08/07/18 7:40 AM	08/09/18 6:21 PM	18018035	Copper	0.7	1.3	ppm
172-4377-A-001A Cafeteria	08/07/18 7:40 AM	08/08/18 6:11 PM	18018035	Lead	2	15	ppb
172-4377-A-001B Cafeteria	08/07/18 7:40 AM	08/08/18 6:24 PM	18018036	Copper	0.3	1.3	ppm
172-4377-A-001B Cafeteria	08/07/18 7:40 AM	08/08/18 6:24 PM	18018036	Lead	< 1	15	ppb

Analyzed by: Pixis Labs

*EPA action level for lead is 20 ppb and 1.3 for copper

Reviewed by: TRC Environmental Corporation

Page 1 of 1