

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Maplewood Elementary School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
172-CH4390-N/A-003-A	Classroom 111	3/28/2019	4/9/2019	A9C1068-01	Lead	8.88	0.20	15	ppb
172-CH4380-N/A-003-A	Cafeteria	3/28/2019	4/9/2019	A9C1068-03	Lead	0.797	0.20	15	ppb
172-CH4383-N/A-003-A	Hallway (Gym)	3/28/2019	4/9/2019	A9C1068-05	Lead	4.77	0.20	15	ppb
172-CH4386-N/A-003-A	Hallway (Gym)	3/28/2019	4/9/2019	A9C1068-07	Lead	2.92	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15 ppb