

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Markham School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
170-CH3929-N/A-003-A	Classroom 159	4/9/2019	4/22/2019	A9D0541-01	Lead	7.11	0.20	15	ppb
170-CH3940-N/A-003-A	Classroom 223	4/9/2019	4/22/2019	A9D0541-03	Lead	14.9	0.20	15	ppb
170-CH3942-N/A-003-A	Classroom 105	4/9/2019	4/22/2019	A9D0541-05	Lead	24.80	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.