

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
King Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
262-1684-A-002A Kitchen (Faucet)	10/04/18 6:07 AM	10/09/18 4:05 PM	18025564	Copper	< 0.1	1.3	ppm
262-1684-A-002A Kitchen (Faucet)	10/04/18 6:07 AM	10/09/18 4:05 PM	18025564	Lead	4	15	ppb
262-1684-A-002B Kitchen (Faucet)	10/04/18 6:08 AM	10/09/18 4:07 PM	18025565	Copper	< 0.1	1.3	ppm
262-1684-A-002B Kitchen (Faucet)	10/04/18 6:08 AM	10/09/18 4:07 PM	18025565	Lead	3	15	ppb
262-1696-A-002A Cafeteria (DF)	10/04/18 6:14 AM	10/09/18 4:10 PM	18025566	Copper	< 0.1	1.3	ppm
262-1696-A-002A Cafeteria (DF)	10/04/18 6:14 AM	10/09/18 4:10 PM	18025566	Lead	1	15	ppb
262-1696-A-002B Cafeteria (DF)	10/04/18 6:15 AM	10/09/18 5:30 PM	18025567	Copper	< 0.1	1.3	ppm
262-1696-A-002B Cafeteria (DF)	10/04/18 6:15 AM	10/09/18 5:30 PM	18025567	Lead	< 1	15	ppb
262-1664-A-002A Gym West Wall LT	10/04/18 6:18 AM	10/09/18 5:33 PM	18025568	Copper	< 0.1	1.3	ppm
262-1664-A-002A Gym West Wall LT	10/04/18 6:18 AM	10/09/18 5:33 PM	18025568	Lead	76	15	ppb
262-1664-A-002B Gym West Wall LT	10/04/18 6:19 AM	10/09/18 5:36 PM	18025569	Copper	< 0.1	1.3	ppm
262-1664-A-002B Gym West Wall LT	10/04/18 6:19 AM	10/09/18 5:36 PM	18025569	Lead	7	15	ppb
262-1664-B-002A Gym West Wall RT	10/04/18 6:20 AM	10/10/18 6:24 PM	18025570	Copper	< 0.1	1.3	ppm
262-1664-B-002A Gym West Wall RT	10/04/18 6:20 AM	10/10/18 6:24 PM	18025570	Lead	7	15	ppb
262-1664-B-002B Gym West Wall RT	10/04/18 6:21 AM	10/10/18 6:27 PM	18025571	Copper	< 0.1	1.3	ppm
262-1664-B-002B Gym West Wall RT	10/04/18 6:21 AM	10/10/18 6:27 PM	18025571	Lead	5	15	ppb
262-1679-A-002A Classroom 210	10/04/18 6:32 AM	10/10/18 6:30 PM	18025572	Copper	< 0.1	1.3	ppm
262-1679-A-002A Classroom 210	10/04/18 6:32 AM	10/10/18 6:30 PM	18025572	Lead	11	15	ppb
262-1679-A-002B Classroom 210	10/04/18 6:33 AM	10/10/18 6:33 PM	18025573	Copper	< 0.1	1.3	ppm
262-1679-A-002B Classroom 210	10/04/18 6:33 AM	10/10/18 6:33 PM	18025573	Lead	13	15	ppb
262-1682-A-002A Classroom 211	10/04/18 6:35 AM	10/10/18 6:36 PM	18025574	Copper	< 0.1	1.3	ppm
262-1682-A-002A Classroom 211	10/04/18 6:35 AM	10/10/18 6:36 PM	18025574	Lead	18	15	ppb
262-1682-A-002B Classroom 211	10/04/18 6:36 AM	10/10/18 6:58 PM	18025575	Copper	< 0.1	1.3	ppm
262-1682-A-002B Classroom 211	10/04/18 6:36 AM	10/10/18 6:58 PM	18025575	Lead	8	15	ppb
262-1685-A-002A Classroom 212	10/04/18 6:39 AM	10/10/18 7:01 PM	18025576	Copper	< 0.1	1.3	ppm
262-1685-A-002A Classroom 212	10/04/18 6:39 AM	10/10/18 7:01 PM	18025576	Lead	9	15	ppb
262-1685-A-002B Classroom 212	10/04/18 6:40 AM	10/10/18 7:04 PM	18025577	Copper	< 0.1	1.3	ppm
262-1685-A-002B Classroom 212	10/04/18 6:40 AM	10/10/18 7:04 PM	18025577	Lead	6	15	ppb
262-1698-A-002A Classroom 220 (bubbler)	10/04/18 6:44 AM	10/10/18 7:07 PM	18025578	Copper	< 0.1	1.3	ppm
262-1698-A-002A Classroom 220 (bubbler)	10/04/18 6:44 AM	10/10/18 7:07 PM	18025578	Lead	5	15	ppb
262-1698-A-002B Classroom 220 (bubbler)	10/04/18 6:45 AM	10/10/18 7:10 PM	18025579	Copper	< 0.1	1.3	ppm
262-1698-A-002B Classroom 220 (bubbler)	10/04/18 6:45 AM	10/10/18 7:10 PM	18025579	Lead	3	15	ppb
262-1683-A-002A Classroom 251	10/04/18 6:49 AM	10/10/18 7:13 PM	18025580	Copper	< 0.1	1.3	ppm
262-1683-A-002A Classroom 251	10/04/18 6:49 AM	10/10/18 7:13 PM	18025580	Lead	12	15	ppb
262-1683-A-002B Classroom 251	10/04/18 6:50 AM	10/10/18 7:17 PM	18025581	Copper	< 0.1	1.3	ppm
262-1683-A-002B Classroom 251	10/04/18 6:50 AM	10/10/18 7:17 PM	18025581	Lead	6	15	ppb
262-1658-A-002A Classroom 140-C	10/04/18 6:57 AM	10/10/18 7:20 PM	18025582	Copper	< 0.1	1.3	ppm
262-1658-A-002A Classroom 140-C	10/04/18 6:57 AM	10/10/18 7:20 PM	18025582	Lead	4	15	ppb
262-1658-A-002B Classroom 140-C	10/04/18 6:58 AM	10/10/18 7:23 PM	18025583	Copper	< 0.1	1.3	ppm
262-1658-A-002B Classroom 140-C	10/04/18 6:58 AM	10/10/18 7:23 PM	18025583	Lead	5	15	ppb
262-1699-A-002A Classroom 141	10/04/18 7:03 AM	10/10/18 7:26 PM	18025584	Copper	< 0.1	1.3	ppm
262-1699-A-002A Classroom 141	10/04/18 7:03 AM	10/10/18 7:26 PM	18025584	Lead	4	15	ppb
262-1699-A-002B Classroom 141	10/04/18 7:04 AM	10/10/18 7:48 PM	18025585	Copper	< 0.1	1.3	ppm
262-1699-A-002B Classroom 141	10/04/18 7:04 AM	10/10/18 7:48 PM	18025585	Lead	6	15	ppb
262-1702-A-002A Classroom 142	10/04/18 7:07 AM	10/10/18 7:51 PM	18025586	Copper	< 0.1	1.3	ppm
262-1702-A-002A Classroom 142	10/04/18 7:07 AM	10/10/18 7:51 PM	18025586	Lead	5	15	ppb
262-1702-A-002B Classroom 142	10/04/18 7:09 AM	10/10/18 7:54 PM	18025587	Copper	< 0.1	1.3	ppm
262-1702-A-002B Classroom 142	10/04/18 7:09 AM	10/10/18 7:54 PM	18025587	Lead	6	15	ppb
262-1670-A-002A Classroom 130	10/04/18 7:13 AM	10/10/18 7:57 PM	18025588	Copper	< 0.1	1.3	ppm
262-1670-A-002A Classroom 130	10/04/18 7:13 AM	10/10/18 7:57 PM	18025588	Lead	12	15	ppb
262-1670-A-002B Classroom 130	10/04/18 7:14 AM	10/10/18 8:00 PM	18025589	Copper	< 0.1	1.3	ppm
262-1670-A-002B Classroom 130	10/04/18 7:14 AM	10/10/18 8:00 PM	18025589	Lead	7	15	ppb
262-1681-A-002A Classroom 132	10/04/18 7:17 AM	10/10/18 8:03 PM	18025590	Copper	< 0.1	1.3	ppm
262-1681-A-002A Classroom 132	10/04/18 7:17 AM	10/10/18 8:03 PM	18025590	Lead	17	15	ppb

Analyzed by: Pixis Labs

*EPA action level for lead is 20 ppb and 1.3 for copper

Reviewed by: TRC Environmental Corporation

**Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
King Elementary School**

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
262-1681-A-002B Classroom 132	10/04/18 7:18 AM	10/10/18 8:06 PM	18025591	Copper	< 0.1	1.3	ppm
262-1681-A-002B Classroom 132	10/04/18 7:18 AM	10/10/18 8:06 PM	18025591	Lead	4	15	ppb
262-1678-A-002A Classroom 134	10/04/18 7:21 AM	10/10/18 8:09 PM	18025592	Copper	< 0.1	1.3	ppm
262-1678-A-002A Classroom 134	10/04/18 7:21 AM	10/10/18 8:09 PM	18025592	Lead	9	15	ppb
262-1678-A-002B Classroom 134	10/04/18 7:22 AM	10/10/18 8:12 PM	18025593	Copper	< 0.1	1.3	ppm
262-1678-A-002B Classroom 134	10/04/18 7:22 AM	10/10/18 8:12 PM	18025593	Lead	2	15	ppb
262-1701-A-002A Staff Kitchen (109)	10/04/18 7:36 AM	10/10/18 8:16 PM	18025594	Copper	< 0.1	1.3	ppm
262-1701-A-002A Staff Kitchen (109)	10/04/18 7:36 AM	10/10/18 8:16 PM	18025594	Lead	4	15	ppb
262-1701-A-002B Staff Kitchen (109)	10/04/18 7:37 AM	10/10/18 8:38 PM	18025595	Copper	< 0.1	1.3	ppm
262-1701-A-002B Staff Kitchen (109)	10/04/18 7:37 AM	10/10/18 8:38 PM	18025595	Lead	< 1	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.