Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
King Elementary School - Test 5

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
262-CH1676-N/A-005-A	Hallway (211)	5/21/2019	5/28/2019	A9E0811-05	Lead	3.26	0.20	15	ppb

*OHA Action Level = 15ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek