

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Marysville Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
268-5474A-001A Kitchen	08/01/18 10:40 AM	08/03/18 5:22 PM	18016962	Copper	0.1	1.3	ppm
268-5474A-001A Kitchen	08/01/18 10:40 AM	08/03/18 5:22 PM	18016962	Lead	2	15	ppb
268-5474-A-001B Kitchen	08/01/18 10:40 AM	08/03/18 5:24 PM	18016963	Copper	<0.1	1.3	ppm
268-5474-A-001B Kitchen	08/01/18 10:40 AM	08/03/18 5:24 PM	18016963	Lead	1	15	ppb
268-5474-B-001A Kitchen	08/01/18 10:41 AM	08/02/18 9:29 PM	18016964	Copper	0.1	1.3	ppm
268-5474-B-001A Kitchen	08/01/18 10:41 AM	08/02/18 9:29 PM	18016964	Lead	6	15	ppb
268-5474-B-001B Kitchen	08/01/18 10:41 AM	08/02/18 9:31 PM	18016965	Copper	<0.1	1.3	ppm
268-5474-B-001B Kitchen	08/01/18 10:41 AM	08/02/18 9:31 PM	18016965	Lead	6	15	ppb
268-5346-A-001A Hallway Custodial 102	08/01/18 10:50 AM	08/02/18 9:59 PM	18016966	Copper	<0.1	1.3	ppm
268-5346-A-001A Hallway Custodial 102	08/01/18 10:50 AM	08/02/18 9:59 PM	18016966	Lead	2	15	ppb
268-5346-A-001B Hallway Custodial 102	08/01/18 10:50 AM	08/02/18 10:02 PM	18016967	Copper	<0.1	1.3	ppm
268-5346-A-001B Hallway Custodial 102	08/01/18 10:50 AM	08/02/18 10:02 PM	18016967	Lead	1	15	ppb
268-5326-A-001A Hallway by Rm. 120	08/01/18 10:58 AM	08/02/18 9:33 PM	18016968	Copper	<0.1	1.3	ppm
268-5326-A-001A Hallway by Rm. 120	08/01/18 10:58 AM	08/02/18 9:33 PM	18016968	Lead	4	15	ppb
268-5326-A-001B Hallway by Rm. 120	08/01/18 10:58 AM	08/02/18 9:35 PM	18016969	Copper	<0.1	1.3	ppm
268-5326-A-001B Hallway by Rm. 120	08/01/18 10:58 AM	08/02/18 9:35 PM	18016969	Lead	5	15	ppb
268-5326-B-001A Hallway by Rm. 120	08/01/18 10:59 AM	08/02/18 8:50 PM	18016970	Copper	<0.1	1.3	ppm
268-5326-B-001A Hallway by Rm. 120	08/01/18 10:59 AM	08/02/18 8:50 PM	18016970	Lead	5	15	ppb
268-5326-B-001B Hallway by Rm. 120	08/01/18 10:59 AM	08/02/18 8:52 PM	18016971	Copper	<0.1	1.3	ppm
268-5326-B-001B Hallway by Rm. 120	08/01/18 10:59 AM	08/02/18 8:52 PM	18016971	Lead	1	15	ppb
268-5329-A-001A Hallway by Girls RR 118	08/01/18 11:00 AM	08/02/18 9:38 PM	18016972	Copper	0.1	1.3	ppm
268-5329-A-001A Hallway by Girls RR 118	08/01/18 11:00 AM	08/02/18 9:38 PM	18016972	Lead	1	15	ppb
268-5329-A-001B Hallway by Girls RR 118	08/01/18 11:00 AM	08/02/18 9:40 PM	18016973	Copper	<0.1	1.3	ppm
268-5329-A-001B Hallway by Girls RR 118	08/01/18 11:00 AM	08/02/18 9:40 PM	18016973	Lead	1	15	ppb
268-5329-B-001A Hallway by Girls RR 118	08/01/18 11:01 AM	08/02/18 9:42 PM	18016974	Copper	<0.1	1.3	ppm
268-5329-B-001A Hallway by Girls RR 118	08/01/18 11:01 AM	08/02/18 9:42 PM	18016974	Lead	1	15	ppb
268-5329-B-001B Hallway by Girls RR 118	08/01/18 11:01 AM	08/02/18 9:44 PM	18016975	Copper	<0.1	1.3	ppm
268-5329-B-001B Hallway by Girls RR 118	08/01/18 11:01 AM	08/02/18 9:44 PM	18016975	Lead	2	15	ppb

Analyzed by: Pixis Labs

Reviewed by: TRC Environmental Corporation

*EPA action level for lead is 20 ppb and 1.3 for copper