

**Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Marysville Elementary School**

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
268-5459-A-003A Room 151	09/28/18 6:29 AM	10/03/18 12:53 AM	18024690	Copper	0.3	1.3	ppm
268-5459-A-003A Room 151	09/28/18 6:29 AM	10/03/18 12:53 AM	18024690	Lead	3	15	ppb
268-5459-A-003B Room 151	09/28/18 6:29 AM	10/03/18 12:58 AM	18024652	Copper	0.3	1.3	ppm
268-5459-A-003B Room 151	09/28/18 6:29 AM	10/03/18 12:58 AM	18024652	Lead	< 1	15	ppb
268-5347-A-003A Hallway 146 Bottle Fill	09/28/18 6:35 AM	10/03/18 1:03 AM	18024693	Copper	0.3	1.3	ppm
268-5347-A-003A Hallway 146 Bottle Fill	09/28/18 6:35 AM	10/03/18 1:03 AM	18024693	Lead	4	15	ppb
268-5347-A-003B Hallway 146 Bottle Fill	09/28/18 6:35 AM	10/03/18 1:37 AM	18024688	Copper	0.5	1.3	ppm
268-5347-A-003B Hallway 146 Bottle Fill	09/28/18 6:35 AM	10/03/18 1:37 AM	18024688	Lead	< 1	15	ppb
268-5347-B-003A Hallway 146 Fountain	09/28/18 6:37 AM	10/03/18 1:41 AM	18024694	Copper	0.5	1.3	ppm
268-5347-B-003A Hallway 146 Fountain	09/28/18 6:37 AM	10/03/18 1:41 AM	18024694	Lead	< 1	15	ppb
268-5347-B-003B Hallway 146 Fountain	09/28/18 6:37 AM	10/03/18 1:46 AM	18024695	Copper	0.2	1.3	ppm
268-5347-B-003B Hallway 146 Fountain	09/28/18 6:37 AM	10/03/18 1:46 AM	18024695	Lead	< 1	15	ppb
268-5456-A-003A Hallway 146 Fountain	09/28/18 6:42 AM	10/03/18 1:51 AM	18024654	Copper	0.2	1.3	ppm
268-5456-A-003A Hallway 146 Fountain	09/28/18 6:42 AM	10/03/18 1:51 AM	18024654	Lead	< 1	15	ppb
268-5456-A-003B Hallway 146 Fountain	09/28/18 6:42 AM	10/03/18 1:56 AM	18024687	Copper	0.2	1.3	ppm
268-5456-A-003B Hallway 146 Fountain	09/28/18 6:42 AM	10/03/18 1:56 AM	18024687	Lead	< 1	15	ppb

Analyzed by: Pixis Labs

Reviewed by: TRC Environmental Corporation

*EPA action level for lead is 20 ppb and 1.3 for copper