Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Mcdaniel High School - Test 1

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
218-DF-6340-A-001-A	Track Level Concessions (Restrooms F210)	7/28/2021	08/03/2021	A1G0852-01	Lead	ND	0.2	15	ppb
218-DF-6343-N/A-001-A	Track Level Concessions F210A	7/28/2021	08/03/2021	A1G0852-02	Lead	1.26	0.2	15	ppb
218-DF-6342-N/A-001-A	Track Level Concessions F210A	7/28/2021	08/10/2021	A1G0852-03	Lead	1.56	0.2	15	ppb
218-DF-6341-N/A-001-A	Track Level Concessions F210A	7/28/2021	08/03/2021	A1G0852-04	Lead	3.29	0.2	15	ppb
218-DF-6405-A-001-A	Hallway Weight room G122 P1.11	7/28/2021	08/03/2021	A1G0852-05	Lead	ND	0.2	15	ppb
218-DF-6346-N/A-001-A	Food Clothing Pantry G134	7/28/2021	08/03/2021	A1G0852-06	Lead	ND	0.2	15	ppb
218-DF-6351-A-001-A	Gym Level Vestibule VG201	7/28/2021	08/03/2021	A1G0852-07	Lead	2.07	0.2	15	ppb
218-DF-6347-A-001-A	Gym Level (Restrooms G204)	7/28/2021	08/03/2021	A1G0852-08	Lead	4.77	0.2	15	ppb
218-DF-6348-N/A-001-A	Gym Level Concessions G207	7/28/2021	08/03/2021	A1G0852-09	Lead	8.41	0.2	15	ppb
218-DF-6349-N/A-001-A	Gym Level Concessions G207	7/28/2021	08/03/2021	A1G0852-10	Lead	2.79	0.2	15	ppb
218-DF-6350-N/A-001-A	Gym Level Concessions G207	7/28/2021	08/03/2021	A1G0852-11	Lead	2.05	0.2	15	ppb
218-DF-6356-N/A-001-A	Hall H007 (Restrooms 004)	7/28/2021	08/03/2021	A1G0852-12	Lead	ND	0.2	15	ppb
218-DF-6355-N/A-001-A	Student Government 027	7/28/2021	08/03/2021	A1G0852-13	Lead	0.629	0.2	15	ppb
218-DF-6354-N/A-001-A	Comm Partner Conference Rm 029	7/28/2021	08/03/2021	A1G0852-14	Lead	1.87	0.2	15	ppb
218-DF-6353-A-001-A	Basement (031)	7/28/2021	08/03/2021	A1G0852-15	Lead	ND	0.2	15	ppb
218-DF-6352-N/A-001-A	Teacher Collaboration Offices 033	7/28/2021	08/03/2021	A1G0852-16	Lead	8.62	0.2	15	ppb
218-DF-6372-A-001-A	Commons (Servery 184)	7/28/2021	08/03/2021	A1G0852-17	Lead	ND	0.2	15	ppb
218-DF-6374-N/A-001-A	Servery 184	7/28/2021	08/03/2021	A1G0852-18	Lead	0.443	0.2	15	ppb
218-DF-6375-N/A-001-A	Servery 184	7/28/2021	08/03/2021	A1G0852-19	Lead	0.627	0.2	15	ppb
218-DF-6376-N/A-001-A	Kitchen & Dishwashing 186	7/28/2021	08/03/2021	A1G0852-20	Lead	0.822	0.2	15	ppb
218-DF-6377-N/A-001-A	Kitchen & Dishwashing 186	7/28/2021	08/05/2021	A1G0852-21	Lead	2.05	0.2	15	ppb
218-DF-6378-N/A-001-A	Kitchen & Dishwashing 186	7/28/2021	08/05/2021	A1G0852-22	Lead	9.14	0.2	15	ppb
218-DF-6379-N/A-001-A	Kitchen & Dishwashing 186	7/28/2021	08/05/2021	A1G0852-23	Lead	2.08	0.2	15	ppb
218-DF-6380-N/A-001-A	Kitchen & Dishwashing 186	7/28/2021	08/05/2021	A1G0852-24	Lead	2.11	0.2	15	ppb
218-DF-6381-N/A-001-A	Kitchen & Dishwashing 186	7/28/2021	08/05/2021	A1G0852-25	Lead	5.37	0.2	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb

218-DF-6382-N/A-001-A	Kitchen & Dishwashing 186	7/28/2021	08/05/2021	A1G0852-26	Lead	0.802	0.2	15	ppb
218-DF-6371-A-001-A	Hall (181)	7/28/2021	08/05/2021	A1G0852-27	Lead	0.542	0.2	15	ppb
218-DF-6398-N/A-001-A	Teacher Collaboration Offices 291	7/28/2021	08/05/2021	A1G0852-28	Lead	11.6	0.2	15	ppb
218-DF-6397-A-001-A	Hall H209 (Restrooms 282)	7/28/2021	08/05/2021	A1G0852-29	Lead	ND	0.2	15	ppb
218-DF-6403-A-001-A	Hall H205 (220)	7/28/2021	08/05/2021	A1G0852-30	Lead	0.717	0.2	15	ppb
218-DF-6404-N/A-001-A	Teacher Collaboration Offices 206	7/28/2021	08/05/2021	A1G0852-31	Lead	8.91	0.2	15	ppb
218-DF-6400-N/A-001-A	Learning Resource Center 232	7/28/2021	08/05/2021	A1G0852-32	Lead	2.10	0.2	15	ppb
218-DF-6401-N/A-001-A	Learning Resource Center 233	7/28/2021	08/05/2021	A1G0852-33	Lead	3.62	0.2	15	ppb
218-DF-6399-A-001-A	Hall (Flexible Learning FX245)	7/28/2021	08/05/2021	A1G0852-34	Lead	ND	0.2	15	ppb
218-DF-6402-N/A-001-A	Teacher Collaboration Offices 237	7/28/2021	08/05/2021	A1G0852-35	Lead	5.28	0.2	15	ppb
218-DF-6388-N/A-001-A	Learning Resource Center 133	7/28/2021	08/05/2021	A1G0852-36	Lead	1.86	0.2	15	ppb
218-DF-6387-N/A-001-A	Intensive Skills 139	7/28/2021	08/05/2021	A1G0852-37	Lead	2.37	0.2	15	ppb
218-DF-6386-N/A-001-A	Intensive Skills 141	7/28/2021	08/05/2021	A1G0852-38	Lead	3.40	0.2	15	ppb
218-DF-6384-N/A-001-A	Teacher Collaboration Offices 140	7/28/2021	08/05/2021	A1G0852-39	Lead	10.6	0.2	15	ppb
218-DF-6385-N/A-001-A	Behavioral 147	7/28/2021	08/05/2021	A1G0852-40	Lead	1.97	0.2	15	ppb
218-DF-6383-A-001-A	Hall (Flexible Learning FX145)	7/28/2021	08/05/2021	A1G0852-41	Lead	ND	0.2	15	ppb
218-DF-6367-N/A-001-A	Custodial Break 155B	7/28/2021	08/05/2021	A1G0852-42	Lead	6.08	0.2	15	ppb
218-DF-6365-N/A-001-A	Infant Room 159D	7/28/2021	08/05/2021	A1G0852-43	Lead	5.37	0.2	15	ppb
218-DF-6366-N/A-001-A	Infant Room 159D	7/28/2021	08/05/2021	A1G0852-44	Lead	0.725	0.2	15	ppb
218-DF-6364-N/A-001-A	Crawler Room 159C	7/28/2021	08/05/2021	A1G0852-45	Lead	3.58	0.2	15	ppb
218-DF-6363-N/A-001-A	Crawler Room 159C	7/28/2021	08/05/2021	A1G0852-46	Lead	6.83	0.2	15	ppb
218-DF-6362-N/A-001-A	Toddler Room 159B	7/28/2021	08/05/2021	A1G0852-47	Lead	2.78	0.2	15	ppb
218-DF-6361-N/A-001-A	Toddler Room 159B	7/28/2021	08/10/2021	A1G0852-48	Lead	6.27	0.2	15	ppb
218-DF-6368-N/A-001-A	Kitchen/Storage 159J	7/28/2021	08/05/2021	A1G0852-49	Lead	5.85	0.2	15	ppb
218-DF-6369-N/A-001-A	Breast Feeding 157	7/28/2021	08/05/2021	A1G0852-50	Lead	0.400	0.2	15	ppb
218-DF-6357-N/A-001-A	Clinic Conf/Break Room 161D	7/28/2021	08/05/2021	A1G0852-51	Lead	8.70	0.2	15	ppb
218-DF-6358-A-001-A	Hall H109 (165)	7/28/2021	08/05/2021	A1G0852-52	Lead	ND	0.2	15	ppb
218-DF-6359-N/A-001-A	Bandroom 165	7/28/2021	08/05/2021	A1G0852-53	Lead	0.590	0.2	15	ppb
218-DF-6360-N/A-001-A	Dressing Room/Make-Up 175	7/28/2021	08/05/2021	A1G0852-54	Lead	0.756	0.2	15	ppb
218-DF-6370-N/A-001-A	Production Storage 179E	7/28/2021	08/05/2021	A1G0852-55	Lead	3.42	0.2	15	ppb
218-DF-6389-N/A-001-A	Text Storage/Work Room 131	7/28/2021	08/05/2021	A1G0852-56	Lead	11.9	0.2	15	ppb
218-DF-6390-N/A-001-A	Small Instruction/Student Store 124	7/28/2021	08/05/2021	A1G0852-57	Lead	3.69	0.2	15	ppb
218-DF-6391-A-001-A	Staff Room 112B	7/28/2021	08/05/2021	A1G0852-58	Lead	ND	0.2	15	ppb
218-DF-6392-N/A-001-A	Hall H103 (Restroom 123)	7/28/2021	08/05/2021	A1G0852-59	Lead	3.01	0.2	15	ppb

Analyzed by: Apex Laboratories

*OHA Action Level = 15ppb

Reviewed by: PSI-Intertek

218-DF-6393-N/A-001-A	Hall 100Q (VP 100E)	7/28/2021	08/05/2021	A1G0852-60	Lead	0.892	0.2	15	ppb
218-DF-6396-N/A-001-A	CTE Flex Lab 105	7/28/2021	08/05/2021	A1G0852-61	Lead	8.89	0.2	15	ppb
218-DF-6395-N/A-001-A	CTE Flex Lab 105	7/28/2021	08/05/2021	A1G0852-62	Lead	7.29	0.2	15	ppb
218-DF-6394-N/A-001-A	CTE Flex Lab 105	7/28/2021	08/05/2021	A1G0852-63	Lead	10.3	0.2	15	ppb
218-DF-6345-N/A-001-A	Training Room G104	7/28/2021	08/05/2021	A1G0852-64	Lead	1.16	0.2	15	ppb
218-DF-6344-N/A-001-A	Training Room G103	7/28/2021	08/05/2021	A1G0852-65	Lead	4.25	0.2	15	ppb

*OHA Action Level = 15ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek