

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Alliance High School at Meek

Sample Identification #	Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
270-1741-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 105	8/10/2018	8/23/2018	A8H0309-01RE1	Copper	0.692	0.00200	1.3	ppm
270-1741-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 105	8/10/2018	8/23/2018	A8H0309-01RE1	Lead	81.0	0.200	15	ppb
270-1741-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 105	8/10/2018	8/17/2018	A8H0309-02RE1	Copper	0.113	0.00200	1.3	ppm
270-1741-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 105	8/10/2018	8/15/2018	A8H0309-02	Lead	17.0	0.200	15	ppb
270-1735-N/A-001-A	Drinking Fountain (Metal) - Hallway near 106	8/10/2018	8/17/2018	A8H0309-03RE1	Copper	0.373	0.00200	1.3	ppm
270-1735-N/A-001-A	Drinking Fountain (Metal) - Hallway near 106	8/10/2018	8/15/2018	A8H0309-03	Lead	33.0	0.200	15	ppb
270-1735-N/A-001-B	Drinking Fountain (Metal) - Hallway near 106	8/10/2018	8/17/2018	A8H0309-04RE1	Copper	0.0541	0.00200	1.3	ppm
270-1735-N/A-001-B	Drinking Fountain (Metal) - Hallway near 106	8/10/2018	8/15/2018	A8H0309-04	Lead	3.29	0.200	15	ppb
270-1732-N/A-001-A	Sink Bubbler - Classroom 109	8/10/2018	8/21/2018	A8H0309-05RE2	Copper	0.0715	0.0100	1.3	ppm
270-1732-N/A-001-A	Sink Bubbler - Classroom 109	8/10/2018	8/15/2018	A8H0309-05	Lead	34.8	0.200	15	ppb
270-1732-N/A-001-B	Sink Bubbler - Classroom 109	8/10/2018	8/17/2018	A8H0309-06RE1	Copper	0.0216	0.00200	1.3	ppm
270-1732-N/A-001-B	Sink Bubbler - Classroom 109	8/10/2018	8/15/2018	A8H0309-06	Lead	28.5	0.200	15	ppb
270-1391-N/A-001-A	Sink (Food Prep) - Kitchen	8/10/2018	8/17/2018	A8H0309-07RE1	Copper	0.264	0.00200	1.3	ppm
270-1391-N/A-001-A	Sink (Food Prep) - Kitchen	8/10/2018	8/15/2018	A8H0309-07	Lead	9.07	0.200	15	ppb
270-1391-N/A-001-B	Sink (Food Prep) - Kitchen	8/10/2018	8/17/2018	A8H0309-08RE1	Copper	0.527	0.00200	1.3	ppm
270-1391-N/A-001-B	Sink (Food Prep) - Kitchen	8/10/2018	8/15/2018	A8H0309-08	Lead	2.41	0.200	15	ppb
270-1388-N/A-001-A	Coffee Maker - Kitchen	8/10/2018	8/18/2018	A8H0309-09RE1	Copper	0.0905	0.00200	1.3	ppm
270-1388-N/A-001-A	Coffee Maker - Kitchen	8/10/2018	8/15/2018	A8H0309-09	Lead	6.77	0.200	15	ppb
270-1388-N/A-001-B	Coffee Maker - Kitchen	8/10/2018	8/18/2018	A8H0309-10RE1	Copper	0.185	0.00200	1.3	ppm
270-1388-N/A-001-B	Coffee Maker - Kitchen	8/10/2018	8/15/2018	A8H0309-10	Lead	6.43	0.200	15	ppb
270-1401-N/A-001-A	Sink Bubbler - Classroom 110B	8/10/2018	8/23/2018	A8H0309-11RE1	Copper	0.567	0.00200	1.3	ppm
270-1401-N/A-001-A	Sink Bubbler - Classroom 110B	8/10/2018	8/23/2018	A8H0309-11RE1	Lead	24.4	0.200	15	ppb
270-1401-N/A-001-B	Sink Bubbler - Classroom 110B	8/10/2018	8/21/2018	A8H0309-12RE1	Copper	1.16	0.0200	1.3	ppm

270-1401-N/A-001-B	Sink Bubblers - Classroom 110B	8/10/2018	8/23/2018	A8H0309-12RE2	Lead	9.62	0.200	15	ppb
270-1403-N/A-001-A	Sink Bubblers - Classroom 111	8/10/2018	8/18/2018	A8H0309-13RE1	Copper	0.791	0.00200	1.3	ppm
270-1403-N/A-001-A	Sink Bubblers - Classroom 111	8/10/2018	8/15/2018	A8H0309-13	Lead	25.5	0.200	15	ppb
270-1403-N/A-001-B	Sink Bubblers - Classroom 111	8/10/2018	8/18/2018	A8H0309-14RE1	Copper	0.851	0.00200	1.3	ppm
270-1403-N/A-001-B	Sink Bubblers - Classroom 111	8/10/2018	8/15/2018	A8H0309-14	Lead	6.04	0.200	15	ppb
270-1400-N/A-001-A	Sink Bubblers - Classroom 113	8/10/2018	8/18/2018	A8H0309-15RE1	Copper	0.511	0.00200	1.3	ppm
270-1400-N/A-001-A	Sink Bubblers - Classroom 113	8/10/2018	8/15/2018	A8H0309-15	Lead	24.0	0.200	15	ppb
270-1400-N/A-001-B	Sink Bubblers - Classroom 113	8/10/2018	8/21/2018	A8H0309-16RE2	Copper	0.769	0.00200	1.3	ppm
270-1400-N/A-001-B	Sink Bubblers - Classroom 113	8/10/2018	8/15/2018	A8H0309-16	Lead	7.30	0.200	15	ppb
270-1397-A-001-A	Sink (Food Prep) - Staff Room 110A	8/10/2018	8/21/2018	A8H0309-17RE2	Copper	0.562	0.00200	1.3	ppm
270-1397-A-001-A	Sink (Food Prep) - Staff Room 110A	8/10/2018	8/15/2018	A8H0309-17	Lead	10.5	0.200	15	ppb
270-1397-A-001-B	Sink (Food Prep) - Staff Room 110A	8/10/2018	8/21/2018	A8H0309-18RE3	Copper	0.903	0.00200	1.3	ppm
270-1397-A-001-B	Sink (Food Prep) - Staff Room 110A	8/10/2018	8/15/2018	A8H0309-18RE1	Lead	1.51	1.00	15	ppb
270-1397-B-001-A	Sink Bubblers - Staff Room 110A	8/10/2018	8/21/2018	A8H0309-19RE2	Copper	0.326	0.00200	1.3	ppm
270-1397-B-001-A	Sink Bubblers - Staff Room 110A	8/10/2018	8/15/2018	A8H0309-19	Lead	13.8	0.200	15	ppb
270-1397-B-001-B	Sink Bubblers - Staff Room 110A	8/10/2018	8/21/2018	A8H0309-20RE2	Copper	0.606	0.00200	1.3	ppm
270-1397-B-001-B	Sink Bubblers - Staff Room 110A	8/10/2018	8/15/2018	A8H0309-20	Lead	6.96	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.