

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
2nd Site Visit - Alliance High School at Meek

Sample Identification #	Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
270-1401-N/A-001-A	Classroom Sink Bubbler - Classroom 110-B	8/29/2018	9/5/2018	A8H0820-01RE1	Copper	0.327	0.00200	1.3	ppm
270-1401-N/A-001-A	Classroom Sink Bubbler - Classroom 110-B	8/29/2018	9/4/2018	A8H0820-01	Lead	5.95	0.200	15	ppb
270-1401-N/A-001-B	Classroom Sink Bubbler - Classroom 110-B	8/29/2018	9/5/2018	A8H0820-02RE1	Copper	0.765	0.00200	1.3	ppm
270-1401-N/A-001-B	Classroom Sink Bubbler - Classroom 110-B	8/29/2018	9/4/2018	A8H0820-02	Lead	2.92	0.200	15	ppb
270-1391-N/A-001-A	Sink (Food Prep) - Kitchen	8/29/2018	9/6/2018	A8H0820-03RE2	Copper	0.267	0.00200	1.3	ppm
270-1391-N/A-001-A	Sink (Food Prep) - Kitchen	8/29/2018	9/4/2018	A8H0820-03	Lead	5.79	0.200	15	ppb
270-1391-N/A-001-B	Sink (Food Prep) - Kitchen	8/29/2018	9/5/2018	A8H0820-04RE1	Copper	0.374	0.00200	1.3	ppm
270-1391-N/A-001-B	Sink (Food Prep) - Kitchen	8/29/2018	9/4/2018	A8H0820-04	Lead	3.51	0.200	15	ppb
270-1388-N/A-001-A	Coffee Maker - Kitchen	8/29/2018	9/5/2018	A8H0820-05RE1	Copper	0.0745	0.00200	1.3	ppm
270-1388-N/A-001-A	Coffee Maker - Kitchen	8/29/2018	9/4/2018	A8H0820-05	Lead	5.63	0.200	15	ppb
270-1388-N/A-001-B	Coffee Maker - Kitchen	8/29/2018	9/5/2018	A8H0820-06RE1	Copper	0.0750	0.00200	1.3	ppm
270-1388-N/A-001-B	Coffee Maker - Kitchen	8/29/2018	9/4/2018	A8H0820-06	Lead	5.78	0.200	15	ppb
270-1403-N/A-001-A	Sink Bubbler - Classroom 111	8/29/2018	9/5/2018	A8H0820-07RE1	Copper	0.590	0.00200	1.3	ppm
270-1403-N/A-001-A	Sink Bubbler - Classroom 111	8/29/2018	9/4/2018	A8H0820-07	Lead	19.8	0.200	15	ppb
270-1403-N/A-001-B	Sink Bubbler - Classroom 111	8/29/2018	9/5/2018	A8H0820-08RE1	Copper	0.921	0.00200	1.3	ppm
270-1403-N/A-001-B	Sink Bubbler - Classroom 111	8/29/2018	9/4/2018	A8H0820-08	Lead	8.64	0.200	15	ppb
270-1394-N/A-001-A	Classroom Sink Bubbler - Classroom 112	8/29/2018	9/10/2018	A8H0820-09RE1	Copper	4.15	0.0200	1.3	ppm
270-1394-N/A-001-A	Classroom Sink Bubbler - Classroom 112	8/29/2018	9/10/2018	A8H0820-09RE1	Lead	398	2.00	15	ppb
270-1394-N/A-001-B	Classroom Sink Bubbler - Classroom 112	8/29/2018	9/5/2018	A8H0820-10RE1	Copper	0.854	0.00200	1.3	ppm
270-1394-N/A-001-B	Classroom Sink Bubbler - Classroom 112	8/29/2018	9/4/2018	A8H0820-10	Lead	6.16	0.200	15	ppb
270-1400-N/A-001-A	Classroom Sink Bubbler - Classroom 113	8/29/2018	9/5/2018	A8H0820-11RE2	Copper	0.621	0.00200	1.3	ppm
270-1400-N/A-001-A	Classroom Sink Bubbler - Classroom 113	8/29/2018	9/4/2018	A8H0820-11	Lead	28.2	0.200	15	ppb
270-1400-N/A-001-B	Classroom Sink Bubbler - Classroom 113	8/29/2018	9/5/2018	A8H0820-12RE1	Copper	0.674	0.00200	1.3	ppm

270-1400-N/A-001-B	Classroom Sink Bubbler - Classroom 113	8/29/2018	9/4/2018	A8H0820-12	Lead	6.95	0.200	15	ppb
270-1397-A-001-A	Sink (Food Prep) - Staff Room 110-A	8/29/2018	9/5/2018	A8H0820-13RE1	Copper	0.544	0.00200	1.3	ppm
270-1397-A-001-A	Sink (Food Prep) - Staff Room 110-A	8/29/2018	9/4/2018	A8H0820-13	Lead	16.9	0.200	15	ppb
270-1397-A-001-B	Sink (Food Prep) - Staff Room 110-A	8/29/2018	9/5/2018	A8H0820-14RE1	Copper	0.948	0.00200	1.3	ppm
270-1397-A-001-B	Sink (Food Prep) - Staff Room 110-A	8/29/2018	9/4/2018	A8H0820-14	Lead	1.49	0.200	15	ppb
270-1397-B-001-A	Classroom Sink Bubbler - Staff Room 110-A	8/29/2018	9/5/2018	A8H0820-15RE1	Copper	0.229	0.00200	1.3	ppm
270-1397-B-001-A	Classroom Sink Bubbler - Staff Room 110-A	8/29/2018	9/4/2018	A8H0820-15	Lead	3.98	0.200	15	ppb
270-1397-B-001-B	Classroom Sink Bubbler - Staff Room 110-A	8/29/2018	9/5/2018	A8H0820-16	Copper	0.381	0.00200	1.3	ppm
270-1397-B-001-B	Classroom Sink Bubbler - Staff Room 110-A	8/29/2018	9/5/2018	A8H0820-16	Lead	2.82	0.200	15	ppb
270-1732-N/A-001-A	Classroom Sink Bubbler - Classroom 109	8/29/2018	9/5/2018	A8H0820-17	Copper	0.0478	0.00200	1.3	ppm
270-1732-N/A-001-A	Classroom Sink Bubbler - Classroom 109	8/29/2018	9/5/2018	A8H0820-17	Lead	16.6	0.200	15	ppb
270-1732-N/A-001-B	Classroom Sink Bubbler - Classroom 109	8/29/2018	9/5/2018	A8H0820-18	Copper	0.0132	0.00200	1.3	ppm
270-1732-N/A-001-B	Classroom Sink Bubbler - Classroom 109	8/29/2018	9/5/2018	A8H0820-18	Lead	5.28	0.200	15	ppb
270-1741-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 105	8/29/2018	9/5/2018	A8H0820-19	Copper	0.0382	0.00200	1.3	ppm
270-1741-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 105	8/29/2018	9/5/2018	A8H0820-19	Lead	11.8	0.200	15	ppb
270-1741-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 105	8/29/2018	9/5/2018	A8H0820-20	Copper	0.0179	0.00200	1.3	ppm
270-1741-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 105	8/29/2018	9/5/2018	A8H0820-20	Lead	6.20	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.