

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Meek - Test 5**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
270-CH1382-N/A-005-A	Kitchen	3/27/2019	4/9/2019	A9C1072-01	Lead	3.01	0.20	15	ppb
270-CH1394-N/A-005-A	Classroom 112	3/27/2019	4/9/2019	A9C1072-08	Lead	99.40	0.20	15	ppb
270-CH1735-N/A-005-A	Hallway	3/27/2019	4/9/2019	A9C1072-10	Lead	18.50	0.20	15	ppb
270-CH1738-N/A-005-A	Hallway	3/27/2019	4/9/2019	A9C1072-12	Lead	8.29	0.20	15	ppb
270-CH1750-N/A-005-A	Classroom 102	3/27/2019	4/9/2019	A9C1072-14	Lead	38.10	0.20	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.