

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Metropolitan Learning Center

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
154-1977-A-002-A Hallway (113)	11/08/18 6:21 AM	11/12/18 2:08 PM	18029549	Copper	1.5	1.3	ppm
154-1977-A-002-A Hallway (113)	11/08/18 6:21 AM	11/12/18 2:08 PM	18029549	Lead	46	15	ppb
154-1977-A-002-B Hallway (113)	11/08/18 6:22 AM	11/12/18 2:11 PM	18029550	Copper	0.1	1.3	ppm
154-1977-A-002-B Hallway (113)	11/08/18 6:22 AM	11/12/18 2:11 PM	18029550	Lead	13	15	ppb
154-1978-A-002-A Hallway (113)	11/08/18 6:24 AM	11/15/18 1:46 PM	18029551	Copper	0.7	1.3	ppm
154-1978-A-002-A Hallway (113)	11/08/18 6:24 AM	11/15/18 1:46 PM	18029551	Lead	36	15	ppb
154-1978-A-002-B Hallway (113)	11/08/18 6:25 AM	11/15/18 1:50 PM	18029552	Copper	0.1	1.3	ppm
154-1978-A-002-B Hallway (113)	11/08/18 6:25 AM	11/15/18 1:50 PM	18029552	Lead	14	15	ppb
154-1979-A-002-A Hallway (204)	11/08/18 6:31 AM	11/12/18 2:15 PM	18029553	Copper	1.2	1.3	ppm
154-1979-A-002-A Hallway (204)	11/08/18 6:31 AM	11/12/18 2:15 PM	18029553	Lead	12	15	ppb
154-1979-A-002-B Hallway (204)	11/08/18 6:32 AM	11/15/18 1:54 PM	18029554	Copper	0.9	1.3	ppm
154-1979-A-002-B Hallway (204)	11/08/18 6:32 AM	11/15/18 1:54 PM	18029554	Lead	1	15	ppb
154-1981-A-002-A Classroom 103 (Pool)	11/08/18 6:37 AM	11/12/18 2:18 PM	18029555	Copper	0.9	1.3	ppm
154-1981-A-002-A Classroom 103 (Pool)	11/08/18 6:37 AM	11/12/18 2:18 PM	18029555	Lead	13	15	ppb
154-1981-A-002-B Classroom 103 (Pool)	11/08/18 6:38 AM	11/12/18 2:21 PM	18029556	Copper	0.6	1.3	ppm
154-1981-A-002-B Classroom 103 (Pool)	11/08/18 6:38 AM	11/12/18 2:21 PM	18029556	Lead	1	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.