

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Mt. Tabor Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	PPS Action Level*	Units
176-3682-A-001A Drinking Fountain by Rm 137	08/02/18 11:52 AM	08/07/18 5:18 PM	18017389	Copper	1.7	1.3	ppm
176-3682-A-001A Drinking Fountain by Rm 137	08/02/18 11:52 AM	08/06/18 7:19 PM	18017389	Lead	13	15	ppb
176-3682-A-001B Drinking Fountain by Rm 137	08/02/18 11:52 AM	08/07/18 5:22 PM	18017390	Copper	1.5	1.3	ppm
176-3682-A-001B Drinking Fountain by Rm 137	08/02/18 11:52 AM	08/06/18 6:23 PM	18017390	Lead	5	15	ppb
176-3678-A-001A Drinking Fountain by Rm 122	08/02/18 11:57 AM	08/06/18 6:24 PM	18017387	Copper	0.5	1.3	ppm
176-3678-A-001A Drinking Fountain by Rm 122	08/02/18 11:57 AM	08/06/18 6:24 PM	18017387	Lead	5	15	ppb
176-3678-A-001B Drinking Fountain by Rm 122	08/02/18 11:57 AM	08/06/18 7:21 PM	18017388	Copper	0.4	1.3	ppm
176-3678-A-001B Drinking Fountain by Rm 122	08/02/18 11:57 AM	08/06/18 7:21 PM	18017388	Lead	<1	15	ppb
176-3685-A-001A Gymnasium	08/02/18 12:10 PM	08/07/18 5:28 PM	18017392	Copper	1.1	1.3	ppm
176-3685-A-001A Gymnasium	08/02/18 12:10 PM	08/06/18 7:22 PM	18017392	Lead	11	15	ppb
176-3685-A-001B Gymnasium	08/02/18 12:10 PM	08/06/18 7:24 PM	18017391	Copper	0.6	1.3	ppm
176-3685-A-001B Gymnasium	08/02/18 12:10 PM	08/06/18 7:24 PM	18017391	Lead	3	15	ppb
176-3698-A-001A Auditorium	08/02/18 12:15 PM	08/06/18 7:26 PM	18017386	Copper	0.4	1.3	ppm
176-3698-A-001A Auditorium	08/02/18 12:15 PM	08/06/18 7:26 PM	18017386	Lead	4	15	ppb
176-3698-A-001B Auditorium	08/02/18 12:15 PM	08/06/18 6:26 PM	18017385	Copper	0.2	1.3	ppm
176-3698-A-001B Auditorium	08/02/18 12:15 PM	08/06/18 6:26 PM	18017385	Lead	<1	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.