

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Mt. Tabor

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
176-CH3674-N/A-002-A	Room 101	11/3/2018	11/7/2018	A8K0193-03RE1	Copper	1.06	0.0100	1.3	ppm
176-CH3674-N/A-002-A	Room 101	11/3/2018	11/7/2018	A8K0193-03	Lead	5.40	0.200	15	ppb
176-CH3674-N/A-002-B	Room 101	11/3/2018	11/7/2018	A8K0193-04	Copper	0.755	0.00200	1.3	ppm
176-CH3674-N/A-002-B	Room 101	11/3/2018	11/7/2018	A8K0193-04	Lead	1.31	0.200	15	ppb
176-CH3675-N/A-002-A	Room 120	11/3/2018	11/7/2018	A8K0193-55RE1	Copper	2.44	0.0200	1.3	ppm
176-CH3675-N/A-002-A	Room 120	11/3/2018	11/7/2018	A8K0193-55	Lead	38.2	0.200	15	ppb
176-CH3675-N/A-002-B	Room 120	11/3/2018	11/7/2018	A8K0193-56	Copper	0.760	0.00200	1.3	ppm
176-CH3675-N/A-002-B	Room 120	11/3/2018	11/7/2018	A8K0193-56	Lead	2.93	0.200	15	ppb
176-CH3676-N/A-002-A	Room 135	11/3/2018	11/7/2018	A8K0193-21	Copper	0.303	0.00200	1.3	ppm
176-CH3676-N/A-002-A	Room 135	11/3/2018	11/7/2018	A8K0193-21	Lead	7.67	0.200	15	ppb
176-CH3676-N/A-002-B	Room 135	11/3/2018	11/7/2018	A8K0193-22	Copper	0.364	0.00200	1.3	ppm
176-CH3676-N/A-002-B	Room 135	11/3/2018	11/7/2018	A8K0193-22	Lead	3.02	0.200	15	ppb
176-CH3677-N/A-002-A	Room 103	11/3/2018	11/7/2018	A8K0193-05	Copper	0.515	0.00200	1.3	ppm
176-CH3677-N/A-002-A	Room 103	11/3/2018	11/7/2018	A8K0193-05	Lead	2.43	0.200	15	ppb
176-CH3677-N/A-002-B	Room 103	11/3/2018	11/7/2018	A8K0193-06	Copper	0.307	0.00200	1.3	ppm
176-CH3677-N/A-002-B	Room 103	11/3/2018	11/7/2018	A8K0193-06	Lead	0.754	0.200	15	ppb

Analyzed by:

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

Page 1 of 7

176-CH3679-N/A-002-A	Room 138	11/3/2018	11/7/2018	A8K0193-25	Copper	0.702	0.00200	1.3	ppm
176-CH3679-N/A-002-A	Room 138	11/3/2018	11/7/2018	A8K0193-25	Lead	6.45	0.200	15	ppb
176-CH3679-N/A-002-B	Room 138	11/3/2018	11/7/2018	A8K0193-26	Copper	0.473	0.00200	1.3	ppm
176-CH3679-N/A-002-B	Room 138	11/3/2018	11/7/2018	A8K0193-26	Lead	1.23	0.200	15	ppb
176-CH3680-N/A-002-A	Room 105	11/3/2018	11/7/2018	A8K0193-07	Copper	0.887	0.00200	1.3	ppm
176-CH3680-N/A-002-A	Room 105	11/3/2018	11/7/2018	A8K0193-07	Lead	1.92	0.200	15	ppb
176-CH3680-N/A-002-B	Room 105	11/3/2018	11/7/2018	A8K0193-08	Copper	0.563	0.00200	1.3	ppm
176-CH3680-N/A-002-B	Room 105	11/3/2018	11/7/2018	A8K0193-08	Lead	0.639	0.200	15	ppb
176-CH3681-N/A-002-A	Room 107	11/3/2018	11/7/2018	A8K0193-11RE1	Copper	0.526	0.00200	1.3	ppm
176-CH3681-N/A-002-A	Room 107	11/3/2018	11/7/2018	A8K0193-11RE1	Lead	1.65	0.200	15	ppb
176-CH3681-N/A-002-B	Room 107	11/3/2018	11/7/2018	A8K0193-12	Copper	0.359	0.00200	1.3	ppm
176-CH3681-N/A-002-B	Room 107	11/3/2018	11/7/2018	A8K0193-12	Lead	0.889	0.200	15	ppb
176-CH3682-N/A-002-A	Gym 137	11/3/2018	11/7/2018	A8K0193-27RE1	Copper	2.21	0.0100	1.3	ppm
176-CH3682-N/A-002-A	Gym 137	11/3/2018	11/7/2018	A8K0193-27	Lead	11.6	0.200	15	ppb
176-CH3682-N/A-002-B	Gym 137	11/3/2018	11/7/2018	A8K0193-28RE1	Copper	1.64	0.0100	1.3	ppm
176-CH3682-N/A-002-B	Gym 137	11/3/2018	11/7/2018	A8K0193-28	Lead	1.86	0.200	15	ppb
176-CH3683-N/A-002-A	Room 112	11/3/2018	11/7/2018	A8K0193-09RE1	Copper	1.59	0.0100	1.3	ppm
176-CH3683-N/A-002-A	Room 112	11/3/2018	11/7/2018	A8K0193-09	Lead	14.9	0.200	15	ppb
176-CH3683-N/A-002-B	Room 112	11/3/2018	11/7/2018	A8K0193-10RE1	Copper	2.01	0.0100	1.3	ppm
176-CH3683-N/A-002-B	Room 112	11/3/2018	11/7/2018	A8K0193-10	Lead	3.62	0.200	15	ppb

Analyzed by:

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

Page 2 of 7

176-CH3684-N/A-002-A	Room 109	11/3/2018	11/7/2018	A8K0193-13	Copper	0.821	0.00200	1.3	ppm
176-CH3684-N/A-002-A	Room 109	11/3/2018	11/7/2018	A8K0193-13	Lead	16.0	0.200	15	ppb
176-CH3684-N/A-002-B	Room 109	11/3/2018	11/7/2018	A8K0193-14	Copper	0.436	0.00200	1.3	ppm
176-CH3684-N/A-002-B	Room 109	11/3/2018	11/7/2018	A8K0193-14	Lead	2.83	0.200	15	ppb
176-CH3687-N/A-002-A	Room 111	11/3/2018	11/7/2018	A8K0193-15RE1	Copper	3.16	0.0200	1.3	ppm
176-CH3687-N/A-002-A	Room 111	11/3/2018	11/7/2018	A8K0193-15	Lead	31.1	0.200	15	ppb
176-CH3687-N/A-002-B	Room 111	11/3/2018	11/7/2018	A8K0193-16RE1	Copper	2.21	0.0200	1.3	ppm
176-CH3687-N/A-002-B	Room 111	11/3/2018	11/7/2018	A8K0193-16	Lead	2.36	0.200	15	ppb
176-CH3688-N/A-002-A	Room 139	11/3/2018	11/7/2018	A8K0193-59RE1	Copper	1.82	0.0100	1.3	ppm
176-CH3688-N/A-002-A	Room 139	11/3/2018	11/7/2018	A8K0193-59	Lead	14.5	0.200	15	ppb
176-CH3688-N/A-002-B	Room 139	11/3/2018	11/7/2018	A8K0193-60RE1	Copper	1.36	0.0100	1.3	ppm
176-CH3688-N/A-002-B	Room 139	11/3/2018	11/7/2018	A8K0193-60	Lead	15.5	0.200	15	ppb
176-CH3689-N/A-002-A	Kitchen Prep Sink	11/3/2018	11/7/2018	A8K0193-01RE1	Copper	0.142	0.00200	1.3	ppm
176-CH3689-N/A-002-A	Kitchen Prep Sink	11/3/2018	11/7/2018	A8K0193-01RE1	Lead	ND	0.200	15	ppb
176-CH3689-N/A-002-B	Kitchen Prep Sink	11/3/2018	11/7/2018	A8K0193-02	Copper	0.115	0.00200	1.3	ppm
176-CH3689-N/A-002-B	Kitchen Prep Sink	11/3/2018	11/7/2018	A8K0193-02	Lead	ND	0.200	15	ppb
176-CH3690-N/A-002-A	Room 113	11/3/2018	11/7/2018	A8K0193-17RE1	Copper	1.08	0.0100	1.3	ppm
176-CH3690-N/A-002-A	Room 113	11/3/2018	11/7/2018	A8K0193-17	Lead	11.2	0.200	15	ppb
176-CH3690-N/A-002-B	Room 113	11/3/2018	11/7/2018	A8K0193-18	Copper	0.945	0.00200	1.3	ppm
176-CH3690-N/A-002-B	Room 113	11/3/2018	11/7/2018	A8K0193-18	Lead	1.39	0.200	15	ppb

Analyzed by:

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

Page 3 of 7

176-CH3691-N/A-002-A	Room 130	11/3/2018	11/7/2018	A8K0193-29	Copper	0.597	0.00200	1.3	ppm
176-CH3691-N/A-002-A	Room 130	11/3/2018	11/7/2018	A8K0193-29	Lead	6.04	0.200	15	ppb
176-CH3691-N/A-002-B	Room 130	11/3/2018	11/7/2018	A8K0193-30	Copper	0.392	0.00200	1.3	ppm
176-CH3691-N/A-002-B	Room 130	11/3/2018	11/7/2018	A8K0193-30	Lead	1.56	0.200	15	ppb
176-CH3693-N/A-002-A	Room 115	11/3/2018	11/7/2018	A8K0193-19	Copper	0.770	0.00200	1.3	ppm
176-CH3693-N/A-002-A	Room 115	11/3/2018	11/7/2018	A8K0193-19	Lead	5.41	0.200	15	ppb
176-CH3693-N/A-002-B	Room 115	11/3/2018	11/7/2018	A8K0193-20	Copper	0.577	0.00200	1.3	ppm
176-CH3693-N/A-002-B	Room 115	11/3/2018	11/7/2018	A8K0193-20	Lead	1.21	0.200	15	ppb
176-CH3696-N/A-002-A	Room 131	11/3/2018	11/7/2018	A8K0193-23	Copper	0.317	0.00200	1.3	ppm
176-CH3696-N/A-002-A	Room 131	11/3/2018	11/7/2018	A8K0193-23	Lead	15.8	0.200	15	ppb
176-CH3696-N/A-002-B	Room 131	11/3/2018	11/7/2018	A8K0193-24	Copper	0.297	0.00200	1.3	ppm
176-CH3696-N/A-002-B	Room 131	11/3/2018	11/7/2018	A8K0193-24	Lead	11.1	0.200	15	ppb
176-CH3697-N/A-002-A	Room 210	11/3/2018	11/7/2018	A8K0193-31	Copper	0.654	0.00200	1.3	ppm
176-CH3697-N/A-002-A	Room 210	11/3/2018	11/7/2018	A8K0193-31	Lead	6.40	0.200	15	ppb
176-CH3697-N/A-002-B	Room 210	11/3/2018	11/7/2018	A8K0193-32	Copper	0.542	0.00200	1.3	ppm
176-CH3697-N/A-002-B	Room 210	11/3/2018	11/7/2018	A8K0193-32	Lead	1.23	0.200	15	ppb
176-CH3699-N/A-002-A	Room 133	11/3/2018	11/7/2018	A8K0193-57	Copper	0.539	0.00200	1.3	ppm
176-CH3699-N/A-002-A	Room 133	11/3/2018	11/7/2018	A8K0193-57	Lead	11.0	0.200	15	ppb
176-CH3699-N/A-002-B	Room 133	11/3/2018	11/7/2018	A8K0193-58	Copper	0.343	0.00200	1.3	ppm
176-CH3699-N/A-002-B	Room 133	11/3/2018	11/7/2018	A8K0193-58	Lead	4.58	0.200	15	ppb

Analyzed by:

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

Page 4 of 7

176-CH3700-N/A-002-A	Room 215	11/3/2018	11/7/2018	A8K0193-33RE1	Copper	0.791	0.00200	1.3	ppm
176-CH3700-N/A-002-A	Room 215	11/3/2018	11/7/2018	A8K0193-33	Copper	0.804	0.00200	1.3	ppm
176-CH3700-N/A-002-A	Room 215	11/3/2018	11/7/2018	A8K0193-33RE1	Lead	4.06	0.200	15	ppb
176-CH3700-N/A-002-B	Room 215	11/3/2018	11/7/2018	A8K0193-34	Copper	0.783	0.00200	1.3	ppm
176-CH3700-N/A-002-B	Room 215	11/3/2018	11/7/2018	A8K0193-34	Lead	0.930	0.200	15	ppb
176-CH3728-N/A-002-A	Room 209	11/3/2018	11/7/2018	A8K0193-35RE1	Copper	1.14	0.0100	1.3	ppm
176-CH3728-N/A-002-A	Room 209	11/3/2018	11/7/2018	A8K0193-35	Lead	10.2	0.200	15	ppb
176-CH3728-N/A-002-B	Room 209	11/3/2018	11/7/2018	A8K0193-36	Copper	0.789	0.00200	1.3	ppm
176-CH3728-N/A-002-B	Room 209	11/3/2018	11/7/2018	A8K0193-36	Lead	1.29	0.200	15	ppb
176-CH3729-N/A-002-A	Room 204	11/3/2018	11/7/2018	A8K0193-51	Copper	0.476	0.00200	1.3	ppm
176-CH3729-N/A-002-A	Room 204	11/3/2018	11/7/2018	A8K0193-51	Lead	8.95	0.200	15	ppb
176-CH3729-N/A-002-B	Room 204	11/3/2018	11/7/2018	A8K0193-52	Copper	0.545	0.00200	1.3	ppm
176-CH3729-N/A-002-B	Room 204	11/3/2018	11/7/2018	A8K0193-52	Lead	1.14	0.200	15	ppb
176-CH3731-N/A-002-A	Room 208	11/3/2018	11/7/2018	A8K0193-37RE1	Copper	1.30	0.0100	1.3	ppm
176-CH3731-N/A-002-A	Room 208	11/3/2018	11/7/2018	A8K0193-37	Lead	18.6	0.200	15	ppb
176-CH3731-N/A-002-B	Room 208	11/3/2018	11/7/2018	A8K0193-38	Copper	0.989	0.00200	1.3	ppm
176-CH3731-N/A-002-B	Room 208	11/3/2018	11/7/2018	A8K0193-38	Lead	3.75	0.200	15	ppb
176-CH3732-N/A-002-A	Staff Lunch Room	11/3/2018	11/7/2018	A8K0193-53	Copper	0.175	0.00200	1.3	ppm
176-CH3732-N/A-002-A	Staff Lunch Room	11/3/2018	11/7/2018	A8K0193-53	Lead	0.411	0.200	15	ppb
176-CH3732-N/A-002-B	Staff Lunch Room	11/3/2018	11/7/2018	A8K0193-54	Copper	0.157	0.00200	1.3	ppm

Analyzed by:

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

Page 5 of 7

176-CH3732-N/A-002-B	Staff Lunch Room	11/3/2018	11/7/2018	A8K0193-54	Lead	ND	0.200	15	ppb
176-CH3737-N/A-002-A	Room 200	11/3/2018	11/7/2018	A8K0193-39RE1	Copper	2.31	0.0200	1.3	ppm
176-CH3737-N/A-002-A	Room 200	11/3/2018	11/7/2018	A8K0193-39	Lead	15.4	0.200	15	ppb
176-CH3737-N/A-002-B	Room 200	11/3/2018	11/7/2018	A8K0193-40RE1	Copper	0.611	0.00200	1.3	ppm
176-CH3737-N/A-002-B	Room 200	11/3/2018	11/7/2018	A8K0193-40RE1	Lead	1.81	0.200	15	ppb
176-CH3740-N/A-002-A	Room 201	11/3/2018	11/7/2018	A8K0193-41	Copper	0.988	0.00200	1.3	ppm
176-CH3740-N/A-002-A	Room 201	11/3/2018	11/7/2018	A8K0193-41	Lead	6.10	0.200	15	ppb
176-CH3740-N/A-002-B	Room 201	11/3/2018	11/7/2018	A8K0193-42	Copper	0.548	0.00200	1.3	ppm
176-CH3740-N/A-002-B	Room 201	11/3/2018	11/7/2018	A8K0193-42	Lead	0.763	0.200	15	ppb
176-CH3743-N/A-002-A	Room 202	11/3/2018	11/7/2018	A8K0193-43	Copper	0.734	0.00200	1.3	ppm
176-CH3743-N/A-002-A	Room 202	11/3/2018	11/7/2018	A8K0193-43	Lead	10.4	0.200	15	ppb
176-CH3743-N/A-002-B	Room 202	11/3/2018	11/7/2018	A8K0193-44	Copper	0.503	0.00200	1.3	ppm
176-CH3743-N/A-002-B	Room 202	11/3/2018	11/7/2018	A8K0193-44	Lead	1.24	0.200	15	ppb
176-CH3746-N/A-002-A	Room 206	11/3/2018	11/7/2018	A8K0193-45	Copper	0.538	0.00200	1.3	ppm
176-CH3746-N/A-002-A	Room 206	11/3/2018	11/7/2018	A8K0193-45	Lead	7.00	0.200	15	ppb
176-CH3746-N/A-002-B	Room 206	11/3/2018	11/7/2018	A8K0193-46	Copper	0.470	0.00200	1.3	ppm
176-CH3746-N/A-002-B	Room 206	11/3/2018	11/7/2018	A8K0193-46	Lead	1.01	0.200	15	ppb
176-CH3749-N/A-002-A	Room 203	11/3/2018	11/7/2018	A8K0193-47	Copper	0.427	0.00200	1.3	ppm
176-CH3749-N/A-002-A	Room 203	11/3/2018	11/7/2018	A8K0193-47	Lead	3.32	0.200	15	ppb
176-CH3749-N/A-002-B	Room 203	11/3/2018	11/7/2018	A8K0193-48	Copper	0.536	0.00200	1.3	ppm

Analyzed by:

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Reviewed by: PBS Engineering and Environmental

Page 6 of 7

176-CH3749-N/A-002-B	Room 203	11/3/2018	11/7/2018	A8K0193-48	Lead	0.611	0.200	15	ppb
176-CH3752-N/A-002-A	Room 205	11/3/2018	11/7/2018	A8K0193-49	Copper	0.415	0.00200	1.3	ppm
176-CH3752-N/A-002-A	Room 205	11/3/2018	11/7/2018	A8K0193-49	Lead	4.29	0.200	15	ppb
176-CH3752-N/A-002-B	Room 205	11/3/2018	11/7/2018	A8K0193-50	Copper	0.454	0.00200	1.3	ppm
176-CH3752-N/A-002-B	Room 205	11/3/2018	11/7/2018	A8K0193-50	Lead	0.624	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

Analyzed by: