

**Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Ockley Green Re-Test 1**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
178-CH2733-N/A-002-A	Hall Bubbler	5/3/2018	5/16/2018	A8E0135-01RE1	Copper	0.907	0.01	1.3	ppm
178-CH2733-N/A-002-A	Hall Bubbler	5/3/2018	5/16/2018	A8E0135-01	Lead	11.6	0.2	15	ppb
178-CH2733-N/A-002-B	Hall Bubbler	5/3/2018	5/16/2018	A8E0135-02	Copper	0.393	0.001	1.3	ppm
178-CH2733-N/A-002-B	Hall Bubbler	5/3/2018	5/16/2018	A8E0135-02	Lead	2.41	0.2	15	ppb
178-CH2745-N/A-002-A	Hall Bubbler	5/3/2018	5/16/2018	A8E0135-03	Copper	0.23	0.001	1.3	ppm
178-CH2745-N/A-002-A	Hall Bubbler	5/3/2018	5/16/2018	A8E0135-03	Lead	14.4	0.2	15	ppb
178-CH2745-N/A-002-B	Hall Bubbler	5/3/2018	5/16/2018	A8E0135-04	Copper	0.142	0.001	1.3	ppm
178-CH2745-N/A-002-B	Hall Bubbler	5/3/2018	5/16/2018	A8E0135-04	Lead	9.27	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Page 1 of 1